

DECLARATION

We, ABB LV Installation Materials Co., Ltd. Beijing hereby declare that power meter of

D1M 15, D1M 15 Modbus, D1M 20 Modbus, D1M 20 Ethernet

are comply with the relevant parts of the following standards for railway applications mentioned in this document.

IEC 61373-2010 - Railway applications – Rolling stock equipment - Shock and vibration tests

These products have passed the vibration test and impact test of IEC 61373-2010 standard Category 1 – Class A/B -Body mounted, and the test results are qualified. They are suitable for operation stably in similar environments.


This declaration is valid for the present design and for the use of the products according to the standards and as displayed in the product data sheets.

Also, a change of the design could make this certificate invalid.

All former declarations or certificates issued by us before date of this declaration/certificate are to be considered null and void and have no further validity.

Yours sincerely,

Zhilong Niu
R&D Manager





Aaron-Wei Jiang
Quality & Continuous
Improvement Manager

ABB LV Installation Materials Co., Ltd. Beijing

Beijing, 2024-07-03

Declaration No: CNIIB24SDMeter070303

