Buffer Block

S8T-DCBU-02

Prevents Equipment Stoppage, Data Loss, and Other Problems Resulting from Momentary Power Failures

- Provides a backup time of 500 ms at an output current of 2.5 A.
- Can be wired to the 24-V output from the S8VS Supplies.
- Connects to an S8TS Power Supply via an S8T-BUS03 Bus Line Connector.
- Parallel connections to up to four Blocks can be used to increase the backup time and current capacities.
- Complies with SEMI F47-0200 standard.
- RoHS-compliant
- Ambient operating temperature range of -20 to 60°C.



Refer to Safety Precautions for All Power Supplies and Safety Precautions on page 16.



For the most recent information on models that have been certified for safety standards, refer to your OMRON website.

Ordering Information

■ Buffer Block

Input voltage	Output voltage (during backup operation)	Output current	Model number
24 VDC (24 to 28 VDC)	22.5 V	2.5 A	S8T-DCBU-02

■ Options (Order Separately)


Bus Line Connector (Connects to Buffer Block)

Туре	Number of Connectors	Model number
Connector with DC line connected.	1 Connector	S8T-BUS03
	10 Connectors (See note.)	S8T-BUS13


Note: One package contains 10 S8T-BUS03 Connectors.

Basic Configuration

Connecting to the S8TS-06024 ☐



Connection via Wiring



Specifications

■ Ratings/Characteristics

Item		Model	S8T-DCBU-02		
Input	Voltage		24 to 28 VDC		
	Current	Charging	0.4 A		
		Standby	0.18 A		
Output (See note 1.)			For 24 V: 22.5 V typ., 22.0 V min. For 28 V: 26.4 V typ., 25.8 V min.		
		Output current	2.5 A		
		Backup time (See note 2.)	Time required until the voltage drops from the fully charged level down to 21.6 VDC 1,000 ms min. (for an output current of 1.2 A) 500 ms min. (for an output current of 2.5 A)		
Additional	Output	READY indicator	Yes (color: green)		
functions	functions	READY output	Yes (relay: 24 VDC, 0.1 A max.)		
	(See note 3.)	Backup indictor	Yes (color: red)		
		Backup output	Yes (relay: 24 VDC, 0.1 A max.)		
	Overcurrent pro	otection	Reverse-L dropping, automatic reset, overcurrent detection point: 5.8 to 6.8 A		
	Overvoltage protection		Yes		
	Parallel operation		Yes (Up to 4 Blocks)		
	Series operation	n	No		
Other	Ambient operating temperature		Refer to the derating curve in Engineering Data. (with no condensation or icing)		
	Storage temperature		−25 to 65°C		
	Ambient humidi	ity	Operating: 25% to 85%; Storage: 25% to 90%		
	Dielectric streng	gth (See note 4.)	1.0 kVAC for 1 minute (between all DC connection terminals and PE terminals; Detection current: 20 mA) 500 VAC for 1 minute (between all DC connection terminals/PE terminals and all signal output terminals; detection current: 20 mA)		
	Insulation resistance		100 M Ω min. (between all DC connection terminals and PE terminals) at 500 VDC		
	Vibration resista	ance (See notes 5 and 6.)	10 to 55 Hz, 0.375-mm single amplitude for 2 h each in X, Y, and Z directions		
	Shock resistant	ce (See notes 5 and 6.)	150 m/s ² , 3 times each in \pm X, \pm Y, and \pm Z directions		
	EMI	Conducted Emission (See note 5.)	Conforms to EN61204-3 EN55011 Class B and based on FCC Class A		
		Radiated Emission	Conforms to EN61204-3 EN55011 Class B		
	EMS	•	Conforms to EN61204-3 High severity levels		
	Approved	UL:	UL508 (Listing; Class 2: Per UL1310) (See note 7.)		
	standards	cUL:	CSA C22.2 No.107.1 (Class 2: Per No. 223) (See note 7.)		
		EN:	EN62477-1		
	SEMI		SEMI F47-0200		
	Weight		450 g max.		

Note: 1. The output characteristics are specified at the power output terminals.

- 2. Refer to Backup Time on page 10 for details.
- 3. Refer to Functions on page 7 for details.
- 4. If the number of S8T-DCBU-02 Buffer Blocks to be connected is "N," set the detection current to 20 mA \times N.
- 5. Specified by S8TS-06024 \square connection.
- 6. Be sure to mount an End Plate (PFP-M: Order separately) on each end of the Buffer Block. Refer to DIN Rails on page 15.
- 7. To comply with Class 2, connect one S8TS-06024 $\!\square$ to one S8T-DCBU-02 Buffer Block.


■ Reference Value

Item	Value	Definition
Reliability (MTBF)	135,000 hrs min.	MTBF stands for Mean Time Between Failures, which is calculated according to the probability of accidental device failures, and indicates reliability of devices. Therefore, it does not necessarily represent a life of the product.
Life expectancy	10 yrs. min.	The life expectancy indicates average operating hours under the ambient temperature of 40°C and a load rate of 50%. Normally this is determined by the life expectancy of the built-in aluminum electrolytic capacitor.

Connections

■ Block Diagram

S8T-DCBU-02



Operation

■ Application

Connectable Power Supplies

The following Power Supplies can be connected. When connected to the following Power Supplies, the Buffer Block will function properly against a momentary power failure of at least 300 ms. (See note 1.)

S8TS Series: S8TS-06024

S8VS Series: S8VS-01524, S8VS-03024,

S8VS-06024 (See note 2.), S8VS-06024A/B, S8VS-09024, S8VS-09024S, S8VS-09024A / /B , S8VS-12024 (See note 2.), S8VS-12024A□/B□, S8VS-18024 (See note 2.), S8VS-18024A□/B□, S8VS-24024 (See note 2.), S8VS-24024A□/B□,

and S8VS-48024A/B

S8JX Series: S8JX-N01524 , S8JX-N03024 , S8JX-N05024 , S8JX-N10024 , S8JX-N10024 , S8JX-N30024 , S8JX-N3002 , S8JX-N3002 , S8JX-N3002 , S8JX-N3002 , S8JX-N3002 , S8JX-N30

S8JX-N60024□□


S8VM Series: S8VM-01524 , S8VM-03024 , S8VM-05024 , S8VM-05024 ,

S8VM-10024 , S8VM-15024 ,

S8VM-30024C, S8VM-60024C, and S8VM-15224C

Note: 1. The backup current must be less than 5 A (parallel operation connection is required if the backup current exceeds 2.5 A) and the Buffer Block must be fully charged. If three or more S8T-DCBU-02 Buffer Blocks are used in parallel operation and the backup current exceeds 5 A, the momentary power failure time that can be compensated for will be reduced.

- 2. When connected to the S8VS-06024, S8VS-12024, S8VS-18024, S8VS-24024, or S82J-10024□□ Power Supply, the output voltage may increase by approximately 4 V for several 10 s of milliseconds after recovery from the momentary power failure. If any adverse effect is foreseen, connect a diode as shown below based on the guidelines given below.
- 3. Orders for S8JX-N Series and S8VM Series products are no longer accepted as of March 31, 2019.




Guidelines for Selecting Diode

Type: Schottky barrier diode

Withstanding voltage (V_{RRM}): At least twice the rated output voltage

Forward current (I_F): At least twice the rated output current




Power Supply To Be Connected

The power consumption of the S8T-DCBU-02 is approximately 10 W, so make sure that the output capacity of the connected Power Supply is sufficient.

If the S8T-DCBU-02 is connected to a previously installed power supply, the voltage may drop due to the power supply's overload protection, or backup operations may not be possible.

Note: Connect a Power Supply within the specified derating range, considering the power consumption of the S8T-DCBU-02.

Selecting the Power Supply



Determining the Output Capacity

 Checking Capacities of Devices To Be Connected Check the capacities (W) of the devices to be connected.

2. Calculating the Total Capacity (Including That of the S8T-DCBU-02 Buffer Block)

The S8T-DCBU-02 Buffer Block will consume the following power. Add this to the above capacities (W) of the devices to be connected to obtain the total capacity.

Vin = 24 V: 9.6 W max. (during charging)

Vin = 28 V: 11.2 W max. (during charging)

Calculation of the Total Capacity



3. Calculating the Required Output Capacity

Determine the rate of allowance and apply this allowance rate to the total capacity calculated above to obtain the output capacity required by the Power Supply. Be sure to provide a sufficient allowance rate.

Calculation of the Total Power Supply Capacity



Example: Output voltage: 24 V

Capacities of devices: 36 W (output current: 1.5 A)

Allowance rate: 0.8

Required output capacity of the Power Supply > (36 W

 $+ 9.6 \text{ W}) \div 0.8 = 57 \text{ W}$

Therefore, an S8TS-06024□ Power Supply,

S8VS-06024□ Power Supply, or a Power Supply with a


larger capacity is required.

Selecting the Power Supply To Be Connected


1. Checking the Output Hold Time and Restart Time of the Connected Power Supply

The relation between the momentary power failure time and the backup time required to compensate the failure is shown in the following illustration. As shown by the illustration, the backup time required from the S8T-DCBU-02 Buffer Block depends on the connected Power Supply even for the same momentary power failure time.

Calculation of the Required Backup Time



Relation between Momentary Power Failure and Backup Time



The output hold time and restart time of each Power Supply are shown in Power Supply Output Hold Times (Reference Values) on page 12 and Power Supply Restart Times (Reference Values) on page 13.

Example: S8T-DCBU-02: 1 Unit

Connected Power Supply: S8TS-06024□

Load current: 1 A

AC input voltage: 200 VAC

Assumed momentary power failure time: 300 ms
Required backup time > 300 ms + 270 ms - 100 ms = 470 ms
Refer to the graphs under *Backup Time* on page 10 to check whether the backup time is sufficient.

2. Selecting the Power Supply

After obtaining the output capacity required for the Power Supply and checking its output hold time and restart time as described above, select an appropriate Power Supply from the list under *Connectable Power Supplies* on page 3.

3. Checking the Derating Curve

Confirm that the total output capacity calculated in step 2, Calculating the Total Capacity, under Determining the Output Capacity is within the derating curve of the Power Supply. If the capacity exceeds the derating curve, increase the Power Supply capacity or use forced air cooling to reduce the ambient operating temperature.

Mounting

Mounting Direction


Standard mounting	Yes
Face-up mounting	No
Other mounting	No

Improper mounting will interfere with heat dissipation and may occasionally result in deterioration of or damage to internal parts. Use standard mounting only.

Standard mounting Correct Incorrect


Connecting to the S8TS-06024

When connecting one or more S8T-DCBU-02 Blocks to the S8TS-06024 using Bus Line Connectors, connect them to either the left or right end of the Blocks. Heat dissipation will be interfered with if the S8T-DCBU-02 Blocks are not connected to the end.



Wiring Connections

A load can be connected to either the Power Supply side or the S8T-DCBU-02 side.



Note: Use the largest wire size possible and keep the wiring distance as short as possible. If the voltage drop caused by the wiring material is too large, the backup operation may not be sufficient.

Input Voltage

Input voltage range: 24 to 28 VDC

Confirm that an input voltage of at least 24 V is being supplied to the S8T-DCBU-02 input terminals.

Output Voltage

The output voltage for the backup operation is automatically adjusted internally by detecting the input voltage. The backup operation is started when the input voltage drops 2 $\rm V.$

Note: The output voltage during the backup operation is a maximum of 2 V lower than the voltage input at an input voltage of 24 VDC

Serial Connection

Two Blocks cannot be connected in series to increase the output voltage to 48 V or to create positive and negative outputs.

Parallel Connection

The output current and backup time for the backup operation can be increased by connecting Buffer Blocks in parallel.

Maximum number of Buffer Blocks for parallel operation: 4

When connecting the S8T-DCBU-02 with a Bus Line Connector, use the S8T-BUS03 Bus Line Connector, which connects only the DC lines. (The AC lines are not connected.) If the backup current exceeds 5 A when three or more Buffer Blocks are connected in parallel, the backup time will be greatly reduced. Refer to *Backup Time* on page 10 for details on the backup time during parallel operation.


Note: Although the number of Buffer Blocks that can be connected when using the S8TS-06024□ is five when calculated from the current capacity of the Bus Line Connector, only a maximum of four S8T-DCBU-02 can actually be connected in parallel.

Connecting to S8TS-06024□

When connecting to the S8TS-06024□, always use the S8T-BUS03 Bus Line Connector. This Connector connects only the DC lines. It does not connect AC lines.

S8T-BUS03 Bus Line Connector

The S8T-BUS03 Bus Line Connector is equipped with a selector to prevent incorrect connection to a power supply unit with a different output voltage specification. Slide the selector to the 24 V position.



Inserting and Removing the Bus Line Connector


Pay attention to the following points to maintain electric characteristics.

- Do not insert and remove a Bus Line Connector more than 20 times.
- Do not touch the Bus Line Connector terminals.
- To remove a Bus Line Connector, insert a flat-blade screwdriver alternately at both ends.




Mounting to DIN Rail

To mount the Buffer Block to DIN Rail, hook portion (A) of the Buffer Block onto the Rail and press the Buffer Block in direction (B).




To dismount the Buffer Block, pull down portion (C) with a flat-blade screwdriver and pull out the Buffer Block.



Checking Operation and Periodic Inspection

After connecting the Buffer Blocks, check the Buffer Block using the following procedure to confirm that it operates correctly for momentary power failures on the AC input. Use this procedure for periodic inspection as well.


- 1. Turn ON the AC power of the connected power supply.
- 2. Check the READY indicator on the S8T-DCBU-02 to confirm that it is lit.




Note: Up to 60 seconds is required to charge the internal capacitor before the indicator lights.

Use a timer and create a momentary power failure on the AC input of the expected length of time. Considering variations in characteristics, using 140% or more of the power failure time is recommended.

Operation Check and Periodic Inspection



4. Check to confirm that the expected backup operation was performed. The operation of the BACKUP indicator and BACKUP output should be as shown below during the backup operation. Check these as well.



Note: Check the backup operation under conditions that are safe and will cause no problems if the backup operation fails.

■ Functions

READY Operation

The READY indicator and READY output will function as shown below after the internal capacitor is completely charged and the Buffer Block is ready to perform the backup operation. Up to 60 seconds is required for the capacitor to charge completely.

READY Indicator



READY output relay



(READY: Green)

Relay (READY) (1)-(2): open

The following status will occur if there is an error in the charge voltage of the internal capacitor or the output voltage of the S8T-DCBU-02

READY Indicator



READY output relay



Indicator not lit (READY: Green)

Relay (READY) (1)-(2): closed

The backup operation will not be sufficient or will fail under the above status. If this status occurs, immediately remove the cause of the error, such as the following causes.

- 1. The connected DC voltage is 23 V or less.
- 2. The terminals have been connected in reverse, a wire is broken, or wiring is otherwise not correct.
- 3. The overvoltage protection circuit has operated.
- 4. The overcurrent protection circuit of the connected power supply has operated.

Note: The contact capacity of the output relay is 0.1 A at 24 VDC.

Backup Operation

The S8T-DCBU-02 will switch to the backup operation if a voltage drop is detected on the connected power supply.

BACKUP Indicator





BACKUP output relay

Relay (BACKUP)

When the backup operation functions, the energy in the internal capacitor will be discharged to the load. When the voltage of the power supply then recovers, the S8T-DCBU-02 will start charging the capacitor. Up to 60 seconds is required to charge the capacitor completely. The backup operation may therefore not function for the required period if the backup operation starts while the capacitor is being charged.

The following are examples in which the backup operation may not be sufficient.

- 1. The backup operation starts within 60 seconds after turning ON the power.
- 2. The backup operation is started consecutively within 60 seconds of the previous backup operation.
- 3. A rapid change in the load or other factor causes the DC voltage to drop, resulting in the backup operation, and then the backup operation occurs again within 60 seconds.

The READY indicator and READY output will function as shown below when the internal capacitor is being charged.

READY Indicator



Indicator not lit (READY: Green)

READY output relay



Relay (READY)

- Note: 1. The contact capacity of the output relay is 0.1 A at 24 VDC.
 - 2. The backup operation may be repeatedly performed if the connected power supply is overloaded. Remove the cause of the overload immediately.
 - 3. The backup operation does not detect drops in the AC input.

Overload Protection

The S8T-DCBU-02 is provided with an overload protection function that protects the Power Supply from possible damage due to shortcircuits and overcurrents by automatically decreasing the output if the overcurrent reaches 5.8 to 6.8 A. When the output current falls within the rated range, the overload protection function is automatically cleared.

Note: Internal parts may occasionally deteriorate or be damaged if a short-circuited or other overcurrent state continues during operation.

Overvoltage Protection

If a voltage that is higher than the specified input voltage range is input or the output voltage exceeds the specified voltage, the overvoltage protection circuit will operate at between 31 and 36 V to shut OFF the output voltage and protect the load from damage due to overvoltages. To reset the Buffer Block, turn OFF the input power for at least 1 minute and then turn it back ON.

- Note: 1. Remove the cause of the overvoltage before turn the input power back ON.
 - 2. The backup operation will not be performed when the overvoltage protection is performed to shut OFF the output.


Reverse Connection Protection


The S8T-DCBU-02 will be protected even if the positive and negative I/O terminals are connected in reverse.

Nomenclature

Buffer Block

S8T-DCBU-02





- I: Protective Earthing Terminal (\clubsuit)
- J: I/O Terminal (-V)
- K: I/O Terminal (+V)
- L: Rail Stopper
- M: Connecting part of Bus Line Connector
- N: Terminal Cover

A, B: READY Output: NC contact C, D: BACKUP Output: NC contact


E: READY Indicator (READY: Green)
F: BACKUP Indicator (BACKUP: Red)

G: NC

H: Slider

Bus Line Connector


S8T-BUS03



- A: Selector
- $B\colon \ensuremath{\stackrel{.}{\oplus}}$ Bus Line Connector terminal
- C: NC
- D: DC Bus Line Connector Terminal (+V)
- E: DC Bus Line Terminal (-V)

Engineering Data


■ Derating Curve




- Note: 1. If natural air circulation is limited, use the forced air cooling to prevent overheating.
 - 2. The ambient temperature is measured at a point 50 mm below the Buffer Block.
 - Check the derating curve for each power supply to be connected. Refer to Connections
 to the S8TS (Reference Values) on page 11 for details on the derating curves when
 connecting the Buffer Block to the S8TS-06024□.

■ Time Charts


Startup



Momentary Power Failure or Instantaneous Voltage Drop




Power Supply Interrupted or Stopped




■ Backup Time


Single Operation




Parallel Operation with 2 Blocks



Parallel Operation with 3 Blocks



Parallel Operation with 4 Blocks



Note: 1. The backup time may be reduced if a fixed power load (such as a DC-DC converter) is connected.


2. If the input voltage increases, the output voltage for the backup operation will also increase, reducing the backup time due to the higher power consumption of the load.


■ Connections to the S8TS (Reference Values)


Derating Curves of the S8TS-06024☐ When Connecting to the S8T-DCBU-02


Number of S8TS-06024□ Blocks	S8TS-06024 rated input	Number of S8T-DCBU-02 Blocks	Derating curve	Rated output power
1	200 to 240 VAC	1	*1	50 W
	100 to 120 VAC	1	*2	50 W
1 (+1)	100 to 120/200	1	*3	44 W
2	to 240 VAC	1	*4	110 W
2 (+1)		1	*5	98 W
3		1	*6	170 W
3 (+1)		1	*7	152 W
4		1	*8	230 W
4 (+1)		1	*9	206 W
1	200 to 240 VAC	2	*10	40 W
	100 to 120 VAC	2	*11	40 W
1 (+1)	100 to 120/200	2	*12	34 W
2	to 240 VAC	2	*13	100 W
2 (+1)		2	*14	88 W
3		2	*15	160 W
3 (+1)		2	*16	142 W
1	200 to 240 VAC	3	*17	30 W
	100 to 120 VAC	3	*18	30 W
1 (+1)	100 to 120/200	3	*19	24 W
2	to 240 VAC	3	*20	90 W
2 (+1)	İ	3	*21	78 W
1	200 to 240 VAC	4	*22	20 W
	100 to 120 VAC	4	*23	20 W


- Note: 1. "+1" indicates the addition of one more S8TS-06024□ Basic Block if a redundant system is used.
 - 2. If there is a derating problem, use forced air cooling.
 - 3. The ambient temperature is specified at a place 50 mm below the Product.
 - 4. The energy consumption of the S8T-DCBU-02 (approximately 10 W per Block) from the S8TS-06024□ reduces the total output capacity when more than one S8TS-06024□ Block is connected.
 - The rated output current of the S8T-DCBU-02 is 2.5 A per Block regardless of the number of S8TS-06024
 Basic Blocks that are connected.


























■ Power Supply Output Hold Times (Reference Values)

The rated currents are given for load currents.

Series			Output ho	ld time (ms)
	number	(A)	100 VAC	200 VAC
S8TS	06024□	0.5	163	167
		1	98	100
		1.5	70	70
		2.1	56	58
S8VS	01524	0.1	114	472
		0.2	78.4	344
		0.25	68.8	300
	03024	0.25	124	526
		0.5	72	334
		0.75	47.4	242
		0.9	36.8	204
	06024□	0.5	158	664
		1	88	382
		1.5	57	266
		2.1	36	194
	09024□□	1	118	508
		2	58	274
		2.95	34	176
	12024□□	1	262	262
		2	148	148
		3	102	102
		4	75	75
		4.2	72	72
	18024□□	2	225	230
		4	107	120
		6	71	75
		6.3	65	70
	24024□□	2.5	170	170
		5	68	72
		7.5	52	56
		8.4	40	44
	48024□	2.5	291	268
		5.0	147	157
		7.5	97	103
		10.0	75	77

Series	Model	Load current		old time (ms)
	number	(A)	100 VAC	200 VAC
S8VM	01524□□	0.1	94	414
		0.2	66	308
		0.25	52	258
	03024□□	0.1	154	492
		0.2	114	516
		0.3	84	414
		0.4	72	340
		0.5	56	290
		0.6	46	248
		0.7	36	218
		0.8	28	202
		0.9	22	166
	05024□□	0.1	218	218
		0.2	164	170
		0.4	114	110
		0.6	84	84
		0.8	68	72
		1.0	58	54
		1.2	44	44
		1.4	36	38
		1.6	34	32
		1.8	28	30
	10024□□	0.5	240	232
		1.0	136	132
		1.5	94	92
		2.0	70	70
		2.5	52	56
		3.0	40	44
		3.5	38	38
		3.7	32	30
	15024□□	0.5	332	334
		1.0	192	196
		1.5	136	140
		2.0	102	108
		2.5	80	86
		3.0	66	66
		3.5	60	58
		4.0	52	50
		4.5	44	44
		5.0	54	54
		5.3	34	38
	30024C	2.5	162	169
		5.0	84	84
		7.5	52	57
		10.0	43	41
	60024C	2.5	304	306
		5.0	170	158
		7.5	116	121
		10.0	88	88
	15224C	2.5	680	520
		5.0	644	517
		7.5	638	515
		10.0	635	510

Note: Orders for S8VM Series products are no longer accepted as of March 31, 2019.

■ Power Supply Output Hold Times (Reference Values)

The rated currents are given for load currents.

Series	Model number	Load current (A)	Output hold time (ms)	
			100 VAC	200 VAC
S8JX	N05024□□	0.5	112	520
		1	62	290
		1.5	42	208
		1.7	38	186
	N10024□□	1	104	524
		2	58	288
		3	36	184
		3.7	30	150
	N15024□□	1.5	142	648
		3	68	334
		4.5	46	226
		5.3	38	188

■ Power Supply Restart Times (Reference Values)

Series	Model number		Restart time (ms)					
		Momentary power failure time: 300 ms		Momentary power failure time: 500 ms		Momentary power failure time: 1,000 ms		
		100 VAC	200 VAC	100 VAC	200 VAC	100 VAC	200 VAC	
S8TS	06024□	320	270	320	270	345	290	
S8VS	01524	5.4	5.6	6	4.8	6.2	5	
	03024	390	110	456	140	576	196	
	06024	330	8	424	200	496	300	
	06024A/06024B	220	5	280	95	380	155	
	09024/09024S	312	6	378	186	512	308	
	09024A□/09024B□	220	5	286	100	390	157	
	12024□□	360	248	400	288	432	322	
	18024	288	252	306	276	388	356	
	18024A□/18024B□	230	198	247	216	263	235	
	24024	266	236	272	248	328	300	
	24024A□/24024B□	5	5	5	5	15	5	
	48024□	53	3	267	229	278	242	
S8VM	01524□□	356	152	376	164	420	180	
	03024□□	350	150	372	160	420	184	
	05024□□	240	196	248	196	270	216	
	10024□□	248	208	256	208	280	220	
	15024□□	250	226	272	216	300	236	
	30024C	62	48	64	50	74	60	
	60024C	366	198	380	200	436	276	
	15224C	556	472	568	480	576	488	
S8JX	N05024□□	180	120	204	138	280	172	
	N10024□□	186	128	210	144	268	106	
	N15024□□	222	12	246	152	320	208	

Note: Orders for S8VM Series and S8JX-N Series products are no longer accepted as of March 31, 2019.


Dimensions

Note: All units are in millimeters unless otherwise indicated.

■ Buffer Block and Bus Line Connector


Buffer Block


S8T-DCBU-02



Bus Line Connector

S8T-BUS03







■ DIN Rails (Order Separately)

Mounting Rails (Material: Aluminum)


PFP-100N PFP-50N





PFP-100N2






End Plate

PFP-M





Safety Precautions

Refer to Safety Precautions for All Power Supplies.

/ CAUTION

Installation and Environment

Minor fires may occasionally occur or wires may become detached causing the backup operation to fail if screws are not tightened properly. Tighten terminal screws to a torque of 1.08 N·m so that they do not become loose.



Minor electric shock may occasionally occur. Do not remove the connector cover unless connecting the Bus Line Connector



Minor electric shock may occasionally occur and the backup operation will fail if the connector becomes disconnected. Be sure to lock the slider and rail stopper securely when connecting the Basic Block and the S8T-DCBU-02 to prevent the connector from being disconnected due to vibration.



Internal parts may occasionally deteriorate or be damaged and the backup operation may not be sufficient. Do not use the S8T-DCBU-02 for applications that subject the load to frequent inrush currents or overload currents.



The S8T-DCBU-02 may occasionally be damaged. Do not allow any clippings or cuttings to enter the S8T-DCBU-02 during mounting.



Operation

Minor burns may occasionally occur. Do not touch the S8T-DCBU-02 while power is being supplied or immediately after power is turned OFF.



Minor electric shock may occasionally occur. Do not add or remove the S8T-DCBU-02 while power is being supplied.



Maintenance

Minor electric shock may occasionally occur. Do not disassemble the S8T-DCBU-02 or touch the interior of the S8T-DCBI I-02



■ Precautions for Safe Use

Observe the following precautions to ensure safety when using the S8T-DCBU-02.

Setting and Selecting Power Supply to be Connected

Do not connect a power supply other than the ones specified below. Specified Power Supply (SELV Power Supply): S8TS Series, S8VS Serie.

Only power supplies with an output voltage of 24 V and an output capacity of 9.6 W or more can be connected.


When selecting the power supply to be connected, take both the operation current and power of S8T-DCBU-02 into consideration, allowing sufficient margin.

Mounting

Improper mounting will interfere with heat dissipation and may occasionally result in deterioration or damage of internal parts. Use the specified mounting method only.

Ensure sufficient heat dissipation when installing the Product to increase its long-term reliability.

Natural cooling is used, so mount the S8T-DCBU-02 so that there is airflow around it.



Installation/Wiring

Minor electric shock or malfunction may possibly occur. Connect the ground wire completely.

Minor fires may possibly occur. Check the terminals to be sure they are wired correctly.

Do not apply more than 100-N force to the terminal block when tightening the terminals.

Close the terminal cover to help prevent short-circuiting terminals with foreign objects.

Be sure to remove the sheets covering the S8T-DCBU-02 for machining before turning ON the power so that they do not interfere with heat dissipation.

Use the wiring material specified in the following table to protect wires from smoking or ignition due to abnormal loads. Also, the backup operation may not be sufficient due to voltage drop in the wiring material if thin wiring materials are used.

I/O Terminals

Load current	Number of connected S8T-DCBU-02	Recommended wire diameter
Up to 2.5 A	1	AWG 14 to 20 (cross-sectional area: 0.517 to 2.081 mm²)
Up to 5.0 A	2	AWG 14 to 18 (cross-sectional area: 0.823 to 2.081 mm²)
Up to 7.5 A	3	AWG 14 to 16 (cross-sectional area: 1.309 to 2.081 mm²)
Up to 10 A	4	AWG 14 (cross-sectional area: 2.081 mm²)

Signal output terminals: AWG 16 to 22 (Cross-sectional area:

0.326 to 1.309 mm²)

(Wire stripping length: 11 mm)

Installation Environment

Do not use the S8T-DCBU-02 in locations subject to shocks or vibrations. In particular, install the S8T-DCBU-02 as far away as possible from contactors or other devices that are a vibration source. Install a PFP-M End Plate on each end of the product.

Install the S8T-DCBU-02 well away from any sources of strong, high-frequency noise and surge.

Ambient Operating Environment and Storage Environment

Store the S8T-DCBU-02 at an ambient temperature of -25 to $+65^{\circ}$ C, and a relative humidity of 25% to 90%.

The internal parts may occasionally deteriorate or be damaged. Do not use the S8T-DCBU-02 outside the derating range (i.e., under conditions indicated by the shaded area () in the derating curve diagram on page 9.)

Use the S8T-DCBU-02 at a relative humidity of 25% to 85%.

Do not use the S8T-DCBU-02 in locations subjected to direct sunlight.

Do not use the S8T-DCBU-02 in locations where liquid, foreign matter, or corrosive gases may enter the interior of the S8T-DCBU-02.

Precautions in Using

After connecting the devices to the S8T-DCBU-02, check whether sufficient backup is performed correctly by operating the S8T-DCBU-02.

Check the load current using the actual system in advance to confirm that there is sufficient leeway in the backup time.

Check to confirm that the READY indicator and the output function correctly. The backup operation may not be sufficient if the READY indicator and output do not function correctly.

The S8T-DCBU-02 will perform the backup operation not only for momentary power failures or voltage drops, but also when the input power is OFF. The backup time is particularly long for light loads. Check the devices connected to the S8T-DCBU-02 to be sure it has stopped operation correctly.

Periodic Inspection and Periodic Replacement

The S8T-DCBU-02 contains built-in electrolytic capacitors, which have a limited life. Perform periodic inspection and replacement. The performance of the electrolytic capacitor will deteriorate as the total operating time increases, eventually leading to insufficient performance. Refer to the following guidelines for periodic replacement.

Ambient	Guideline of replacement		
temperature	With space between the Units	Connected to S8TS	
30°C max.	15 years	15 years	
40°C	12 years	8.5 years	
50°C	6 years	5.5 years (See note.)	
60°C	3 years		

Note: The load ratio of the S8TS is limited to 60% due to the derating

Handling the Bus Line Connector

Do not drop the Bus Line Connector or subject it to strong shock.

Do not connect and disconnect the Bus Line Connector more than 20 times. Also, do not touch the terminals on the Bus Line Connector. Connection failure may cause deterioration of electric performance.

Troubleshooting

The following table lists the errors that may occur when the S8T-DCBU-02 is used, along with their probable causes and remedies. Check the relevant items.

The SBTS-660241 and SBT-05BU-02 cannot be connected. When chocking procedure. When chocking the SBT-05BU-02 connected on the connected on t	When	Cause	Description	Remedies
Self-DCBU-02 cannot be connected. Self-Biblios. Connection will not be possible file file for 52 FFU.03 Bits Line Connector on the self-DCBU-02 to the right or left the selector is self for the wrong type of Block. The Self-3602AII when connected dosh not specified to the selector is self-of the wrong type of Block. The Self-3602AII when connected dosh not specified to the self-DCBU-02 does not the SEIF-DCBU-02 does not the SEIF-DCBU-02 does not the SEIF-DCBU-02 does not light in step 2 of the operation checking procedure. The READY indicator on the SEIF-DCBU-02 does not light in step 2 of the operation checking procedure. The READY indicator on the SEIF-DCBU-02 does not light in step 2 of the operation checking procedure. The READY indicator on the SEIF-DCBU-02 does not light in step 2 of the operation checking procedure. The READY indicator on the SEIF-DCBU-02 does not light in step 2 of the operation checking procedure. The READY indicator on the SEIF-DCBU-02 does not light in step 2 of the operation checking procedure. The Telf-DCBU-02 does not light in step 2 of the operation checking procedure. The Telf-DCBU-02 does not light in step 2 of the operation checking procedure. The Voltage input to the SEIF-DCBU-02 may be connected the SEIF-DCBU-02 and SEIF-DCBU-02 an			·	
The S8TS-06024_when connected does not operation on the calculation of the connected does not operate the connected form of the connected between the connected state that the connected between the connected of the connected between the connected to the S8T-0CBU-02 and S8TS-0CBU-02 and S8TS-0C	J	S8T-DCBU-02 cannot be		Connector to 24 V.
The SBT-068U-02 to the right or left of Connect the SBT-068U-02 to the right or left of Connect the SBT-068U-02 to the right or left of Connect the SBT-068U-02 to the right or left of Connect the SBT-068U-02 to the right or left of Connect the SBT-068U-02 to the right or left of Connect the SBT-068U-02 to the right or left of Connect the SBT-068U-02 to the right of the Connect or the SBT-068U-02 does not left of the operation of the SBT-068U-02 does not left of the operation of the SBT-068U-02 does not light in sile 2 of the operation of the sBT-068U-02 does not light in sile 2 of the operation of the sBT-068U-02 does not light in sile 2 of the operation of the sBT-068U-02 does not light in sile		connected.		
connected does not operation of Referet On Checking procedure. SST-BUS03 Bus Line Connector when the SST- Decarition and Pervoice inspection. The READY indicator on the SST-DCBU-02 and SST-BUS03 Bus Line Connector when the SST-DCBU-02 and SST-06024T Bus Line Connector when the SST-DC				
progression and Personal procedure. DCBU-02 is connected. Droparation and Personal procedure was STR-050024. Blocks. The READY indicator on the SSF-DCBU-02 does not connected between two SSTS-06024. Blocks. The READY indicator on the SSF-DCBU-02 does not connect the SSF-DCBU-02 and SSTS-06024. Blocks. The READY indicator on the SSF-DCBU-02 does not connected. The BSF-DCBU-02 and SSTS-06024. Blocks are connected. The BSF-DCBU-02 does not connected was not connected to the SSF-DCBU-02 does not light in step 2 of the operation checking procedure. The READY indicator on the SSF-DCBU-02 does not connect the SSF-DCBU-02 and SSF-06024. Blocks on the SSF-DCBU-02 does not light in step 2 of the operation checking procedure. The READY indicator on the SSF-DCBU-02 does not connect the SSF-DCBU-02 and SSF-06024. Blocks on the SSF-DCBU-02 does not light in step 2 of the operation checking procedure. The READY indicator on the SSF-DCBU-02 does not connect the SSF-DCBU-02 and SSF-06024. Blocks on the SSF-DCBU-02 does not light in step 2 of the operation checking procedure. The PSSF-DCBU-02 does not connect the SSF-DCBU-02 and SSF-06024. Blocks on the SSF-DCBU-02 does not not light in step 2 of the operation checking procedure. The voltage input to the SSF-DCBU-02 may be connected in reverse or the power supply some than the power operation on the SSF-DCBU-02 will be proved in the specific on the SSF-DCBU-02 will be proved by the power supply some than the power operation on the SSF-DCBU-02 will be proved on the SSF-D	0			S S
The SRT-DCBU-02 may be connected between the SRT-DCBU-02 and SRT-06024_Increase the SRT-DCBU-02				
incline Inspection The READY indicator on the SBT-DCBU-02 does not light in step 2 of the opera- tion checking procedure when connected to the SBTS. The PEADY indicator on the SBT-DCBU-02 does not light in step 2 of the opera- tion checking procedure. The READY indicator on the SBT-DCBU-02 does not light in step 2 of the opera- tion checking procedure. The Dackup operation is no performed for the expected backup time in step 4 of the operation of checking procedure. The voltage output for the backup operation is low in step 4 of the operation is low in step 4 of the operation is low in step 4 of the operation is low of the expected on the backup operation is low in step 4 of the operation is low of the expected on the backup operation is lo				l page 3.
The READY indicator on light in step 2 of the operation checking procedure. When connected to the SET-DCBU-2 does not light in step 2 of the operation checking procedure. When connected to the SET-DCBU-2 does not light in step 2 of the operation checking procedure. When connected to the SET-DCBU-2 does not line (such as the SET-BUS03) may be connected to the SET-DCBU-2 does not line (such as the SET-BUS02) may be connected to the SET-DCBU-2 does not line (such as the SET-BUS02) may be connected for the SET-DCBU-02 does not line (such as the SET-BUS02) may be connected for the SET-DCBU-02 does not line (such as the SET-BUS03) may be connected for the SET-DCBU-02 does not line (such as the SET-BUS03) may be connected for the SET-DCBU-02 does not line (such as the SET-BUS03) may be connected for the SET-DCBU-02 does not line (such as the SET-BUS03) may be connected for the SET-DCBU-02 does not line (such as the SET-BUS03) may be connected for the SET-DCBU-02 does not line (such as the SET-BUS03) may be connected for the SET-DCBU-02 does not line (such as the SET-BUS03) may be connected for the SET-DCBU-02 does not line (such as the SET-BUS03) may be connected for the SET-DCBU-02 does not line (such as the SE	riodic Inspection	3 /		
light in step 2 of the operation checking procedure when connected to the S8TS. Abus Line Connector that does not connect the Connection the S8T-DCBU-02 and S8TS-06024—10 to the S8T-DCBU-02 does not light in step 2 of the operation checking procedure. The READY indicator on the S8T-DCBU-02 through the internal capacitor after the input light in step 2 of the operation checking procedure. In the S8T-DCBU-02 through the internal capacitor after the input light in step 2 of the operation or checking procedure. In the S8T-DCBU-02 may be connected in reverse or the power supply may be connected power supply may be connected power supply may be con	on page 6.)			Connect the S8T-DCBU-02 and S8TS-06024
ison checking procedure when connected to the S8TS. Abs Line Connector that does not connect the S8T-DCBU-02 and S8TS-06024 The READY indicator on the S8T-DCBU-02 does not light in step 2 of the operation checking procedure. The S8T-DCBU-02 does not light in step 2 of the operation checking procedure. The PEADY indicator on the second light in step 2 of the operation checking procedure. The S8T-DCBU-02 does not light in step 2 of the operation checking procedure. The voltage input to the S8T-DCBU-02 may be connected to an incorrect terminal (e.g., an NC terminal). The voltage input to the S8T-DCBU-02 may be connected to an incorrect terminal (e.g., an NC terminal). The voltage input to the S8T-DCBU-02 may be 23 V or less. Overcurrent protection on the connected power supply may have operated and the voltage may have dropped to below 23 V. The backup operation is not performed for the expected backup time in step 4 of the operation checking procedure. The voltage during the backup operation is low in step 4 of the operation checking procedure. The voltage autput for the backup operation is low in step 4 of the backup operation is low in step 4 of the operation checking procedure. The voltage autput for the backup operation is low in step 4 of the backup operation is low in step 4 of the operation checking procedure. The voltage autput for the backup operation is low in step 4 of the backup operation is low in step 4 of the operation checking procedure. The voltage autput for the backup operation is low in step 4 of the operation on the connected power supply may have operated and the voltage input in sub-part of the connected power supply may have operated and the voltage input in the sakeup operation is low in step 4 of the operation on the connected power supply may have operated and the voltage input in the sakeup operation is low in step 4 of the operation of the connected power supply may have operated and the voltage input in the sakeup operation is low in step 4 of the operation on the c				
when connected to the S8TS. Bus Line Connector that does not connect the S8TS. GCBU-02 and s8TS. GCBU-				fer to <i>Basic Configuration</i> on page 1.
SSTS. DC line (such as the SST-BUSO2) may be con- leaded. The READY indicator on the SST-DCBU-02 does not light in step 2 of the opera- tion checking procedure. The relative section of the system		o.		Connect the COT DODLL OF and COTC OCCOM
The READY indicator on the S8T-DCBU-02 does not light in step 2 of the operation checking procedure. In the READY indicator of the S8T-DCBU-02 does not light in step 2 of the operation checking procedure. In the READY indicator of lights after 60 seconds has passed since turning ON the input lower is turned ON. The positive and negative I/O terminals on the S8T-DCBU-02 may be connected in reverse or the power supply may be connected in reverse or the power supply may be connected to an incorrect terminal (e.g., an NC terminal). The voltage input to the S8T-DCBU-02 may be connected on the second of the secon				
The READY indicator on the S8T-DCBU-02 does not charge the internal capactor after the input power has been turned ON. The READY indicator inght in step 2 of the operation checking procedure. The voltage input to the S8T-DCBU-02 may be connected in reverse or the power supply and part one checking procedure. The voltage input to the S8T-DCBU-02 may be connected or an incorrect terminal (e.g., an NC terminal). The voltage input to the S8T-DCBU-02 may be connected in reverse or the power supply may be connected to an incorrect terminal are reversed. Correct the polarity and in the same of the power supply again. Refer to Reverse Connection Protection on page 7. The voltage input to the S8T-DCBU-02 may be 20 or supply so that it is 24 V or higher. Refer to Reverse Connection Protection on page 7. The voltage input to the S8T-DCBU-02 may be 20 or supply so that it is 24 V or higher. Refer to Inverse supply so that it is 24 V or higher. Refer to Inverse supply and the voltage output using the output voltage adjust to Alp Jo the connected power supply so that it is 24 V or higher. Refer to Inverse supply and the voltage adjust of the connected power supply so that it is 24 V or higher. Refer to Inverse supply and the voltage adjust of the voltage adjust of the connected power supply so that it is 24 V or higher. Refer to Inverse supply and the voltage adjust of the connected power supply so that it is 24 V or higher. Refer to Inverse supply and the voltage adjust of the connected power supply. Refer to Selecting the Power Supply and the recovery from momentary power failures shadoup time in step 4 of the operation decking procedure. The backup operation is not performed for the expected backup time, leave to the power supply so that it is 24 V or higher. Refer to Reverse voltage during the backup operation in any be high, increasing the power supply so that it is 24 V or higher. Refer to Reverse voltage adjust of the backup operation is not be dispersed to the power supply with a shorter restart may be to forth			, ,	
ilight in step 2 of the operation checking procedure. bower has been turned ON. The READY indicator will not turn ON immediately after the input power is turned ON. The positive and negative (I/C terminals on the SRT-DCBU-02 may be connected in reverse or the power supply may be connected to an incorrect terminal (e.g., an NC terminal). The voltage input to the SRT-DCBU-02 may be 20 or supply again. Refer to Reverse Oncention Protection on page 7. The voltage input to the SRT-DCBU-02 may be 23 V or less. Overcurrent protection on the connected power supply so that it is 24 V or higher. Refer to In put Voltage on Justice 1. Overcurrent protection on the connected power supply so that it is 24 V or higher. Refer to In put Voltage adjuster to delivered completely to the load. Increase the page 5. Overcurrent protection on the connected power supply so that it is 24 V or higher. Refer to In put Voltage and page 5. The backup operation is not performed for the expected backup time in step 4 of the operation checking procedure. The backup operation is not performed for the expected backup time in step 4 of the operation checking procedure. The voltage during the backup operation may be high, increasing the power consumption during the backup operation in sour in step 4 of the operation is not performed for the expected backup time. Refer to Recall the following the backup operation in may be high, increasing the power consumption during the backup operation in may be high, increasing the power consumption during the backup operation in the connected power supply time. Refer to Parallel Connection on page 5. The output current during the backup operation may be high, increasing the power supply may have operated and the voltage input to the SRT-DCBU-02 Slocks in parallel to increase the backup time. Refer to Parallel Connection on page 5. The output current during the backup operation in the SRT-DCBU-02 Slocks in parallel to increase the backup poperation is the 4 of the operation. The output current prot		The READY indicator on	Up to 60 seconds is required to completely	
tion checking procedure. It is contected even if the positive and negative I/O terminals on the SRT-DCBU-02 may be connected to an incorrect terminal (e.g., an NC terminal). It is voltage input to the SRT-DCBU-02 may be connected to an incorrect terminal (e.g., an NC terminal). The voltage input to the SRT-DCBU-02 may be adjuster I/O terminal on the power supply again. Refer to Reverse Connection Protection on page 7. The voltage input to the SRT-DCBU-02 may be adjuster I/O the power supply again. Refer to Reverse Connection Protection on page 7. The voltage input to the SRT-DCBU-02 may be adjuster I/O the power supply again. Refer to Reverse Connection Protection on page 7. The voltage input to the SRT-DCBU-02 may be adjuster I/O the power supply again. Refer to Reverse Connection Protection on page 7. The voltage input to the SRT-DCBU-02 may be adjuster I/O the power supply again. Refer to Input Voltage on page 5. Overcurrent protection on the connected power supply to the load increase the capacity of the connected power supply may have operated and the voltage may have dropped to below 23 V. The sample 20 consumes 0.4 A, so the ration of the connected power supply in the load increase the backup time. Refer to Selecting the Power Supply on page 4. The voltage output for the backup operation is low in step 4 of the operation is low in SRT-DCBU-02 and position is low in step 4 of the operation is low in step 4 of the operation is low in step 4 of the operation is lo				seconds has passed since turning ON the input
power is turned ON. The positive and negative I/O terminals on the S8FDCBU-02 may be connected in reverse or the power supply may be connected in nicroriect terminal (e.g., an NC terminal). The voltage input to the S8T-DCBU-02 may be connected on incorriect terminal (e.g., an NC terminal). The voltage input to the S8T-DCBU-02 may be connected power supply again. Refer to Reverse Connection Protection on page 7. The voltage input to the S8T-DCBU-02 may be connected power supply and in the voltage output using the output voltage adjuster (V. ADJ) of the connected power supply may have operated and the voltage may have dropped to below 23 V. The backup operation is not performed for the expected backup time in step 4 of the operation checking procedure. The voltage during the backup operation may be high, increasing the power consumption during the backup operation is not ing the backup operation. The voltage output for the backup operation is not ing the backup operation. The voltage output for the backup operation is not ing the backup operation on the soft operat				power. Refer to <i>READY Operation</i> on page 7.
The positive and negative I/O terminals on the SRT-DCBU-02 may be connected in reverse or the power supply may be connected to neverse or the power supply may be connected to an incorrect terminal (e.g., an NC terminal). The voltage input to the S8T-DCBU-02 may be connected to make the polarity and turn of the power supply again. Refer to Reverse Connection Protection on page 7. The voltage input to the S8T-DCBU-02 may be 23 V or less. Overcurrent protection on the connected power supply adains on the S8T-DCBU-02 and adjust it is 24 V or higher. Refer to Input Voltage adjuster (V. ADJ) of the connected power supply and adjuster it is 24 V or higher. Refer to Input Voltage on page 5. Overcurrent protection on the connected power supply and the capacity of the connected power supply and the		lion checking procedure.		
S8T-DCBU-02 may be connected to an incorrect terminal (e.g., an NC terminal). The voltage input to the S8T-DCBU-02 may be 23 V or less. The voltage input to the S8T-DCBU-02 may be 23 V or less. Overcurrent protection on the connected power supply and adjust the voltage output using the output voltage during the backup operation is not performed for the expected dure. The voltage output for the operation during the backup operation is now in step 4 of the operation checking procedure. S8T-DCBU-02 may be 23 V or less. Overcurrent protection on the connected power supply so that it is 24 V or higher. Refer to Involve and adjust the voltage output using the output voltage adjuster (V. ADJ) of the connected power supply so that it is 24 V or higher. Refer to Involve and adjust the voltage output using the output voltage adjuster (V. ADJ) of the connected power supply and adjust the voltage output using the output voltage adjuster (V. ADJ) of the connected power supply so that it is 24 V or higher. Refer to Involve and adjust the voltage output using the output voltage adjuster (V. ADJ) of the connected power supply and adjust the voltage output to the load. Increase the capacity of the connected power supply cannot be delivered completely to the load. Increase the capacity of the connected power supply and the connected power supply in the power failure time of the connected power supply and the connected power supply in the power failure time of the connected power supply and the power failure time of the connected power supply and the power failure time of the connected power supply and power failure time of the backup operation is own in the power failure time of the powe			l'	Check the wiring to be sure it is correct. The in-
rect terminal (e.g., an NC terminal). terminals are reversed. Correct the polarity and furn ON the power supply again. Refer to Reverse Connection Protection on page 7. The voltage input to the S8T-DCBU-02 may be 23 V or less. Overcurrent protection on the connected power supply so that it is 24 V or ligher. Refer to Industry and adjust the voltage output using the output voltage adjuster (V. ADJ) of the connected power supply so that it is 24 V or ligher. Refer to Industry by so that it is 24 V or ligher. Refer to Industry by so that it is 24 V or ligher. Refer to Industry by so that it is 24 V or ligher. Refer to Industry by the Industry of Industry or			S8T-DCBU-02 may be connected in reverse or	ternal circuits of the S8T-DCBU-02 will be pro-
The voltage input to the S8T-DCBU-02 may be 23 V or less. The voltage input to the S8T-DCBU-02 may be 23 V or less. Overcurrent protection on the connected power supply again. Refer to Reserve Connection or page 5. Overcurrent protection on the connected power supply to that it is 24 V or higher. Refer to Involtage adjuster (V ADJ) of the connected power supply may have operated and the voltage may have dropped to below 23 V. The backup operation is not performed for the expected backup time in step 4 of the operation checking procedure. The voltage during the backup operation may be high, increasing the power consumption during the backup operation. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. When checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. When checking procedure. The voltage output for the backup operation may be higher than expected. The voltage output for the backup operation is low in step 4 of the operation checking procedure. When checking procedure. When checking procedure. When checking operation and Periodic Inspection The voltage output for the backup operation is low in step 4 of the operation checking procedure. When checking operation and Periodic Inspection The voltage output for the backup operation is low in step 4 of the operation checking procedure. When checking operation and Periodic Inspection The voltage output for the backup operation is low in step 4 of the operation on the connected operation and Periodic Inspection The voltage output for the backup operation is low in step 4 of the operation on the connected operation on the ST-DCBU-02 blocks in parallel to increase the backup time. Refer to Parallel Connection on page 5. When checking procedure. The voltage output for the operation is low in step 4 of the operation is low in step 4 of the				
The voltage input to the S8T-DCBU-02 may be 23 V or less. The voltage input to the S8T-DCBU-02 may be 23 V or less. The voltage input to the S8T-DCBU-02 may be 23 V or less. Overcurrent protection on the connected power supply so that it is 24 V or higher. Refer to the connected power supply may have operated and the voltage may have dropped to below 23 V. The backup operation is not performed for the expected backup time in step 4 of the operation checking procedure. The voltage during the backup operation may be high, increasing the power consumption during the backup operation where the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation. The voltage output for the backup operation is low in step 4 of the operation. The voltage output for the backup operation is low in step 4 of the operation. The voltage output for the backup operation is low in step 4 of the operation. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation on page 5. The output current during the backup operation in the connected power supply may have operated and the voltage input to the S8T-DCBU-02 Blocks in parallel to increase the backup time. Refer to Parallel Connection on page 5. The voltage output for the backup operation on page 5. The voltage output for the backup operation on the connected power supply may have operated and the voltage input to the S8T-DCBU-02 Blocks in parallel to increase the backup time. Refer to Parallel Connection on page 5. The voltage output for the backup operation on the connected power supply may have operated and the voltage input to the S8T-DCBU-02 Blocks in parallel to increase the backup time. Refer to Parallel Connection on page 5.			rect terminal (e.g., an NC terminal).	
The voltage input to the S8T-DCBU-02 may be 23 V or less. The voltage input to the S8T-DCBU-02 with the voltage output using the output voltage adjuster (V. ADJ) of the connected power supply and payed on page 5. Overcurrent protection on the connected power supply and the voltage and user (V. ADJ) of the connected power supply may have operated and the voltage may have dropped to below 23 V. The S8T-DCBU-02 consumes 0.4 A, so the rate the operation of the checking procedure. The backup operation is not performed for the expected backup time in step 4 of the operation detection on the connected power supply. Refer to Selecting the Power Supply with a shorter restart time of or operation is low in step 4 of the operation. The voltage during the backup operation may be high, increasing the power consumption during the backup operation. The voltage output for the backup operation is low in step 4 of the operation is low in step 4 of the operation is low in step 4 of the operation. The voltage output for the backup operation is low in step 4 of the operation is low in step 4 of the operation. The voltage output for the backup operation is low in step 4 of the operation is low in step 6 of the operation is low in step 6 of the operation is low in step 6 of the operation is low in checking procedure. The voltage output for the backup operation is low in step 6 of the operation is low in the S8T-DCBU-02. The voltage output for the backup operation is low in step 6 of the operation on the S8T-DCBU-02. The voltage output for the backup operation on the connected power supply voltage during backup to the load. Increase the backup time. Refer to Parallel Connection on page 5. The voltage output for the backup operation is low in the S8T-DCBU-				
and adjust the voltage output using the output voltage and gardjuster (V. ADJ) of the connected power supply so that it is 24 V or higher. Refer to Input Woltage on page 5. Overcurrent protection on the connected power supply so that it is 24 V or higher. Refer to Input Woltage on page 5. Overcurrent protection on the connected power supply so that it is 24 V or higher. Refer to Input Woltage on page 5. The backup operation is not performed for the expected backup time in step 4 of the operation checking procedure. The voltage output for the backup operation. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation on checking procedure. The voltage output for the backup operation is low in step 4 of the operation on checking procedure. The voltage output for the backup operation is low in step 4 of the operation on help of the operation on checking procedure. The voltage output for the backup operation is low in step 4 of the operation on help of the operation on checking procedure. The voltage output for the backup operation is low in step 4 of the operation on checking procedure. The voltage output for the backup operation is low in step 4 of the operation on checking procedure. The voltage output for the backup operation is low in step 4 of the operation on the connected power supply cannot be operation on page 5. The voltage output for the backup operation is low in the stripctor of the connected power supply cannot be operation on page 5. The voltage output for the backup operation is low in the stripctor of the connected power supply cannot be operation on page 5. The voltage output for the load is too long or too thin, causing excessive voltage drop. The voltage output for the			The voltage input to the S8T-DCBU-02 may be	, ,
Overcurrent protection on the connected power supply cannot be delivered completely to the load. Increase the capacity of the connected power supply cannot performed for the expected backup time in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation and Periodic Inspection The voltage output for the backup operation and Periodic Inspection The voltage output for the backup operation and Periodic Inspection The voltage output for the backup operation and Periodic Inspection The voltage output for the backup operation and Periodic Inspection The voltage output for the backup operation and Periodic Inspection The voltage output for the backup operation is low in step 4 of the operation operation and Periodic Inspection The voltage output for the backup operation and Periodic Inspection The voltage output for the backup operation on the connected power supply cannot be delivered completely to the load. Increase the backup time. Refer to Parallel Connection on page 5. The voltage output for the backup operation is low in the periodic Inspection on the connected power supply cannot be delivered completely to the load. Increase the backup time. Refer to Parallel Connection on page 5. The voltage output for the backup operation is low in the set T-DCBU-02 may have operated and the voltage input of the connected power supply cannot be delivered completely to the load. Increase the backup operation is low in the set T-DCBU-02 may have operated on the set T-DCBU-02 becking the connected pow				
Overcurrent protection on the connected power supply may have dropped to below 23 V. The backup operation is not performed for the expected backup time in step 4 of the operation checking procedure. The voltage output for the backup operation on the backup operation checking procedure. The voltage output for the backup operation checking procedure. The voltage output for the backup operation checking procedure. The voltage output for the backup operation checking procedure. The voltage output for the backup operation checking procedure. The voltage output for the backup operation checking procedure. The voltage output for the backup operation checking procedure. The voltage output for the backup operation checking procedure. The voltage output for the backup operation on the connected power supply cannot be delivered completely to the load increase the backup time required to compensate for it. Change to a power supply with a shorter restart time or connect S8T-DCBU-02 Blocks in parallel to increase the backup time. Refer to Parallel Connection on page 5. The voltage output for the backup operation on the connected power supply on page 4. The voltage output for the packup operation on the connected power supply on page 5. The voltage output for the packup operation on the connected power supply cannot be delivered completely to the load. Increase the backup time. Refer to Parallel Connection on page 5. The voltage output for the backup operation and Poperation on the connected power supply. Refer to Selecting the Power Supply cannot be delivered completely to the load. Increase the capacity of the connected power supply. Refer to Selecting the Power Supply cannot be delivered completely to the load. Increase the capacity of the connected power supply in the paptication and Poperation and Pop				voltage adjuster (V. ADJ) of the connected pow-
Overcurrent protection on the connected power supply any have operated and the voltage may have dropped to below 23 V. The SBT-DCBU-02 consumes 0.4 A, so the rated current of the connected power supply supply. Refer to Selecting the Power Supply and the performed for the expected backup time in step 4 of the operation checking procedure. The voltage during the backup operation and be handled to the backup operation is now in step 4 of the operation checking procedure. Overcurrent protection on the connected power supply properation may be high, increasing the power consumption during the backup operation. The voltage during the backup operation may be high, increasing the power consumption during the backup operation. The voltage output for the backup operation is low in step 4 of the operation of the connected power supply on page 4. The voltage output for the backup operation is low in step 4 of the operation of the connected power supply on page 4. The voltage output for the backup operation is low in step 4 of the operation of the connected power supply on page 4. The voltage output for the backup operation is low in step 4 of the operation of the connected power supply may have operated and the voltage input to the connected power supply may have operated and the voltage input of the connected power supply may have operated and the voltage input of the connected power supply may have operated and the voltage input of the connected power supply cannection on page 5. The wiring to the load is too long or too thin, causing excessive voltage drop. The voltage output for the backup operation is low in step 4 of the operation hecking procedure. The voltage output for the backup operation is low in step 4 of the operation hecking procedure. The voltage output for the backup operation is low in step 4 of the operation hecking procedure. The voltage output for the backup operation is low in step 4 of the operation hecking procedure. The voltage output for the backup operation is low in step 4 of the o				
supply may have operated and the voltage may have dropped to below 23 V. The backup operation is not performed for the expected backup time in step 4 of the operation checking procedure. The voltage during the backup operation and be delivered completely to the load is too long or too thin, causing excessive voltage drop. When checking procedure. Supply may have operated and the voltage may have depended and the voltage in the connected power supply. Refer to Selecting the Power Supply on page 4. The voltage during the backup operation may be high, increasing the power consumption during the backup operation. The voltage output for the backup operation is low in step 4 of the operation checking procedure. When checking procedure. Supply may have operated and the voltage may and the load. Increase the capacity of the connected power supply after to Selecting the Power Supply on page 4. The voltage during the backup operation may be higher than expected. The output current during the backup operation may be higher than expected. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation on the connected power supply cannet to the connected power supply and the voltage input to the S8T-DCBU-02 Blocks in parallel to increase the backup time. Refer to Parallel Connection on page 5. The output current protection on the connected power supply cannot be delivered completely to the load. Increase the backup time. Refer to Parallel Connection on page 5. The voltage output for the backup operation on the connected power supply. Refer to Selecting the Power Supply and the voltage input to the SaT-DCBU-02 consumes 0.4 A, so the rate of the parallel to increase the backup time. Refer to Parallel Connection on page 5. The voltage output for the backup operation on the connected power supply. Refer to Selecting the Power Supply and the voltage input to the connected power supply. Refer to Selecting the Power Supply and the voltage			Overeus and a vest estimated the compacted actual	
have dropped to below 23 V. In the delivered completely to the load. Increase the capacity of the connected power supply. Refer to Selecting the Power Supply on page 4. The backup operation is not performed for the expected backup time in step 4 of the operation checking procedure. The voltage during the backup operation may be high, increasing the power consumption during the backup operation. The voltage during the backup operation may be high increasing the power consumption during the backup operation. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation checking procedure. The voltage output for the backup operation step 4 of the operation checking procedure. The voltage output for the backup operation checking procedure. The voltage output for the backup operation step 4 of the operation checking procedure. The voltage output for the backup operation step 4 of the operation checking procedure. The voltage output for the backup operation step 4 of the operation checking procedure. The voltage output for the backup operation step 4 of the operation checking procedure. The voltage output for the backup operation step 4 of the operation checking procedure. The voltage output for the backup operation stow in step 4 of the operation checking procedure. The voltage output for the backup operation stow in step 4 of the operation checking procedure. The voltage output for the backup operation on page 5. Overcurrent protection on page 5. The voltage output for the backup operation stow in the same page of the connected power supply sear-ot be delivered completely to the load. Increase the capacity of the connected powe				
The backup operation is not performed for the expected backup time in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation and periodic inspection The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation and Periodic inspection The voltage output for the backup operation and Periodic inspection The voltage output for the backup operation and Periodic inspection The voltage output for the backup operation and Periodic inspection The voltage output for the backup operation and Periodic inspection Overcurrent protection may have operated and increase the capacity of the connected power supply on page 4. When checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation backup operation is low in the seriodic inspection on the connected power supply on page 4. When checking procedure is a five formation on page 5. The voltage output for the backup operation by onnected power supply on page 4. Overcurrent protection may have operated on the serio			have dropped to below 23 V.	
The backup operation is not performed for the expected backup time in step 4 of the operation checking procedure. The voltage during the backup operation may be higher than expected. The voltage output for the backup operation show in step 4 of the operation checking procedure. The voltage output for the backup operation may be higher than expected. The voltage output for the backup operation checking procedure. The voltage output for the backup operation may be higher than expected. The voltage output for the backup operation checking procedure. The voltage output for the backup operation checking procedure. The voltage output for the backup operation on the connected power to supply may have operated and the voltage input to the S8T-DCBU-02 Blocks in parallel to increase the backup time. Refer to Parallel Connection on page 5. The voltage output for the backup operation step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation of the connected power supply cannot be delivered completely to the load. Increase the capacity of the connected power supply cannot be delivered completely to the load. Increase the capacity of the connected power supply cannot be delivered completely to the load. Increase the capacity of the connected power supply cannot be delivered completely to the load. Increase the capacity of the connected power supply spage 4. When checking operation is low in supply may have operated on the S8T-DCBU-02 Blocks in parallel to increase the capacity of the connected power supply cannot be delivered completely to the load. Increase the capacity of the connected power supply spage 4. When checking operation is low in step 4 of the operation is low in supply may have operated on the S8T-DCBU-02 Blocks in parallel to increase the load capacity in the application or increase the output current during the backup operation by connection on page 5.				Increase the capacity of the connected power
The backup operation is not performed for the expected backup time in step 4 of the operation checking procedure. The voltage output for the backup operation or hecking procedure. The voltage output for the backup operation or hecking procedure. The voltage output for the backup operation or hecking procedure. The voltage output for the backup operation or hecking procedure. The voltage output for the backup operation or hecking procedure. The voltage output for the backup operation or hecking procedure. The voltage output for the backup operation or hecking procedure. The voltage output for the backup operation or hecking procedure. The voltage output for the backup operation or hecking procedure. The voltage output for the backup operation or hecking procedure. The voltage output for the backup operation or hecking procedure. The voltage output for the backup operation or hecking procedure. The voltage output for the backup operation or hecking procedure. The voltage output for the backup operation or hecking procedure. The voltage output for the backup operation or hecking procedure. The voltage output for the backup operation or hecking procedure. The voltage output for the backup operation or hecking procedure. The voltage output for the backup operation or hecking procedure. The voltage output for the backup operation or hecking procedure. The voltage output for the backup operation or hecking procedure. The voltage output for the load is too long or too thin, causing excessive voltage drop. The voltage output for the load is too long or too thin, causing excessive voltage drop. The voltage output for the load is too long or too thin, causing excessive voltage drop. The voltage output for the load is too long or too thin, causing excessive voltage drop. The voltage output for the load is too long or too thin, causing excessive voltage drop. The voltage output voltage during backup operation backup operation is low in the procedure. The voltage output for the load is too long or				
performed for the expected backup time in step 4 of the operation checking procedure. ### The voltage output for the backup operation is low in step 4 of the operation checking procedure. ### Voercurrent protection on the connected power supply may have operated and the voltage input to the S8T-DCBU-02 Consumes 0.4 A, so the rated backup operation checking procedure. ### The voltage output for the backup operation is low in step 4 of the operation checking procedure. ### Voercurrent protection on the connected power supply may have operated and the voltage input to the S8T-DCBU-02 Consumes 0.4 A, so the rated current of the connected power supply may have operated and the voltage input to the S8T-DCBU-02 Consumes 0.4 A, so the rated current of the connected power supply may have operated and the voltage input to the S8T-DCBU-02 Consumes 0.4 A, so the rated current of the connected power supply may have operated and the voltage input to the S8T-DCBU-02 Consumes 0.4 A, so the rated current of the connected power supply may have operated and the voltage input to the delivered completely to the load. Increase the capacity of the connected power supply canneged 4. #### When checking procedure. #### Voercurrent protection on the connected power supply canneged 4. #### Voercurrent of the connected power supply canneged 5. #### Application or increase the output voltage during backup will be up to 2 V lower than the input voltage. Refer to Wiring Connections on page 5. #### Application or increase the output current during the backup operation by connecting 0 Set-DCBU-02 Blocks in parallel to increase the backup to the backup operation on the set of the parallel Connection on page 5. #### Application or increase the output current during the backup operation by connecting 0 Set-DCBU-02 Blocks in parallel to increase the output current during the backup operation by connecting 0 Set-DCBU-02 Blocks in parallel to increase the obscluption or increase the output current during the backup operation by connecting 0			The grant disease of the consequence of a consequence of the consequen	
backup time in step 4 of the operation checking procedure. The voltage during the backup operation way be higher than expected.				
operation checking procedure. The voltage during the backup operation may be high, increasing the power consumption during the backup operation. The output current during the backup operation may be higher than expected. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The wiring to the load is too long or too thin, causing excessive voltage drop. When checking procedure. The voltage output for the backup operation is low in step 4 of the operation. The voltage output for the backup operation is low in step 4 of the operation. The voltage output for the backup operation on the connected power supply may have operated and the voltage input to the S8T-DCBU-02 consumes 0.4 A, so the rated current of the connected power supply cannot be delivered completely to the load. Increase the capacity of the connected power supply. Refer to Selecting the Power Supply on page 4. The voltage output for the backup operation on the connected power supply cannot be delivered completely to the load. Increase the capacity of the connected power supply. Refer to Selecting the Power Supply on page 4. When checking operation decking operation decking procedure. The voltage output for the backup operation and Periodic Inspection on page 5. The voltage output for the backup operation and Periodic Inspection on page 5. The decking procedure. The voltage during the backup operation is page 4. Use the thickest wire and shortest distance possible. The output voltage during backup will be up to 2 V lower than the input voltage. Refer to Wiring Connections on page 5. Allow for leeway for the load capacity in the application or increase the output current during the backup operation by connecting S8T-DCBU-02 Blocks in parallel. Refer to Parallel Connection on page 5.				
The voltage during the backup operation may be high, increasing the power consumption during the backup operation. The output voltage during the backup operation is automatically adjusted based on detecting the voltage input to the S8T-DCBU-02. Connect S8T-DCBU-02 Blocks in parallel to increase the backup time. Refer to Parallel Connection on page 5. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation. The voltage output for the backup operation and Periodic Inspection The voltage output for the backup operation is low in step 4 of the operation on the connected power supply cannot be delivered completely to the load. Increase the capacity of the connected power supply. Refer to Selecting the Power Supply on page 4. The output voltage output for the backup operation is low in step 4 of the operation on the connected power supply cannot be delivered completely to the load. Increase the capacity of the connected power supply. Refer to Selecting the Power Supply on page 4. The output voltage output for the backup operation is low in step 4 of the operation or checking operation and Periodic Inspection The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation or checking procedure. The voltage output for the backup operation is low in step 4 of the operation or checking procedure. The voltage output for the backup operation is low in step 4 of the operation or checking procedure.				time or connect S8T-DCBU-02 Blocks in parallel
The voltage during the backup operation may be high, increasing the power consumption during the backup operation. The output current during the backup operation The output current during the backup operation The voltage output for the backup operation on page 5. The voltage output for the backup operation on page 5. The voltage output for the backup operation on page 5. The voltage output for the backup operation on page 5. Overcurrent protection on the connected power supply may have operated and the voltage input on the S8T-DCBU-02 Blocks in parallel to increase the backup time. Refer to Parallel Connection on page 5. Overcurrent protection on the connected power supply cannot be delivered completely to the load. Increase the capacity of the connected power supply. Refer to Selecting the Power Supply on page 4. The wiring to the load is too long or too thin, causing excessive voltage drop. When checking operation The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation by connection may have operated on the S8T-DCBU-02 Blocks in parallel to increase the backup operation in determined to the same procedure. The voltage output for the backup operation or increase the output current during the backup operation by connecting S8T-DCBU-02 Blocks in parallel. Refer to Parallel Connection on page 5. Allow for leeway for the load capacity in the application or increase the output current during the backup operation by connecting S8T-DCBU-02 Blocks in parallel. Refer to Parallel Connection on page 5. Allow for leeway for the load capacity in the application or increase the output current during the backup operation by connection		dure.		to increase the backup time. Refer to Selecting
be high, increasing the power consumption during the backup operation. Definition of the connection of the packup operation o				
ing the backup operation. In the voltage input to the S8T-DCBU-02. Connect S8T-DCBU-02 Blocks in parallel to increase the backup time. Refer to Parallel Connection on page 5. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The wiring to the load is too long or too thin, causing excessive voltage drop. When checking poperation and Periodic Inspection The voltage output for the backup operation. In the voltage input to the S8T-DCBU-02 Blocks in parallel to increase the backup time. Refer to Parallel Connection on page 5. Overcurrent protection on the connected power supply on the S8T-DCBU-02 may have dropped to below 24 V. Overcurrent protection on the connected power supply cannot be delivered completely to the load. Increase the capacity of the connected power supply. Refer to Selecting the Power Supply on page 4. Use the thickest wire and shortest distance possible. The output voltage during backup will be up to 2 V lower than the input voltage. Refer to Wiring Connections on page 5. When checking operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. Overcurrent protection may have operated on the S8T-DCBU-02. Allow for leeway for the load capacity in the application or increase the output current during the backup operation by connecting S8T-DCBU-02 Blocks in parallel to increase the backup operation or page 5.				
S8T-DCBU-02 Blocks in parallel to increase the backup time. Refer to Parallel Connection on page 5. The output current during the backup operation may be higher than expected. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation checking procedure. Overcurrent protection on the connected power supply cannot be delivered completely to the load. Increase the capacity of the connected power supply. Refer to Selecting the Power Supply on page 4. The wiring to the load is too long or too thin, causing excessive voltage drop. When checking operation Insert to Checking Operation and Periodic Inspection The voltage output for the backup operation is low in step 4 of the operation checking operation and Periodic Inspection S8T-DCBU-02 Blocks in parallel to increase the backup operation in crease the backup operation on the connected power supply cannot be delivered completely to the load. Increase the capacity of the connected power supply. Refer to Selecting the Power Supply on page 4. Use the thickest wire and shortest distance possible. The output voltage during backup will be up to 2 V lower than the input voltage. Refer to Wiring Connections on page 5. Allow for leeway for the load capacity in the application or increase the output current during the backup operation by connecting S8T-DCBU-02 Blocks in parallel. Refer to Parallel Connection on page 5.				
backup time. Refer to Parallel Connection on page 5. The output current during the backup operation may be higher than expected. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The wiring to the load is too long or too thin, causing excessive voltage drop. When checking operation and Periodic Inspection The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. Overcurrent protection on the connected power supply cannot be delivered completely to the load. Increase the capacity of the connected power supply. Refer to Selecting the Power Supply on page 4. The wiring to the load is too long or too thin, causing excessive voltage drop. The voltage output for the backup operation is low in step 4 of the operation checking operation and Periodic Inspection The output current during the backup operation on page 5. Covercurrent protection on the connected power supply cannot be delivered completely to the load. Increase the capacity of the connected power supply. Refer to Selecting the Power Supply on page 4. Use the thickest wire and shortest distance possible. The output voltage during backup will be up to 2 V lower than the input voltage. Refer to Wiring Connections on page 5. Allow for leeway for the load capacity in the application or increase the output current during the backup operation by connecting S8T-DCBU-02 Blocks in parallel. Refer to Parallel Connection on page 5.				S8T-DCBU-02 Blocks in parallel to increase the
The output current during the backup operation may be higher than expected. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The wiring to the load is too long or too thin, causing excessive voltage drop. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. The wiring to the load is too long or too thin, causing excessive voltage drop. The voltage output for the backup operation is low in step 4 of the operation on page 5. The S8T-DCBU-02 consumes 0.4 A, so the rate of current of the connected power supply cannot be delivered completely to the load. Increase the capacity of the connected power supply. Refer to Selecting the Power Supply on page 4. The wiring to the load is too long or too thin, causing excessive voltage drop. When checking operation is low in step 4 of the operation or increase the backup operation by connection or increase the backup operation by connecting S8T-DCBU-02 Blocks in parallel. Refer to Parallel Connection on page 5. The voltage output for the backup operation is low in the S8T-DCBU-02. The voltage output for the backup operation is low in the S8T-DCBU-02. The voltage output for the backup operation by connecting S8T-DCBU-02 Blocks in parallel. Refer to Parallel Connection on page 5.				·
The voltage output for the backup operation is low in step 4 of the operation checking procedure. When checking procedure of the voltage output for the backup operation is low in step 4 of the operation checking operation on the load is too long or too thin, causing excessive voltage drop. When checking operation is low in step 4 of the operation checking operation on the connected power supply cannot be delivered completely to the load. Increase the capacity of the connected power supply. Refer to Selecting the Power Supply on page 4. The wiring to the load is too long or too thin, causing excessive voltage drop. When checking operation is low in step 4 of the operation of the connected power supply. Refer to Selecting the Power Supply on page 4. The voltage output for the backup operation is low in step 4 of the operation of the connected power supply. Refer to Selecting the Power Supply on page 4. The voltage output for the backup operation is low in step 4 of the operation of the connected power supply. Refer to Selecting the Power Supply on page 4. Allow for leeway for the load capacity in the application or increase the output current during the backup operation by connecting S8T-DCBU-02 Blocks in parallel. Refer to Parallel Connection on page 5.			The autout approach device with a last	
The voltage output for the backup operation is low in step 4 of the operation checking procedure. The woltage output for the backup operation is low in step 4 of the operation checking procedure. The woltage output for the backup operation is low in step 4 of the operation checking procedure. The wiring to the load is too long or too thin, causing excessive voltage drop. The wiring to the load is too long or too thin, causing excessive voltage drop. The woltage output for the backup operation is low in step 4 of the operation on page 5. The S8T-DCBU-02 consumes 0.4 A, so the rate of current of the connected power supply cannot be delivered completely to the load. Increase the capacity of the connected power supply. Refer to Selecting the Power Supply on page 4. Use the thickest wire and shortest distance possible. The output voltage during backup will be up to 2 V lower than the input voltage. Refer to Wiring Connections on page 5. When checking operation is low in step 4 of the operation checking procedure. The voltage output for the backup operation is low in step 4 of the operation checking procedure. Overcurrent protection may have operated on the S8T-DCBU-02. Allow for leeway for the load capacity in the application or increase the output current during the backup operation by connecting S8T-DCBU-02 Blocks in parallel. Refer to Parallel Connection on page 5.				
The voltage output for the backup operation is low in step 4 of the operation checking procedure. Overcurrent protection on the connected power supply may have operated and the voltage input to the S8T-DCBU-02 may have dropped to below 24 V. The wiring to the load is too long or too thin, causing excessive voltage drop. The voltage output for the backup operation is low in step 4 of the operation The voltage output for the backup operation is low in step 4 of the operation Refer to Checking Operation and Periodic Inspection The voltage output for the backup operation is low in step 4 of the operation checking procedure. Overcurrent protection on the connected power supply and the voltage input to the S8T-DCBU-02 may have dropped to below 24 V. The wiring to the load is too long or too thin, causing excessive voltage drop. Use the thickest wire and shortest distance possible. The output voltage during backup will be up to 2 V lower than the input voltage. Refer to Wiring Connections on page 5. Allow for leeway for the load capacity in the application or increase the output current during the backup operation by connecting S8T-DCBU-02 Blocks in parallel. Refer to Parallel Connection on page 5.			may be myner man expected.	
backup operation is low in step 4 of the operation checking procedure. Supply may have operated and the voltage input to the S8T-DCBU-02 may have dropped to below 24 V. The wiring to the load is too long or too thin, causing excessive voltage drop. When checking operation Refer to Checking Operation and Periodic Inspection Refer to Checking operation is low in step 4 of the operation checking operation and Periodic Inspection backup operation is low in step 4 of the operation checking operation and Periodic Inspection supply may have operated and the voltage input to the connected power supply. Refer to Selecting the Power Supply on page 4. Use the thickest wire and shortest distance possible. The output voltage during backup will be up to 2 V lower than the input voltage. Refer to Wiring Connections on page 5. Allow for leeway for the load capacity in the application or increase the output current during the backup operation by connecting S8T-DCBU-02 Blocks in parallel. Refer to Parallel Connection on page 5.		The voltage output for the	Overcurrent protection on the connected power	The S8T-DCBU-02 consumes 0.4 A, so the rat-
step 4 of the operation checking procedure. Step 4 of the operation checking procedure. Increase the capacity of the connected power supply. Refer to Selecting the Power Supply on page 4.		backup operation is low in step 4 of the operation		
supply. Refer to Selecting the Power Supply on page 4. The wiring to the load is too long or too thin, causing excessive voltage drop. When checking operation Refer to Checking Operation and Periodic Inspection The voltage output for the backup operation step 4 of the operation checking procedure. Supply. Refer to Selecting the Power Supply on page 4. Use the thickest wire and shortest distance possible. The output voltage during backup will be up to 2 V lower than the input voltage. Refer to Wiring Connections on page 5. Allow for leeway for the load capacity in the application or increase the output current during the backup operation by connecting S8T-DCBU-02 Blocks in parallel. Refer to Parallel Connection on page 5.			, , , , , , , , , , , , , , , , , , , ,	
The wiring to the load is too long or too thin, causing excessive voltage drop. When checking operation Refer to Checking Operation and Periodic Inspection The wiring to the load is too long or too thin, causing excessive voltage drop. Use the thickest wire and shortest distance possible. The output voltage during backup will be up to 2 V lower than the input voltage. Refer to Wiring Connections on page 5. Overcurrent protection may have operated on the S8T-DCBU-02. Allow for leeway for the load capacity in the application or increase the output current during the backup operation by connecting S8T-DCBU-02 Blocks in parallel. Refer to Parallel Connection on page 5.			low 24 V.	
The wiring to the load is too long or too thin, causing excessive voltage drop. The working operation (Refer to Checking Operation and Periodic Inspection) The working to the load is too long or too thin, causing excessive voltage drop. The working to the load is too long or too thin, causing excessive voltage drop. The working to the load is too long or too thin, causing excessive voltage drop. Use the thickest wire and shortest distance possible. The output voltage during backup will be up to 2 V lower than the input voltage. Refer to Wiring Connections on page 5. Allow for leeway for the load capacity in the application or increase the output current during the backup operation by connecting S8T-DCBU-02 Blocks in parallel. Refer to Parallel Connection on page 5.				
causing excessive voltage drop. sible. The output voltage during backup will be up to 2 V lower than the input voltage. Refer to Wiring Connections on page 5. When checking operation (Refer to Checking Operation and Periodic Inspection) The voltage output for the backup operation is low in step 4 of the operation checking procedure. Overcurrent protection may have operated on the S8T-DCBU-02. Allow for leeway for the load capacity in the application or increase the output current during the backup operation by connecting S8T-DCBU-02 Blocks in parallel. Refer to Parallel Connection on page 5.			The wiring to the load is too long or too thin	
when checking operation (Refer to Checking Operation and Periodic Inspection) When checking operation (Refer to Checking Operation and Periodic Inspection) When checking operation (Refer to Checking Operation and Periodic Inspection) When checking output for the backup operation is low in step 4 of the operation checking procedure. Overcurrent protection may have operated on the S8T-DCBU-02. Allow for leeway for the load capacity in the application or increase the output current during the backup operation by connecting S8T-DCBU-02 Blocks in parallel. Refer to Parallel Connection on page 5.				·
When checking operation (Refer to Checking Operation and Periodic Inspection) The voltage output for the backup operation is low in step 4 of the operation checking procedure. Overcurrent protection may have operated on the S8T-DCBU-02. Allow for leeway for the load capacity in the application or increase the output current during the backup operation by connecting S8T-DCBU-02 Blocks in parallel. Refer to Parallel Connection on page 5.			<u>-</u> .	up to 2 V lower than the input voltage. Refer to
backup operation is low in Refer to Checking Operation and Periodic Inspection backup operation is low in Step 4 of the operation operation operation on the S8T-DCBU-02. the S8T-DCBU-02. plication or increase the output current during the backup operation by connecting S8T-DCBU-02 Blocks in parallel. Refer to Parallel Connection on page 5.	1411	T		
Refer to Checking Step 4 of the operation Checking Procedure. Step 4 of the operation Step 4 of the operation Checking Procedure. Step 4 of the operation Step 4 of the oper	•			
Operation and Periodic Inspection S8T-DCBU-02 Blocks in parallel. Refer to Parallel Connection on page 5.				
riodic Inspection lel Connection on page 5.	Operation and Pe-			
on page 6.)	riodic Inspection			
	on page 6.)			

S8T-DCBU-02

When	Cause	Description	Remedies
When checking operation (Refer to Checking Opera- tion and Periodic	The BACKUP indicator does not light in step 4 of the operation checking procedure.	The output hold time of the connected power supply may be sufficient to handle the momentary power failure.	Use a timer to increase the power failure of the AC input from the connected power supply and confirm that the BACKUP indicator lights. Refer to Selecting the Power Supply on page 4.
Inspection on page 6.)		The voltage output from the S8T-DCBU-02 during the backup operation may be lower because overcurrent protection has operated in the S8T-DCBU-02.	Allow for leeway for the load capacity in the application or increase the output current during the backup operation by connecting S8T-DCBU-02 Blocks in parallel. Refer to <i>Parallel Connection</i> on page 5.
During actual operation	The READY indicator is not lit and the READY output is OFF.	23 V or less.	Check the voltage at the I/O terminals of the S8T-DCBU-02 and adjust the voltage output using the output voltage adjuster (V. ADJ) of the connected power supply so that it is 24 V or higher. Refer to <i>Input Voltage</i> on page 5.
		A voltage of approximately 31 V or higher may be input to the I/O terminals of the S8T-DCBU-02, causing the overvoltage protection circuit to operate.	Clear the overvoltage protection (turn OFF the input power for 1 minute or longer and then turn it back ON). Refer to <i>Overvoltage Protection</i> on page 7.
	The backup time has become shorter.	It's possible that momentary power failures are occurring consecutively.	The backup time is measured when the built-in electrolytic capacitors are fully charged. If momentary power failures occur within one minute of each other, the charge will not be complete and the backup time will be shorter. Refer to Backup Operation on page 7.
		It's possible that the characteristics of the built- in electrolytic capacitors have deteriorated.	Electrolytic capacitors are built into the Block and these capacitors have a limited life. When an electrolytic capacitor exceeds its useful life, its capacity will decrease and other characteristics will deteriorate. This will cause the backup time to be shorter. Refer to Operation Check and Periodic Inspection on page 6 and to Periodic Inspection and Periodic Replacement on page 17.
	There is chattering on the READY output.	The input voltage of the S8T-DCBU-02 may be very close to 23 V.	Check the voltage at the I/O terminals of the S8T-DCBU-02 and adjust the voltage output using the output voltage adjuster (V. ADJ) of the connected power supply so that it is 24 V or higher. Refer to <i>Input Voltage</i> on page 5.
	The output voltage is not restored even after the power supply is restored following a momentary power failure.	Protection on the connected power supply may have operated, stopping the operation of the power supply.	Clear the protection function of the connected power supply.
	The backup operation is performed repeatedly.	If more than one S8TS-06024□ Block is connected, one of the Blocks may be faulty.	Replace the faulty S8TS-06024 Block.
		An overcurrent status caused by load fluctuation may exist in the connected power supply.	Allow for leeway for the load capacity in the application or increase the capacity of the connected power supply. Refer to <i>Backup Operation</i> on page 7.

ALL DIMENSIONS SHOWN ARE IN MILLIMETERS.

To convert millimeters into inches, multiply by 0.03937. To convert grams into ounces, multiply by 0.03527.

In the interest of product improvement, specifications are subject to change without notice.

Terms and Conditions Agreement

Read and understand this catalog.

Please read and understand this catalog before purchasing the products. Please consult your OMRON representative if you have any questions or comments.

Warranties.

- (a) Exclusive Warranty. Omron's exclusive warranty is that the Products will be free from defects in materials and workmanship for a period of twelve months from the date of sale by Omron (or such other period expressed in writing by Omron). Omron disclaims all other warranties, express or implied.
- (b) Limitations. OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, ABOUT NON-INFRINGEMENT, MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE OF THE PRODUCTS. BUYER ACKNOWLEDGES THAT IT ALONE HAS DETERMINED THAT THE PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE.

Omron further disclaims all warranties and responsibility of any type for claims or expenses based on infringement by the Products or otherwise of any intellectual property right. (c) Buyer Remedy. Omron's sole obligation hereunder shall be, at Omron's election, to (i) replace (in the form originally shipped with Buyer responsible for labor charges for removal or replacement thereof) the non-complying Product, (ii) repair the non-complying Product, or (iii) repay or credit Buyer an amount equal to the purchase price of the non-complying Product; provided that in no event shall Omron be responsible for warranty, repair, indemnity or any other claims or expenses regarding the Products unless Omron's analysis confirms that the Products were properly handled, stored, installed and maintained and not subject to contamination, abuse, misuse or inappropriate modification. Return of any Products by Buyer must be approved in writing by Omron before shipment. Omron Companies shall not be liable for the suitability or unsuitability or the results from the use of Products in combination with any electrical or electronic components, circuits, system assemblies or any other materials or substances or environments. Any advice, recommendations or information given orally or in writing, are not to be construed as an amendment or addition to the above warranty.

See http://www.omron.com/global/ or contact your Omron representative for published information.

Limitation on Liability; Etc.

OMRON COMPANIES SHALL NOT BE LIABLE FOR SPECIAL, INDIRECT, INCIDENTAL, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR PRODUCTION OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED IN CONTRACT, WARRANTY, NEGLIGENCE OR STRICT LIABILITY.

Further, in no event shall liability of Omron Companies exceed the individual price of the Product on which liability is asserted.

Suitability of Use.

Omron Companies shall not be responsible for conformity with any standards, codes or regulations which apply to the combination of the Product in the Buyer's application or use of the Product. At Buyer's request, Omron will provide applicable third party certification documents identifying ratings and limitations of use which apply to the Product. This information by itself is not sufficient for a complete determination of the suitability of the Product in combination with the end product, machine, system, or other application or use. Buyer shall be solely responsible for determining appropriateness of the particular Product with respect to Buyer's application, product or system. Buyer shall take application responsibility in all cases.

NEVER USE THE PRODUCT FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY OR IN LARGE QUANTITIES WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCT(S) IS PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

Programmable Products.

Omron Companies shall not be responsible for the user's programming of a programmable Product, or any consequence thereof.

Performance Data.

Data presented in Omron Company websites, catalogs and other materials is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of Omron's test conditions, and the user must correlate it to actual application requirements. Actual performance is subject to the Omron's Warranty and Limitations of Liability.

Change in Specifications.

Product specifications and accessories may be changed at any time based on improvements and other reasons. It is our practice to change part numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the Product may be changed without any notice. When in doubt, special part numbers may be assigned to fix or establish key specifications for your application. Please consult with your Omron's representative at any time to confirm actual specifications of purchased Product.

Errors and Omissions.

Information presented by Omron Companies has been checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical or proofreading errors or omissions.

Note: Do not use this document to operate the Unit.

OMRON Corporation Industrial Automation Company

Kyoto, JAPAN

Contact: www.ia.omron.com

Regional Headquarters OMRON EUROPE B.V.

Wegalaan 67-69, 2132 JD Hoofddorp The Netherlands Tel: (31)2356-81-300/Fax: (31)2356-81-388

OMRON ASIA PACIFIC PTE. LTD.
No. 438A Alexandra Road # 05-05/08 (Lobby 2),
Alexandra Technopark,
Singapore 119967 Tel: (65) 6835-3011/Fax: (65) 6835-2711

OMRON ELECTRONICS LLC

2895 Greenspoint Parkway, Suite 200 Hoffman Estates, IL 60169 U.S.A. Tel: (1) 847-843-7900/Fax: (1) 847-843-7787

OMRON (CHINA) CO., LTD.
Room 2211, Bank of China Tower,
200 Yin Cheng Zhong Road,
PuDong New Area, Shanghai, 200120, China Tel: (86) 21-5037-2222/Fax: (86) 21-5037-2200 **Authorized Distributor:**

© OMRON Corporation 2020 All Rights Reserved. In the interest of product improvement, specifications are subject to change without notice.

CSM_10_1 Printed in Japan Cat. No. T234-E1-02 1120(0920)