

Supplier's declaration of conformity

For compliance levels 1, 2 and 3 in Australia



As required by the following Notices:

- *Radiocommunications Devices (Compliance Labelling) Notice 2003* made under section 182 of the *Radiocommunications Act 1992*;
- *Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2008* made under section 182 of the *Radiocommunications Act 1992*;
- *Radiocommunications (Compliance Labelling – Electromagnetic Radiation) Notice 2003* made under section 182 of the *Radiocommunications Act 1992*; and
- *Telecommunications Labelling (Customer Equipment and Customer Cabling) Notice 2001* made under section 407 of the *Telecommunications Act 1997*

Instructions for completion

- **Do not return this form to the ACMA.** This completed form must be retained by the supplier as part of the documentation required for the compliance records and must be made available for inspection by the ACMA when requested.

Supplier's details (manufacturer, importer or authorised agent)

Company Name (OR INDIVIDUAL)

Schneider Electric Australia
TRADING AS

ACMA supplier code number

(issued by the ACMA prior to 1 March 2013)

ERAC000097 (ACMA No: N998)

OR

ABN

--

Street Address

78 Waterloo Road
Macquarie Park, NSW
POSTCODE 2113

Product details

Product description – brand name, type, model, lot, batch or serial number (if available)

Schneider Electric, Zelio Control (Monitoring and Control Relay) with the below model product references:
RMNF22TB30 NFC control relay
Total: 1 product reference
The NFC control relay is designed to monitor the following functions in 3-phase power networks and upon detection of faults, the relay contacts can be opened or closed with or without a set timing period.
In addition, the above reference is incorporated with Near Field Communication (NFC) that is a short-range wireless connectivity technology standard, designed for intuitive and simple communication between two electronic devices.

Compliance

The above mentioned product complies with the requirements of the relevant ACMA Standards made under the *Radiocommunications Act 1992* and the *Telecommunications Act 1997*. These Standards are referenced in notices made under *section 182 of the Radiocommunications Act and 407 of the Telecommunications Act*.

Evidence of compliance is demonstrated by test reports to the following applicable standards.

Applicable standards

Standard title, number and, if applicable, number of the test report

1. Measuring relays and protection equipment-Part 27: Product safety requirements (EN 60255-27:2014)
2. Measuring relays and protection equipment-Part 26: Electromagnetic compatibility requirements (EN 60255-26:2013/AC:2013)
3. Radio equipment and systems - Short range devices - Limits and methods of measurement (AS/NZS 4268: 2017)
Test Reports - 7191187114-EEC18/03; 7191187114-EEC18/06 both dated 3 Sep 2018

Declaration

I hereby declare that the contents of this form are true and correct, that the product mentioned above complies with the relevant above mentioned standards and all products supplied under this declaration will be identical to the product identified above.

Note: Under section 137.1 of the *Criminal Code Act 1995*, it is an offence to knowingly provide false or misleading information to a Commonwealth entity.

Penalty: 12 months imprisonment

 SIGNATURE OF SUPPLIER OR AGENT
BRADLEY YAGER PRINT NAME

DIRECTOR OF SALES ENABLEMENT POSITION IN ORGANISATION
11/10/2018 DATE