

LICENCE

No. 16025 - Issue No 2

Issued to:

Applicant:

NIKO N.V.

Industriepark-West 40

9100 SINT-NIKLAAS

Belgium

Licensee:

NIKO N.V.

Industriepark-West 40

9100 SINT-NIKLAAS

Belgium



Product : socket-outlets (2-pole)

Trade name(s) : NIKO

Type(s)/model(s) : 7073+10*-67700

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.


SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 14

SGS CEBEC hereby grants the right to use the CEBEC certification mark

The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.


This licence is issued on: 09/10/2013



ir. C. Lana,
Certification Manager

© Only integral publication of this certificate, including the annex, is allowed

This certificate is only valid combined with the publication on the following web address: www.sgs.com/ee



SGS Belgium NV-Division SGS CEBEC
Business Riverside Park
Bld Internationalelaan 55 Build. D
B-1070 Brussels
Tel.+32(0)2 556 00 20 Fax.+32(0)2 556 00 36

This certificate is issued by the company under its General Conditions for Certification Services accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitations of liability defined therein and in the Test Report herein mentioned which findings are reflected in this Certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	:	socket-outlets (2-pole)
Trade name(s)	:	NIKO
Type(s)/Model(s)	:	7073+10*-67700
rated current (In)	:	16 A
rated voltage (Un)	:	250 Vac
earthing	:	with pin-earthing contact
method of mounting	:	flush-type
method of installation	:	design A
existence of shutters	:	with shutters
degree of protection	:	IP 20
type of terminals	:	screws-type

Additional information

Base : 7073
cover plate : 10*-67700

TESTS

Test requirements

NBN C 61-112-1 based on IEC 60884-1:2002 + A1:2006

Remarks

This certificate is based on TRF No. 584376.01 / SMT09-001. and SMT13-002.


Conclusion

The examination proved that all test requirements were met.

Checked by, project leader : Zanutto Luigi - 09/10/2013

Department Manager,
Product Certification :

Certification Manager :

 2013-10-09

FACTORY LOCATION(S)

NIKO N.V.
Industriepark-West 40
9100 SINT-NIKLAAS
Belgium