


TIMEGUARD®

Analogue Economy Seven Programmer

Model: TRTM7N - White



Installation & Operating Instructions

1. General Information


These instructions should be read carefully and retained for further reference and maintenance.

2. Safety

- Before installation or maintenance, ensure the mains supply to the time switch is switched off and the circuit supply fuses are removed or the circuit breaker turned off.
- It is recommended that a qualified electrician is consulted or used for the installation of this time switch and install in accordance with the current IEE wiring and Building Regulations.
- Check that the total load on the circuit including when this time switch is fitted does not exceed the rating of the circuit cable, fuse or circuit breaker.

3. Technical Specifications

- 230V AC 50 Hz
- This time switch is of Class I Construction and must be earthed
- Switch Rating: 13A Resistive (3kW) Immersion Heaters
- Switch Type: Micro-disconnection ON control.
Disconnection to immersion heater(s)
via double pole rocker switch
- Programme: 24 hour segment dial timer
with 15 minute switching intervals
- Boost Times: 15, 30, 60, 120 minutes
- Economy Output Light: Blue LED
- Quartz Reserve: 150 hour battery life
- Tamper proof transparent cover for timer
- IP30 Rated suitable for restricted internal applications
- CE Compliant
- Dimensions (H x W x D): 111.5 x 170 x 60mm



4. Installation


Suitable for use with single, dual, or twin element immersion heaters.

- 2.4.1 Ensure the mains supply is switched off and the circuit supply fuses are removed or the circuit breaker turned off.
- 4.2 Remove the 2 fixing screws holding the front panel to the back box.
- 4.3 Decide which mounting holes you would like to use and select a suitable cable entry point by drilling into the back box ensuring not damage or infringe on any of the internal components.
- 4.4 Mark the position of the mounting holes on the wall using the back box as a template. Drill out the mounting holes taking care to avoid any joists, electrical cables or water/gas pipes that may be hidden beneath the surface. Insert the rawl plugs into the holes.
- 4.5 Pass the 230V 50Hz mains supply and load cables through the cable entry point(s) on the back box.
- 4.6 Fix the back box to the wall using the correct mounting screws for the rawl plugs installed.
- 4.7 Use the cable clamp in the back box to secure the cables.
- 4.8 Terminate the cables into the terminal block ensuring correct polarity is observed and that all bare conductors are sleeved (See section 5. Connection Diagram).
- 4.9 Ensure all terminals are secured and screw the front panel of the unit to the back box using the 2 fixing screws previously removed.

5. Connection Diagram

Connect the cables to the terminal block which are marked as follows;

- 230V 50Hz mains – Single element immersion heaters only.



3

230V 50Hz Mains Supply

Live Supply (Brown or Red) to
Neutral Supply (Blue or Black) to
Earth (Green/Yellow) to

terminal 1
terminal 2



Load


Switch Live, Off peak load (Brown or Red) to
Heater Neutral (Blue or Black) to
Earth (Green/Yellow) to

terminal 5
terminal 3



Note: a link or bridge will need to be fitted between **terminal 4** and **terminal 5** if you wish to use the Boost button (single element immersion heaters only).

- 230V 50Hz mains – Twin or Dual element immersion heaters.



4

230V 50Hz Mains Supply

Live Supply (Brown or Red) to
Neutral Supply (Blue or Black) to
Earth (Green/Yellow) to

terminal 1
terminal 2



Load

Switch Live, Off peak load –
Primary element (Brown or Red) to
Switch Live, Boost load –
Secondary element (Brown or Red) to
Heater Neutral (Blue or Black) to
Earth (Green/Yellow) to

terminal 5


terminal 4
terminal 3



6. Commissioning

- Contact your energy supplier to check which energy plan you are on.
- Turn the outer ring of the timer module clockwise to set the current time.
- Set the economy period by positioning the relevant tappet;
 - IN towards the centre = OFF
 - OUT towards the outer edge = ON
- Fit the tamper proof cover over the timer module and push to click into place.

Operating Modes



OFF

TIMED

- OFF: With the rocker switch set to OFF, the unit can be set. There will be no output, either from economy periods or boost.
- TIMED: With the rocker switch set to TIMED, the output will be according to the program, or the appropriate boost period.

5

Illumination

- During off peak periods, the Economy Light will illuminate.

ECONOMY



- The Boost Button surround illuminates during boost periods, and the selected time will be illuminated also.



120



60



30




15



7. Manual Boost

- The manual boost is operated by pressing the BOOST button. When the BOOST button is pressed, the button surround will illuminate, and the selected time will be illuminated also.



- Press the BOOST button once for 15 minutes, twice for 30 minutes, three times for 60 minutes or four times for 120 minutes. Successive presses of the boost button will scroll through the time periods.

120	<input type="checkbox"/>
60	<input type="checkbox"/>
30	<input type="checkbox"/>
15	<input type="checkbox"/>

- The boost can be cancelled by repeatedly pressing the boost button until there is no boost light displayed.
- Should an economy period start within the duration of the boost, this will override the boost period, using cheaper off peak electricity.
- During an off peak period, with the economy light illuminated, it is not possible to use the boost function.

If you experience problems, do not immediately
return the unit to the store.

Telephone the Timeguard Customer Helpline;

**HELPLINE
01582 544 548**

or email helpline@timeguard.com

Qualified Customer Support Co-ordinators will be on-line
to assist in resolving your query.



Deta Electrical Co Ltd
Panattoni Park, Luton Road,
Chalton, Bedfordshire, LU4 9TT
Sales Office: 020 8452 1112
or email csc@timeguard.com

www.timeguard.com