



产品认证证书

证书编号: CQC2014010304744408

申请人名称及地址

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

制造商名称及地址

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

生产企业名称及地址

ABB 新会低压开关有限公司 (V005372)
广东省江门市新会区今古洲工业开发区

产品名称和系列、规格、型号

软起动器

PSTX210-600-70, PSTX250-600-70, PSTX300-600-70, PSTX370-600-70,
PSTX210-690-70, PSTX250-690-70, PSTX300-690-70, PSTX370-690-70: 详细参数及型号解释
见附件

产品标准和技术要求

GB/T 14048.6-2016

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 08 月 14 日 有效期至: 2024 年 08 月 09 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: _____

陆杨



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0351920



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2014010304744408

NAME AND ADDRESS OF THE APPLICANT

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

NAME AND ADDRESS OF THE MANUFACTURER

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

NAME AND ADDRESS OF THE FACTORY

ABB Xinhui Low Voltage Switchgear Co.,Ltd. (V005372)
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

soft starter

PSTX210-600-70, PSTX250-600-70, PSTX300-600-70, PSTX370-600-70,
PSTX210-690-70, PSTX250-690-70, PSTX300-690-70, PSTX370-690-70: See the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.6-2016

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Aug.14,2020

Valid until: Aug.09,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0351920



产品认证证书

附录

第 1 页 共 2 页

证书编号: CQC2014010304744408

纸号: 351920

PSTX210-600-70, PSTX250-600-70,
PSTX300-600-70, PSTX370-600-70,
PSTX210-690-70, PSTX250-690-70,
PSTX300-690-70, PSTX370-690-70
PSTX210-600-70, PSTX250-600-70,
PSTX300-600-70, PSTX370-600-70
Ui: 600V; Ue: 208-550V AC ;
Ith= Ie: 210A (PSTX210-600-70) ; 250A (PSTX250-600-70)
300A (PSTX300-600-70) ; 370A (PSTX370-600-70)
PSTX210-690-70, PSTX250-690-70,
PSTX300-690-70, PSTX370-690-70
Ui: 690V; Ue: 208-690V AC ;
Ith= Ie: 210A (PSTX210-690-70) ; 250A (PSTX250-690-70) ;
300A (PSTX300-690-70) ; 370A (PSTX370-690-70)
Pe:

注: 此附录与证书同时使用时有效。

主任: 陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



产品认证证书

附录

第 2 页 共 2 页

证书编号: CQC2014010304744408

纸号: 351920

产品型号	额定工作 电流 Ie (A)	额定功率(kW)			
		220-230V	380-400V	500V	690V
PSTX210-600-70	210	59	110	132	-
PSTX250-600-70	250	75	132	160	-
PSTX300-600-70	300	90	160	200	-
PSTX370-600-70	370	110	200	257	-
PSTX210-690-70	210	59	110	132	184
PSTX250-690-70	250	75	132	160	220
PSTX300-690-70	300	90	160	200	257
PSTX370-690-70	370	110	200	257	355

AC-53a; 3P

型号解释:

PSTX ***-***-70

1 2 3 4

1 = Softstarter, name of series

2 = Current rating, In line Ie,: 210=210A, 370=370A

3 = Operational voltage, Ue: 600 = 208-550V AC, 690 = 208-690V AC

4 = Control supply voltage, Us: 70 = 100 - 250V AC

注: 此附录与证书同时使用时有效。

主任: 陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>