



产品认证证书

证书编号: CQC2014010304724384

申请人名称及地址

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

制造商名称及地址

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

生产企业名称及地址

ABB AB, Control Products (V054504)
Motorgrand 20, 72161 Vasteras, Sweden

产品名称和系列、规格、型号

软起动器

PSTX210-600-70, PSTX250-600-70, PSTX300-600-70, PSTX370-600-70, PSTX210-690-70,
PSTX250-690-70, PSTX300-690-70, PSTX370-690-70; 详细参数及型号解释见附件

产品标准和技术要求

GB/T14048.6-2016

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 08 月 28 日 有效期至: 2024 年 08 月 19 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任:

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0380645



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2014010304724384

NAME AND ADDRESS OF THE APPLICANT

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

NAME AND ADDRESS OF THE MANUFACTURER

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

NAME AND ADDRESS OF THE FACTORY

ABB AB, Control Products (V054504)
Motorgrand 20, 72161 Vasteras, Sweden

PRODUCT NAME, MODEL AND SPECIFICATION

Softstarter

PSTX210-600-70, PSTX250-600-70, PSTX300-600-70, PSTX370-600-70, PSTX210-690-70,
PSTX250-690-70, PSTX300-690-70, PSTX370-690-70; See the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.6-2016

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Aug.28,2020

Valid until: Aug.19,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0380645



产品认证证书

附录

第 1 页 共 2 页

证书编号: CQC2014010304724384

纸号: 380645

PSTX210-600-70, PSTX250-600-70, PSTX300-600-70, PSTX370-600-70,

PSTX210-690-70, PSTX250-690-70, PSTX300-690-70, PSTX370-690-70

额定绝缘电压(U_i): 600V (PSTX210-600-70, PSTX250-600-70, PSTX300-600-70,

PSTX370-600-70), 690V (PSTX210-690-70, PSTX250-690-70, PSTX300-690-70,

PSTX370-690-70);

约定发热电流(I_{th}): PSTX210:210A, PSTX250:250A, PSTX300:300A, PSTX370:370A.;

额定工作电压(U_e): 208-550V AC (PSTX210-600-70, PSTX250-600-70, PSTX300-600-70,

PSTX370-600-70), 208-690V AC (PSTX210-690-70, PSTX250-690-70, PSTX300-690-70,

PSTX370-690-70);

额定工作电流(I_e): PSTX210:210A, PSTX250:250A, PSTX300:300A, PSTX370:370A.;

额定功率(P_e):

注: 此附录与证书同时使用时有效。

主任:

陆梅



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



产品认证证书

附录

第 2 页 共 2 页

证书编号: CQC2014010304724384

纸号: 380645

Type	Ie (A)	Power(kW)			
		220-230V	380-400V	500V	690V
PSTX210-600-70	210	59	110	132	-
PSTX250-600-70	250	75	132	160	-
PSTX300-600-70	300	90	160	200	-
PSTX370-600-70	370	110	200	257	-
PSTX210-690-70	210	59	110	132	184
PSTX250-690-70	250	75	132	160	220
PSTX300-690-70	300	90	160	200	257
PSTX370-690-70	370	110	200	257	355

使用类别: AC-53a; 极数: 3P

型号解释:

Typekey for Softstarter in the PSTX-series

PSTX ***-6**-70

1 2 3 4

1 = Softstarter, name of series

2 = Current rating, Inline/Inside delta Ie: 210=210A, 250=250A, 300=300A, 370=370A

3 = Operational voltage, Ue: 00 = 208-550V AC, 90 = 208-690V AC

4 = Control supply voltage, Ue: 70 = 100 - 250V AC

注: 此附录与证书同时使用时有效。

主任:

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>