



# 产品认证证书

证书编号: CQC2014010304725046

II 型自愿认证

申请人名称及地址

ABB France

2 rue d'Arsonval 69680 Chassieu France

制造商名称及地址

ABB France

2 rue d'Arsonval 69680 Chassieu France

生产企业名称及地址

Maltown Electrics Pvt Ltd (V058840)

NO. 560-H, HASSAN GROWTH CENTRE INDUSTRIAL AREA, Holenarsipura Road,  
KIADB Industrial Area Hassan - 573201 India

产品名称和系列、规格、型号

辅助触点

CA5X-\*\*\* (型号解释见附件); Uimp:6kV; Ui:690V; Ith:16A;  
Ue/Ie:AC-15:AC24-127V/6A, AC220-240V/4A, AC380-440V/3A, AC500-690V/2A;  
DC-13:DC24V/6A, DC48V/2.8A, DC72V/1A, DC110-125V/0.55A, DC220-250V/0.3A; IP20

产品标准和技术要求

GB/T 14048.5-2017

认证模式

产品型式试验+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

发证日期: 2020 年 11 月 24 日 有效期至: 2024 年 08 月 19 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2020 年 08 月 21 日

主任:

陆杨



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0437475



# PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2014010304725046

Type II CQC Certification

## NAME AND ADDRESS OF THE APPLICANT

ABB France  
2 rue d'Arsonval 69680 Chassieu France

## NAME AND ADDRESS OF THE MANUFACTURER

ABB France  
2 rue d'Arsonval 69680 Chassieu France

## NAME AND ADDRESS OF THE FACTORY

Maltown Electrics Pvt Ltd (V058840)  
NO.560-H, HASSAN GROWTH CENTRE INDUSTRIAL AREA, Holenarsipura Road, KIADB Industrial Area  
Hassan - 573201 India

## PRODUCT NAME, MODEL AND SPECIFICATION

Auxiliary contacts  
CA5X-\*\*\*; Uimp:6kV; Ui:690V; Ith:16A; Ue/Ie:AC-15:AC24-127V/6A,AC220-240V/4A,AC380-440V/3A,AC500-690V/2A;  
DC-13:DC24V/6A,DC48V/2.8A,DC72V/1A,DC110-125V/0.55A,DC220-250V/0.3A; IP20

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

## TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020 .

Valid from: Nov.24,2020

Valid until: Aug.19,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Aug.21,2020

President:

Lu Mei



# CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China  
<http://www.cqc.com.cn>

C 0437475



# 产品认证证书

附录

第 1 页 共 2 页

证书编号: CQC2014010304725046

纸 号: 437475

型号解释:

| CA5X | 40 | E   |
|------|----|-----|
| I    | II | III |

I - Main designation : CA5X Auxiliary contact module, front mounting  
主型号: CA5X 辅助触头模块, 前装

II - Auxiliary Pole Construction  
触点配置

- 40 - 4 Normally Opened and 0 Normally Closed. 4 常开
- 31 - 3 Normally Opened and 1 Normally Closed. 3 常开, 1 常闭
- 22 - 2 Normally Opened and 2 Normally Closed. 2 常开, 2 常闭
- 13 - 1 Normally Opened and 3 Normally Closed. 1 常开, 3 常闭
- 04 - 0 Normally Opened and 4 Normally Closed. 4 常闭

III - Marking 标识

- E : for contactor 4 main poles (type 40-00 or 22-00) 对 4 极接触器(形式 40-00 or 22-00)
- M : for contactor 3 main poles (type 30-10) 对 3 极接触器(形式 30-10)
- U : for contactor 3 main poles (type 30-01) 对 3 极接触器(形式 30-01)
- N : for auxiliary contactor 对辅助触头

注: 此附录与证书同时使用时有效。

主任:

陆楠



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



# 产品认证证书

附录

第 2 页 共 2 页

证书编号: CQC2014010304725046

纸号: 437475

| Designation |
|-------------|
| CA5X-40E    |
| CA5X-31E    |
| CA5X-22E    |
| CA5X-04E    |
| CA5X-31M    |
| CA5X-22M    |
| CA5X-13M    |
| CA5X-04M    |
| CA5X-40U    |
| CA5X-31U    |
| CA5X-22U    |
| CA5X-04U    |
| CA5X-40N    |
| CA5X-31N    |
| CA5X-22N    |
| CA5X-13N    |
| CA5X-04N    |

注: 此附录与证书同时使用时有效。

主任:

陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>