



中国国家强制性产品认证证书

证书编号: 2014010303720193

委托人名称、地址

ABB STOTZ-KONTAKT GmbH

Hauptstrasse 14-16, D-78132 Hornberg, Germany

生产者(制造商)名称、地址

Relpol S.A.

ul. 11 Listopada 37, 68-200 Zary, Poland

生产企业名称、地址

Relpol S.A.

ul. 11 Listopada 37, 68-200 Zary, Poland

产品名称和系列、规格、型号

继电器

CR-M(型号解释详见附件); Uimp:4kV(2P,3P),2.5kV(4P); Ui:300V;
Ith:12A(2P),10A(3P),6A(4P); Ue/Ie:AC-15:AC240V/1.5A(2P,3P),AC240V/1.0A(4P); IP40(操
作面)

产品标准和技术要求

GB/T14048.5-2017

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2019 年 08 月 19 日 有效期至: 2024 年 08 月 19 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2014 年 09 月 05 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2014010303720193

NAME AND ADDRESS OF THE APPLICANT

ABB STOTZ-KONTAKT GmbH
Hauptstrasse 14-16, D-78132 Hornberg, Germany

NAME AND ADDRESS OF THE MANUFACTURER

Relpol S.A.
ul.11 Listopada 37, 68-200 Zary, Poland

NAME AND ADDRESS OF THE FACTORY

Relpol S.A.
ul.11 Listopada 37, 68-200 Zary, Poland

PRODUCT NAME, MODEL AND SPECIFICATION

Relays
CR-M; Uimp:4kV(2P,3P),2.5kV(4P); Ui:300V; Ith:12A(2P),10A(3P),6A(4P); Ue/Ie:AC-15:A
C240V/1.5A(2P,3P),AC240V/1.0A(4P); IP40(above operating surface)

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Aug.19,2019

Valid until: Aug.19,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Sep.05,2014

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号: 2014010303720193

纸 号: 2351780

型号的解释:

CR-M 024DC 3 L
① ② ③ ④

① basic model (基本型号)

② coil voltage (线圈电压) 012DC, 024DC, 048DC, 060DC, 110DC, 125DC, 220DC
024AC, 048AC, 110AC, 120AC, 230AC;

③ number of poles (极数): 2, 3, 4;

④ accessories: (附件)

NULL - general relay without any accessories 一般继电器, 不带任何附件

L - with LED 带 LED

LG: with LED and gold plated contacts 带 LED 和镀金触点

LD: with LED and freewheeling diode 带 LED 和续流二极管保护

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心