

产品认证证书

II型自愿认证

证书编号: CQC2019010302217617

发证日期: 2020年09月02日

有效期至: 2032年06月17日

委托人名称 ABB Stotz-Kontakt GmbH
及注册地址 Eppelheimer Strasse 82 69123 Heidelberg Germany

制造商名称 ABB Stotz-Kontakt GmbH
及注册地址 Eppelheimer Strasse 82 69123 Heidelberg Germany

生产企业名称 Videoton Bulgarian Holdings EOOD
及生产地址 Stara Zagora 6000, 10 Nikola Petkov Blvd, Bulgaria

产品名称和系列、规格、型号 隔离开关
E201, E202, E203, E204;详见附件

产品标准和技术要求 GB/T14048.3-2017

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

签发

郑泉

谢肇煦



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0157727

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2019010302217617

Valid from: Sep.02,2020

Valid until: Jun.17,2032

NAME AND REGISTERED ADDRESS OF THE APPLICANT ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND LOCATION OF THE FACTORY Videoton Bulgarian Holdings EOOD
Stara Zagora 6000, 10 Nikola Petkov Blvd, Bulgaria

PRODUCT NAME, MODEL AND SPECIFICATION Switch-disconnector
E201, E202, E203, E204;See the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T14048.3-2017

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

郑+泉

SIGNATURE

谢肇熙



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0157727

产品认证证书

II型自愿认证

附 录

证书编号: CQC2019010302217617

第 1 页 共 2 页

纸 号:

E201, E202, E203, E204

U_{imp} : 4kV;

U_i : 440V;

I_{th} : 16A, 25A, 32A, 40A, 45A, 63A, 80A, 100A, 125A;

U_e : AC240V(1P), AC415V(2P, 3P, 4P), DC60V(1P 外形, 2P 外形);

I_e : 16A, 25A, 32A, 40A, 45A, 63A, 80A, 100A, 125A;


I_q : 6kA(125A, 1P, 2P, 3P, 4P), 10kA(125A, 1P 外形, 2P 外形),
25kA(16A-100A, 1P, 2P, 3P, 4P, 1P 外形, 2P 外形);

使用类别: AC-22A, DC-21B;

极数: 1P, 2P, 3P, 4P;

防护等级: IP10;

直流产品接线方式:



注: 此附录与证书同时使用时有效。



中国质量认证中心

产品认证证书

II型自愿认证

附 录

证书编号: CQC2019010302217617

第 2 页 共 2 页

纸 号:

型号解释:

<u>E20</u> I	<u>1</u> II	/	<u>100</u> III	<u>r/g</u> IV
-----------------	----------------	---	-------------------	------------------

I Basic type 基本型号

II Number of poles 极数

1: 1 pole	1 极;	2: 2 poles	2 极;
3: 3 poles	3 极;	4: 4 poles	4 极;

III Rated current: 额定电流 16A, 25A, 32A, 40A, 45A, 63A, 80A, 100A, 125A

IV toggle 手柄
r: red toggle 红色
g: grey toggle 灰色

注: 此附录与证书同时使用时有效。



中国质量认证中心