

EU-type examination certificate

Number **T10359** revision 25
Project number 3492054
Page 1 of 1

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU,
after having established that the Measuring instrument meets the applicable
requirements of Directive 2014/32/EU, to:

Manufacturer ABB S.p.A.
Viale dell'Industria 18
20009 Vittuone (MI)
Italy

Measuring instrument A static **Active Electrical Energy Meter**
Type : A43, A44 and A44 690V
Manufacturer's mark or name : ABB

Reference voltage : 3x57,7/100V...3x288/500V (3-phase 4-wire network)
3x100V...3x500V (3-phase 3-wire network)
3x57,7/100V...3x400/690V (3-phase 4 wire network)
3x100V...3x690V (3-phase 3-wire network)

Reference current : A43: 5 A (direct connected)
A44: 1 A (indirect connected)
A44 690V: 1 A (indirect connected)

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network

Accuracy class : A43: A or B
A44: A, B or C
A44 690V: A, B or C

Environment classes : M2 / E2
Temperature range : -40 °C / +70 °C
Further properties are described in the annexes:
- Description T10359 revision 25;
- Documentation folder T10359-13.

Valid until 23 February 2032

Remark This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority

NMI Certin B.V., Notified Body number 0122
31 March 2022

Certification Board

NMI Certin B.V.
Thijssseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision
that no liability is accepted and that the
manufacturer shall indemnify third-party
liability.

The designation of NMI Certin B.V. as Notified
Body can be verified at [http://
ec.europa.eu/growth/tools-databases/nando/](http://ec.europa.eu/growth/tools-databases/nando/)

Reproduction of the complete
document only is permitted.

This document is digitally signed
and sealed. The digital signature
can be verified in the blue ribbon at
the top of the electronic version of
this certificate.