

RCC

(REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO

ABB SOUTH AFRICA (PTY) LTD

IN TERMS OF SANS 10142 CLAUSE 4.

ISSUED BY

National Regulator for Compulsory Specifications

PRODUCT: EARTH LEAKAGE PROTECTION UNITS - ELCBs (ABB) FH204 AC, FH204 A;

$I_n = 415V \sim 4P (3P+N); I_n = 63A; I_{cw} = 6.0kA; I_{In} = 0.03A; 50Hz;$

Test Laboratory:

ZTME

Test report no: 1W181449

RCC No: 1908068



NRCS – Electrotechnical General Manager.



In accordance to(Standards):

VC8035:1987 + Amendment:1990

SABS 767-1:1982 + A1:1985 + A2:1997

Period of Validity

15/08/2019 to 15/08/2022

DATE 2019-08-16