

Mr Ian Richardson
ABB Australia Pty Ltd
601 Blackburn Road
NOTTING HILL VIC 3168

Dear Sir/Madam

RENEWAL OF CERTIFICATE OF APPROVAL: NSW20673

Residual Current Device

Please find enclosed an addendum to the certificate as sought in your application.

THE APPROVAL NOW EXPIRES ON 26/06/2025 unless it is renewed, extended, suspended or cancelled.

Yours faithfully,



For Secretary, Department of Customer Service



Fair
Trading

Ref: NSW20673/5

RENEWAL OF CERTIFICATE OF APPROVAL: NSW20673

Particulars of Renewal

The approval of Residual current operated circuit breakers FH200 Series and all approved modifications has been renewed for a period of FIVE years.

The Approval expires on 26/06/2025 unless it is renewed, extended, suspended or cancelled.

Approved pursuant to Clause 11 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018

30 June 2020

For Secretary, Department of Customer Service



Fair
Trading

File Ref: NSW20673/3
Contact: Admin Clerk
Telephone: 02 9895 0722

Mr Ian Richardson
ABB Australia Pty Ltd
PO Box 4294
MOUNT WAVERLEY VIC 3149

Dear Sir/Madam

MODIFICATION TO CERTIFICATE OF APPROVAL: NSW20673

Residual Current Device

Please find enclosed an addendum to the certificate as sought in your application.

Any sample/s held by this Office should be collected within fifteen (15) days of this letter or the sample/s will be destroyed.

Yours faithfully,

For Commissioner for Fair Trading

9 September 2018



Fair
Trading

Ref: NSW20673/3

ADDENDUM TO CERTIFICATE OF APPROVAL: NSW20673 Particulars of Modification(s)

1. FH200 Series modified by the addition of the suffix AC to indicate a Type 'AC' residual current classification as follows: -
 - (a) FH202 AC 2 Pole
Trade Name: 'ABB'
Rated Voltage: 230/400V, 50Hz
Rated Currents: 25A or 40A or 63A
Rated Residual Currents: 30mA or 100mA or 300mA
 - (b) FH204 AC 4 Pole
Trade Name: 'ABB'
Rated Voltage: 230/400V, 50Hz
Rated Currents: 25A or 40A or 63A
Rated Residual Currents: 30mA, 100mA or 300mA
2. FH200 Series modified by the inclusion of the suffix A to indicate a Type 'A' residual current classification as follows: -
 - (a) FH202 A: 2 Pole
Trade Name: 'ABB'
Rated Voltage: 230/400V, 50Hz
Rated Currents: 25A or 40A or 63A
Rated Residual Currents: 30mA or 100mA or 300mA.
 - (b) FH204 A: 4 Pole
Trade Name: 'ABB'
Rated Voltage: 230/400V, 50Hz
Rated Currents: 25A or 40A or 63A
Rated Residual Current: 30mA or 100mA or 300mA.

This certificate will expire on 06/05/2020

Approved: 4 September 2018

For Commissioner for Fair Trading



Fair Trading

File Ref: NSW20673/2
Contact: Admin Clerk
Telephone: 02 9895 0722
Fax: 02 9895 9917

Mr Ian Richardson
ABB Australia Pty Ltd
PO Box 4294
MOUNT WAVERLEY VIC 3149

Dear Sir/Madam

RENEWAL OF CERTIFICATE OF APPROVAL: NSW20673


Residual Current Device

Please find enclosed an addendum to the certificate as sought in your application.

THE APPROVAL NOW EXPIRES ON 06/05/2020 unless it is renewed, extended, suspended or cancelled.

Any sample/s held by this Office should be collected within fifteen (15) days of this letter or the sample/s will be destroyed.

Yours faithfully,


For Commissioner for Fair Trading

24 April 2015



**Fair
Trading**


Ref: NSW20673/2

RENEWAL OF CERTIFICATE OF APPROVAL: NSW20673

Particulars of Renewal

The approval of the original two and four pole residual current devices Types FH202 AC and FH204 AC respectively have been renewed.

The Approval expires on 06/05/2020 unless it is renewed, extended, suspended or cancelled.


For Commissioner for Fair Trading



Fair
Trading

Mr Ian Richardson
ABB Australia Pty Ltd
PO Box 4294
MOUNT WAVERLEY VIC 3149

File Ref: NSW20673
Contact: Admin Clerk
Telephone: 02 9895 0722
Fax: 02 9895 0735

Dear Sir/Madam

RENEWAL OF CERTIFICATE OF APPROVAL: NSW20673

Residual Current Device

Please find enclosed an addendum to the certificate as sought in your application.

Approved articles may now be marked with either-

- (a) the mark (or marks) as shown on the Certificate; or
- (b) the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

THE APPROVAL NOW EXPIRES ON 06/05/2015 unless it is renewed, extended, suspended or cancelled.

Any sample/s held by this Office should be collected within fifteen (15) days of this letter or the sample/s will be destroyed.

Yours faithfully,

for Deputy Commissioner, Fair Trading Operations
29 April 2010



Fair
Trading

Ref: NSW20673

RENEWAL OF CERTIFICATE OF APPROVAL NSW20673

PARTICULARS OF RENEWAL

The approval of the original two and four pole residual current devices Types FH202 AC and FH204 AC respectively have been renewed.

The Approval expires on 06/05/2015 unless it is renewed, extended, suspended or cancelled.

A handwritten signature in black ink, appearing to be "Pall", written over a horizontal line.

for Deputy Commissioner, Fair Trading Operations



OFFICE OF FAIR TRADING
NSW Consumer Protection Agency
Department of Commerce

Certificate Number: 20673

CERTIFICATE OF APPROVAL

ISSUED PURSUANT TO SECTION 21C OF THE ELECTRICITY SAFETY ACT 1945

ISSUED TO:

ABB Australia Pty Ltd

CLASS OF ARTICLE:

Residual Current Device

DESCRIPTION OF ARTICLE:

Residual current operated circuit breakers for panel mounting in separate enclosures 2P OR 4P:

Type FH202 AC.

Trade Name: 'ABB'

230/400V, ~, 50Hz, 25A or 40A or 63A, Type AC characteristic and rated residual operating current of 30mA or 100mA or 300mA.

Rated short-circuit capacity 1000A.

Type FH204 AC.

Trade Name: 'ABB'

230/400V, ~, 50Hz, 25A or 40A or 63A, Type A characteristic and rated residual operating current of 30mA.

Rated short-circuit capacity 1000A.

EXAMINED FOR COMPLIANCE WITH: AS/NZS61008.1:2004

TYPE REFERENCE CODE: FH200 Series

APPROVAL MARK:

Each electrical article of the abovementioned type shall be marked with Approval Number NSW20673

DATE OF APPROVAL: 06 May 2005

This approval expires 06 May 2010 unless suspended, cancelled, renewed or extended.

for Commissioner of Fair Trading

Annulled at 20-04-10