



IEC SYSTEM FOR CONFORMITY
TESTING TO STANDARDS FOR
SAFETY OF ELECTRICAL
EQUIPMENT (IECEE) CB SCHEME

Ref. Certificate No.

NL-6278/1

CB TEST CERTIFICATE

Issued by: KEMA Quality B.V.

Registration date: 2003-01-27

Product: Auxilliary Contact for contactor types B6 and B7

Applicant: ABB Stotz-Kontakt GmbH Eppelheimerstrasse 82 Germany
69123 HEIDELBERG

Manufacturer: ABB Stotz-Kontakt GmbH Eppelheimerstrasse 82 Germany
69123 HEIDELBERG

Factory: ABB Stotz-Kontakt GmbH Eppelheimerstrasse 82 Germany
69123 HEIDELBERG

Rating and principal characteristics: - DC13 24 Vdc - 2,5 A, 110 Vdc - 0,7 A, 220 V - 0,4 A
- AC15 240 Vac - 4 A, 440 V - 3 A, 500 V - 2 A, lth/ lthe
6 A, Ui 690 V, Uimp 6 kV

Trade mark (if any): ABB

Model/Type reference: CA6x, K6x and KC6x

Additional information: -

Sample of product tested to be in conformity with IEC: 60947-5-1
(ed.2);am1;am2

Test Report Ref. No: 2025724.50

This CB Test Certificate is issued by the National Certification Body

KEMA 

KEMA Quality B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands

Signed by: L.J.W. van Megen



Date of issue: 2003-01-27