

产品认证证书

II型自愿认证

证书编号: CQC2007010307258193

发证日期: 2021年12月08日

有效期至: 2031年12月08日

委托人名称	ABB 新会低压开关有限公司
及注册地址	广东省江门市新会区今古洲工业开发区
制造商名称	ABB 新会低压开关有限公司
及注册地址	广东省江门市新会区今古洲工业开发区
生产企业名称	ABB 新会低压开关有限公司
及生产地址	广东省江门市新会区今古洲工业开发区
产品名称和系列、 规格、型号	具有剩余电流保护的断路器 T5+RC222Ue:AC400V/415V;In:320A,400A,500A(热磁式);In:320A,400A,500A,630A(电子式);过电流脱扣器类型:热磁式,电子式;Icu=Ics:36kA(N型),50kA(S型),70kA(H型);IΔn:30mA,50mA,100mA,300mA,500mA,1A,3A,5A,10A/A型;漏电脱扣器类型:电子式;IΔm:25%Icu;选择性类别:A类;4P; 规格参数详见附件
产品标准和技术要求	GB/T 14048.2-2020
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020年08月14日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn)查验证书信息



授权签字人

签发

刘江

谢肇煦



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0129132

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2007010307258193

Valid from: Dec.08,2021

Valid until: Dec.08,2031

**NAME AND REGISTERED
ADDRESS OF THE APPLICANT**

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province,
P.R.China

**NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER**

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province,
P.R.China

**NAME AND LOCATION
OF THE FACTORY**

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province,
P.R.China

**PRODUCT NAME, MODEL
AND SPECIFICATION**

Residual Current Operated Circuit Breaker
T5+RC222Ue:AC400V/415V;In:320A,400A,500A(Thermal
Magnetic);In:320A,400A,500A,630A(Electronic);Thermal Magnetic,Electronic Over-current
Release;Icu=Ics:36kA(N),50kA(S),70kA(H);I_{Δn}:30mA,50mA,100mA,300mA,500mA,1A,3A,5A,10A/
A Type;Electronic Residual Current Tripping Unit;I_{Δm}:25%Icu;Utilization Category:A;4P; See the
Appendix

**THE STANDARDS AND
TECHNICAL REQUIREMENTS
FOR THE PRODUCTS**

GB/T 14048.2-2020

**TYPE OF CERTIFICATION
SCHEMES**

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Aug.14,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

刘江

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0129132

产品认证证书

II型自愿认证

证书编号: CQC2007010307258193

第1页 共2页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 129132

型号的解释:

T5N630PR221DS-LSI6304P F F + RC222

①②③④⑤⑥⑦⑧⑨⑩

①: Tmax 塑壳断路器 框架号码: 5

②: 分断能力: N、S、H

③: 框架电流 630A

④: 电子脱扣器类型

⑤: 脱扣器保护段数可选:

I: 短路瞬动保护

L: 过载长延时保护

S: 短路短延时保护

⑥: 额定电流: 320、400、630A

⑦: 极数: 4P

⑧: 安装方式: 固定式

⑨: 接线方式

⑩: 剩余电流脱扣器



中国质量认证中心



产品认证证书

II型自愿认证

证书编号: CQC2007010307258193

第2页 共2页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 129132

T5N630TMA500-50004P F F + RC222

①②③④⑤⑥⑦⑧⑨⑩

- ①: Tmax 塑壳断路器 框架号码: 5
- ②: 分断能力: N、S、H
- ③: 框架电流 630A
- ④: 热磁脱扣器类型
- ⑤: 额定电流: 320、400、500A
- ⑥: 10Ith
- ⑦: 极数: 4P
- ⑧: 安装方式: 固定式
- ⑨: 接线方式
- ⑩: 剩余电流脱扣器



中国质量认证中心

