



产品认证证书

证书编号: CQC2003010306078336

申请人名称及地址

ABB 新会低压开关有限公司
广东省江门市新会区今古洲工业开发区

制造商名称及地址

ABB 新会低压开关有限公司
广东省江门市新会区今古洲工业开发区

生产企业名称及地址

ABB 新会低压开关有限公司 (V005372)
广东省江门市新会区今古洲工业开发区

产品名称和系列、规格、型号

剩余电流动作保护继电器

RCD: Un: AC690V; Usn: AC85~380V; In: 250A(Φ60), 400A(Φ110), 630A(Φ185); 输出触头额定工作电压/电流: Ue/Ie:
AC-15: 250V/6A; IΔn: 0.03/0.1/0.3/0.5/1/3/5A(可调); 额定剩余动作类型: A 型; IΔw: 3kA(Φ60), 4kA(Φ110), 6.3kA
(Φ185); Icw: 3kA(Φ60), 4kA(Φ110), 6.3kA(Φ185); 电子式

产品标准和技术要求

GB/T 22387-2016

认证模式

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 08 月 14 日 有效期至: 2024 年 11 月 14 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任:

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0353287



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2003010306078336

NAME AND ADDRESS OF THE APPLICANT

ABB Xinhui Low Voltage Switchgear Co., Ltd.
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen, Guangdong Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

ABB Xinhui Low Voltage Switchgear Co., Ltd.
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen, Guangdong Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

ABB Xinhui Low Voltage Switchgear Co., Ltd. (V005372)
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Residual Current Relays

RCD: Un: AC690V;Usn: AC85~380V;In: 250A(Φ60), 400A(Φ110), 630A(Φ185);Ue/Ie: AC-15: 250V/6A;IΔn: 0.03/0.1/0.3/0.5/1/3/5A(adjustable);Type A;IΔw: 3kA(Φ60), 4kA(Φ110), 6.3kA(Φ185);Icw: 3kA(Φ60), 4kA(Φ110), 6.3kA(Φ185);electric

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 22387-2016

TYPE OF CERTIFICATION SCHEMES

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019.

Valid from: Aug.14,2020

Valid until: Nov.14,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President: _____

陆梅

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0353287