



# 产品认证证书

证书编号: CQC2011010304501045

申请人名称及地址

ABB 新会低压开关有限公司  
广东省江门市新会区今古洲工业开发区

制造商名称及地址

ABB 新会低压开关有限公司  
广东省江门市新会区今古洲工业开发区

生产企业名称及地址

ABB 新会低压开关有限公司 (V005372)  
广东省江门市新会区今古洲工业开发区

产品名称和系列、规格、型号

辅助触头

AUX 250V: Ui:300V; Uimp:2.5kV; Ith:6A; AC-12: Ue/Ie:AC:125V/6A, 250V/6A; AC-13: Ue/Ie:AC:125V/6A, 250V/6A; AC-14: Ue/Ie:AC:125V/6A, 250V/5A; AC-15: Ue/Ie:AC:125V/5A, 250V/4A; DC-12: Ue/Ie:DC:110V/0.5A, 250V/0.3A; DC-14: Ue/Ie:DC:110V/0.05A, 250V/0.03A

产品标准和技术要求

GB/T14048.5-2017

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 08 月 14 日 有效期至: 2021 年 07 月 13 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: \_\_\_\_\_

陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0353258



# PRODUCT CERTIFICATE

**CERTIFICATE NO.: CQC2011010304501045**

**NAME AND ADDRESS OF THE APPLICANT**

ABB Xinhui Low Voltage Switchgear Co., Ltd.  
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen, Guangdong Province, P.R.China

**NAME AND ADDRESS OF THE MANUFACTURER**

ABB Xinhui Low Voltage Switchgear Co., Ltd.  
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen, Guangdong Province, P.R.China

**NAME AND ADDRESS OF THE FACTORY**

ABB Xinhui Low Voltage Switchgear Co., Ltd. (V005372)  
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province, P.R.China

**PRODUCT NAME, MODEL AND SPECIFICATION**

Auxiliary contacts

AUX 250V: Ui:300V; Uimp:2.5kV; Ith:6A; AC-12: Ue/Ie:AC:125V/6A, 250V/6A; AC-13: Ue/Ie:AC:125V/6A, 250V/6A;  
AC-14: Ue/Ie:AC:125V/6A, 250V/5A; AC-15: Ue/Ie:AC:125V/5A, 250V/4A; DC-12: Ue/Ie:DC:110V/0.5A, 250V/0.3A;  
DC-14: Ue/Ie:DC:110V/0.05A, 250V/0.03A

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T14048.5-2017

**TYPE OF CERTIFICATION SCHEMES**

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Aug.14,2020

Valid until: Jul.13,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President: \_\_\_\_\_

陆梅

Lu Mei



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China  
<http://www.cqc.com.cn>

C 0353258