Data Sheet | Item Number: 207-1331

Gelbox; Branch; for cables; with gel; 221, 2x73 Series; max. 4 mm² connectors; without splicing connectors; Size 1; gray

Color: gray

Note on Packaging Unit (PU) and Subpackaging Unit (SPU):
If you order a full PU, you will receive our eco-friendly, sustainable cardboard blisters packed in a shelf-ready box.
If you order a quantity smaller than a full PU, you will receive the eco-friendly, sustainable cardboard blisters without a shelf-ready box.

Please refer to the system description for the splicing connectors that can be used.

Your benefits:

- Easy, fast and safe to use
- Can be used immediately and accessed again later
- Silicon-free
- Label-free
- Suitable for indefinite storage
- The complete system consisting of WAGO's gelboxes and splicing connectors has been VDE-tested and IPX8-certified.

Connection data

Connection 1

Actuation type	Locking system

Physical data

Width	33.6 mm / 1.323 inches
Height	17.8 mm / 0.701 inches
Depth	32 mm / 1.26 inches

Mechanical Data

Mounting type	Flying leads

Material Data

Note (material data)	Information on material specifications can be found here
Color	gray
Housing material	Polypropylene
Fire load	0 MJ
Weight	12 g

Environmental requirements

Ambient temperature (operation)	-55 … +85 °C
Surrounding air temperature (storage)	0 … +40 °C

Commercial data

ETIM 8.0	EC001170
ETIM 7.0	EC001170
PU (SPU)	48 (4) pcs
Country of origin	DE
GTIN	4055143997799
Customs tariff number	85389099990

Approvals / Certificates

WAGO

General approvals

Approval	Standard	Certificate Name
VDE VDE Prüf- und Zertifizie- rungsinstitut	EN 60998	400051938

Downloads

Environmental Product Compliance

Compliance Search	
Environmental Product Compliance 207-1331	↓

Documentation

System Description				Bid Text			
System Description 207 Series Gel boxes	pdf 1156.45 KB	↓		207-1331	xml 3.58 KB	↓	
System Description 207 Series Gel boxes	pdf 1191.37 KB	↓		207-1331	docx 20.35 KB	↓	

## CAD/CAE-Data

CAD data		CAE data	
2D/3D Models 207-1331	↓	ZUKEN Portal 207-1331	↓

Installation Notes

Installation

Open the Gelbox at the side latches.

Place the wired connector in the Gelbox.

Place the wired connector in the Gelbox.

Close the Gelbox.

Close latch securely.

Re-accessible:
Open the Gelbox.Remove the gel.Rewire with new components.

Lift the flap and pull the cover perforation forward.

Press in the perforation on the sides.

Tear off the cover from the perforation.

As a counter display: Bend the rear flap at the fold, straighten it and fix it in the cardboard cut-out

If the flap is not required, tear off from the perforation.

Subject to changes. Please also observe the further product documentation!

Current addresses can be found at:: www.wago.com