

# DATASHEET

**Hamilton**<sup>®</sup>

making connections beautifully

**Code:** HM2050

## Verve || Double Pole Switches

### Product Image



### Wiring



### Dimensions

**Hamilton**<sup>®</sup>

**Dimensional  
drawing is not  
available**

<b>Insert Type</b>	1 gang 50A Double Pole Rocker
<b>Insert Colour</b>	White/White
<b>EAN13 Barcode</b>	5052750550309
<b>Commodity Code</b>	85363030
<b>Luckins TSI</b>	434148266
<b>Dimensions(Nominal)</b>	Single: Height = 86.7mm Width = 86.7mm Depth = 10.0mm
<b>Weight</b>	130 GR
<b>Fixing Hole Centres</b>	Box Fixing = 60.3mm Grid Fixing = N/A
<b>Switched Poles</b>	Double
<b>Current Rating</b>	50 Amp
<b>Voltage</b>	220/250V AC
<b>Maximum Load</b>	50 Amp
<b>Contact Gap Minimum</b>	3mm
<b>Terminal Capacity 1</b>	3x6mm <sup>2</sup>
<b>Terminal Capacity 2</b>	1x10mm <sup>2</sup>
<b>Terminal Capacity 3</b>	1x16mm <sup>2</sup>
<b>Earth Terminal Capacity 1</b>	3x6mm <sup>2</sup>
<b>Earth Terminal Capacity 2</b>	1 x 10mm <sup>2</sup>
<b>Earth Terminal Capacity 3</b>	1 x 16mm <sup>2</sup>
<b>Product Class 1</b>	Must be earthed
<b>Ambient Operating Temperature</b>	-5° to +40°C
<b>Recommended Location</b>	Internal Use Only
<b>Maximum Installation Altitude</b>	2000m
<b>Standard/Approval</b>	BS EN 60669-1

R Hamilton & Co Ltd, Unit 10 Carrick Business Centre,  
4-5 Bonville Road, Brislington, Bristol, BS4 5NZ

**T:** +44 (0)1747 860088

**E:** [info@hamilton-litestat.com](mailto:info@hamilton-litestat.com) | **W:** [www.hamilton-litestat.com](http://www.hamilton-litestat.com)

All accessories are manufactured under an accredited BS EN ISO 9001:2015 Quality Management System. It is the policy of the company to improve products as part of our development programme. Therefore, we reserve the right to alter designs and dimensions without prior notice. Illustrations and diagrams are reproduced within the limitations of reproduction and printing process and are not binding. Due to manufacturing processes we cannot guarantee an exact colour match and shadings of certain finishes. This datasheet was generated on 5/9/2023 1:58:24 PM E&OE