

LOADLIMITER 63

IMPORTANT:
THESE ITEMS TO BE PURCHASED WHEN USING THIS HARNESS (DBXWP125)


125 A

SHEET 1 OF 1

VERTICAL STACKED TWO METER ARRANGEMENT

TABLE 1

	QTY	CAT NUMBER	DESCRIPTION
	1	DBX04-24R	4 to 24 WAY DB1
	1	DBX04-16R	4 to 16 WAY DB2
	1	DBMSB	METER ENCLOSURE
	1	DBXJK	JOINING KIT VERTICAL
EITHER	1	DBXW16	METER WIRING HARNESS UPTO 16 WAY DB1
	1	DBXW24	METER WIRING HARNESS 20 to 24 WAY DB1
	1	DBXWP125	POWER WIRING HARNESS (SUPPLIED)
EITHER	As Req'd	INT-1630-M-5-M-100	MULTIFUNCTION METER
	As Req'd	CI-CI3-01	MULTIFUNCTION METER
	As Req'd	CI-CI1-01	KILOWATT HOUR METER
	1	M3N1-35-100/5 or M3N1-35-125/5	CURRENT TRANSFORMER 100A or 125A
	1	DBXW16T	METER WIRING HARNESS UPTO 16 WAY DB2
	*	AV3125, 3100, 4125, 4100	SWITCH DISCONNECTOR
	*	DBXD0	DIRECT CONNECTION TERMINAL KIT
	*	DBXCKR	DEVICE MOUNTING KIT




* SEE TABLE 3

HORIZONTAL STACKED TWO METER ARRANGEMENT

TABLE 2

	QTY	CAT NUMBER	DESCRIPTION
	1	DBX04-24R	4 to 24 WAY DB1
	1	DBX04-16R	4 to 16 WAY DB2
	2	DBMSB	METER ENCLOSURE
EITHER	1 or 2	DBXW16	METER WIRING HARNESS UPTO 16 WAY
	1 or 2	DBXW24	METER WIRING HARNESS 20 to 24 WAY
	1	DBXWP125	POWER WIRING HARNESS (SUPPLIED)
EITHER	As Req'd	INT-1630-M-5-M-100	MULTIFUNCTION METER
	As Req'd	CI-CI3-01	MULTIFUNCTION METER
	As Req'd	CI-CI1-01	KILOWATT HOUR METER
	1	M3N1-35-100/5 or M3N1-35-125/5	CURRENT TRANSFORMER 100A
	*	AV3125, 3100, 4125, 4100	SWITCH DISCONNECTOR
	*	DBXD0	DIRECT CONNECTION TERMINAL KIT
	*	DBXCKR	DEVICE MOUNTING KIT



* SEE TABLE 3

TABLE 3

	AV (SWITCH DISCONNECTOR)	DBXD0	DBXCKR
MAIN INCOMER ONLY	1	5	0
MAIN & DB1 INCOMER	2	4	0
MAIN, DB1 & DB2 INCOMER	3	3	1