# Eaton 229748

# Catalog Number: 229748

Eaton Moeller® series FAK Palm switch, 1N/O+1N/C, emergency switching off, surface mounting

# General specifications

**Product Name** 

Eaton Moeller® series FAK Palm switch 229748

Model Code

FAK-R/V/KC11/IY

Product Length/Depth

100 mm

**Product Width** 

85 mm

Certifications

IEC/EN 60947-5

CSA Class No.: 3211-03

**VDE 0660** 

IEC/EN 60947-5-5

UL 508

UL Category Control No.: NKCR

UL File No.: E29184

CSA

CSA File No.: 012528 CSA-C22.2 No. 14-05 CSA-C22.2 No. 94-91

UL



Catalog Number

EAN

4015082297480

**Product Height** 

85 mm

**Product Weight** 

0.32 kg

**Catalog Notes** 

Contacts with safety function, by positive

opening to IEC/EN 60947-5-1





### Features & Functions

Enclosure color

Yellow

Black

**Features** 

Emergency stop pushbutton

Tamper-proof (according to ISO 13850/EN 418)

Unlocking method

Pull-release

#### General

Connection to SmartWire-DT

No

Degree of protection

IP67/IP69K

NEMA 4X

Lifespan, mechanical

100,000 Operations

Mounting position

As required

Opening diameter

0 mm

Operating frequency

600 Operations/h

**Product category** 

Foot and palm switches

Shock resistance

Mechanical, According to IEC/EN 60068-2-27

15 g, Mechanical, According to IEC/EN 60068-2-27, Half-

Sinusoidal shock 11 ms

Туре

Complete device

**Actuator** 

60 N

Red

Actuating force

Actuator color

## Climatic environmental conditions

Ambient operating temperature - min

-25 °C

Ambient operating temperature - max

55 °C

Climatic proofing

Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 Actuator function

Switching function latching

Maintained

#### Contacts

Number of contacts (normally closed contacts)

1

Number of contacts (normally open contacts)

### Design verification

Equipment heat dissipation, current-dependent Pvid

0 W

Heat dissipation capacity Pdiss

0 W

1

Heat dissipation per pole, current-dependent Pvid

0.11 W

Rated operational current for specified heat dissipation (In)

6 A

Static heat dissipation, non-current-dependent Pvs

0 W

#### 10.2.2 Corrosion resistance

Meets the product standard's requirements.

#### 10.2.3.1 Verification of thermal stability of enclosures

Meets the product standard's requirements.

# 10.2.3.2 Verification of resistance of insulating materials to normal heat

Meets the product standard's requirements.

# 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects

Meets the product standard's requirements.

#### 10.2.4 Resistance to ultra-violet (UV) radiation

Please enquire

#### 10.2.5 Lifting

Does not apply, since the entire switchgear needs to be evaluated.

#### 10.2.6 Mechanical impact

Does not apply, since the entire switchgear needs to be evaluated.

#### 10.2.7 Inscriptions

Meets the product standard's requirements.

#### 10.3 Degree of protection of assemblies

Does not apply, since the entire switchgear needs to be evaluated.

### 10.4 Clearances and creepage distances

Meets the product standard's requirements.

#### 10.5 Protection against electric shock

Does not apply, since the entire switchgear needs to be evaluated.

#### 10.6 Incorporation of switching devices and components

Does not apply, since the entire switchgear needs to be evaluated.

#### 10.7 Internal electrical circuits and connections

Is the panel builder's responsibility.

#### 10.8 Connections for external conductors

Is the panel builder's responsibility.

#### 10.9.2 Power-frequency electric strength

Is the panel builder's responsibility.

#### 10.9.3 Impulse withstand voltage

Is the panel builder's responsibility.

#### 10.9.4 Testing of enclosures made of insulating material

Is the panel builder's responsibility.

#### 10.10 Temperature rise

The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.

#### 10.11 Short-circuit rating

Is the panel builder's responsibility. The specifications for the switchgear must be observed.

#### 10.12 Electromagnetic compatibility

Is the panel builder's responsibility. The specifications for the switchgear must be observed.

#### 10.13 Mechanical function

The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

#### Resources

#### **Brochures**

RMQ Titan - brochure

#### Catalogues

Product Range Catalog Command and Indication Control Circuit Devices, Signal Towers

#### Certification reports

DA-DC-00004139.pdf

DA-DC-00004178.pdf

#### **Drawings**

eaton-operating-switch-fak-palm-switch-dimensions.eps

eaton-operating-button-symbol-005.eps

eaton-operating-button-symbol-008.eps

eaton-operating-switch-fak-palm-switch-3d-drawing-002.eps

eaton-operating-button-symbol-006.eps

eaton-general-totally-insulated-t0-main-switch-symbol.eps

eaton-general-fak-palm-switch-symbol.eps

eaton-operating-m22-symbol.eps

#### eCAD model

ETN.FAK-R\_V\_KC11\_IY

#### Installation instructions

IL04716006Z

IL04716017Z

#### mCAD model

fak

fak.stp

#### Wiring diagrams

eaton-operating-contact-m22-housing-wiring-diagram.eps



Eaton Corporation plc Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2023 Eaton. All rights reserved.

Eaton is a registered trademark.

All other trademarks are property of their respective owners.



Eaton.com/socialmedia