

45A & 50A DP CONTROL SWITCH



Technical Specification

- Orange rocker on moulded version
- Dual screw terminal
- IP rating is IP4X (unless stated)
- All products are tested to 250 Volt

British Standards

- CRABTREE 45A & 50A DP Control Switches are all type tested to BS 60669-1
- Switches for Household and similar fixed-electrical installation

Terminal Capacities

Size of cable	6.0mm ²	10.0mm ²	16.0mm ²
Qty of cable	2	1	1

A Point of Testing

When installations incorporating electronic devices of the semi-conductor type are being tested, care must normally be taken to ensure that they are not subjected to the output voltage of an insulation tester. However, dimmer switches complying with BS 5518 will not be damaged by the application of a normal 500V insulation resistance test. In all other cases where electronic items are fitted, they should be disconnected whilst the insulation of the installation is tested. A notice, drawing attention to the fact that electronic devices are incorporated in the installation, should always be affixed at the intake position. This also applies to any neon indicators fitted.

45A COOKER CONTROL UNIT



Technical Specification

- Same plate size as standard twin socket
- Two earth terminals as standard
- Separate Double pole switching for both cooker and socket outlet
- IP rating is IP2X (unless stated)
- All products are tested to 250 Volt

British Standards

- Crabtree 45A Cooker Control unit are all type tested to BS 4177 & BS 1363-2
- BS 4177 Specification for cooker control units
- BS 1363-2 13A plugs, socket-outlets, adaptors and connection units
- Specification for 13A switched and unswitched socket-outlets

Terminal Capacities

Size of cable	6.0mm ²	10.0mm ²	16.0mm ²
Qty of cable	2	1	1

A Point of Testing

When installations incorporating electronic devices of the semi-conductor type are being tested, care must normally be taken to ensure that they are not subjected to the output voltage of an insulation tester. However, dimmer switches complying with BS 5518 will not be damaged by the application of a normal 500V insulation resistance test. In all other cases where electronic items are fitted, they should be disconnected whilst the insulation of the installation is tested. A notice, drawing attention to the fact that electronic devices are incorporated in the installation, should always be affixed at the intake position. This also applies to any neon indicators fitted.