



LDLEM3 - SPACING CALCULATION



	Open (Anti-Panic) Area 0.5 Lux minimum in central core				Escape Route (2m Wide) 1 Lux minimum along centre line			
Mounting Height	Transverse to Wall	Transverse to Transverse	Axial to Wall	Axial to Axial	Transverse to Wall	Transverse to Transverse	Axial to Wall	Axial to Axial
2.5m	3.4m	8.4m	3.4m	8.4m	2.9m	7.8m	2.9m	7.8m
3m	3.5m	8.4m	3.5m	8.4m	2.9m	8.2m	2.9m	8.2m
3.5m	3.8m	8.4m	3.8m	8.4m	2.8m	8.4m	2.8m	8.4m
4m	3.9m	9m	3.9m	9m	2.7m	8.6m	2.7m	8.6m