
Lighting connector; push-button on lighting side; Lighting side: for all conductor types; Inst. side: for solid conductors; 224 Series; max. 2.5 mm²; Surrounding air temperature: max 60°C; 2,50 mm²; gray



https://www.wago.com/224-101





Color: ■ gray Dimensions in mm

Notes	
Safety information	in grounded power lines

Electrical data			
Ratings per		EN 60664	
Overvoltage category	III	III	II
Pollution degree	3	2	2
Nominal voltage	-	-	400 V
Rated surge voltage	-	-	4 kV
Rated current	-	_	24 A

	2	Connection 1	
otal number of potentials 1	Connection type 1	Installation side	
		Connection technolo	pgy PUSH WIRE®
		Number of connection	on points 1
		Actuation type	Push-in
		Connectable conduc	tor materials Copper Aluminum

https://www.wago.com/224-101



### Connection 1

Connectable conductor materials (note)

Terminating Aluminum Conductors WAGO spring clamp terminal blocks are suitable for solid aluminum conductors up to 4 mm²/12 AWG if WAGO "Alu-Plus" Contact Paste <a href="https://www.wago.com/249-130">https://www.wago.com/249-130">249-130</a> is used for termination.

"Alu-Plus" Contact Paste Advantages:

- Automatically destroys the oxide film during clamping.
- Prevents fresh oxidation at the clamping point.
- Prevents electrolytic corrosion between aluminum and copper conductors (in the same terminal block).
- Provides long-term protection against corrosion.

Using terminal blocks with CAGE CLAMP® Spring Pressure Connection Technology, aluminum conductors must first be cleaned with a blade and then immediately be inserted into the clamping units filled with "Alu-Plus" Contact Paste.

For spring clamp connections with PUSH WIRE® connection technology, **WAGO recommends that the aluminum conductor first be cleaned** and then immediately inserted into the clamping unit filled with "Alu-Plus" contact paste.

It is also possible to apply WAGO "Alu-Plus" **additionally** on the whole surface of the aluminum conductor before termination.

Please note that the nominal currents must be adapted to the reduced conductivity of the aluminum conductors:: 2.5 mm² = 16 A 4 mm² = 22 A

Solid conductor	1 2.5 mm² / 14 12 AWG
Strip length	9 11 mm / 0.35 0.43 inches
Wiring direction	Side-entry wiring

Connection 2	
Connection type 2	Lighting side
Connection technology 2	CAGE CLAMP®
Number of connection points 2	1
Solid conductor 2	0.5 2.5 mm² / 20 16 AWG
Fine-stranded conductor 2	0.5 2.5 mm <sup>2</sup> / 20 16 AWG

Physical data	
Width	8 mm / 0.315 inches
Height	15.5 mm / 0.61 inches
Depth	20.4 mm / 0.803 inches

Material data	
Note (material data)	<a href="https://www.wago.com/us/material-specifications">Information on material specifications can be found here</a>
Color	gray
Fire load	0.04 MJ
Weight	1.8 g

https://www.wago.com/224-101



#### **Environmental requirements** Ambient temperature (operation) +60 °C 105 °C Continuous operating temperature

Commercial data	
eCl@ss 10.0	27-14-11-03
eCl@ss 9.0	27-14-11-03
ETIM 8.0	EC000447
ETIM 7.0	EC000447
PU (SPU)	1000 (100) pcs
Packaging type	Box
Country of origin	CH
GTIN	4044918583817
Customs tariff number	85369010000

### **Environmental Product Compliance**

RoHS Compliance Status Compliant, No Exemption

### Approvals / Certificates

### General approvals











Approval	Standard	Certificate Name
CSA DEKRA Certification B.V.	C22.2	1053495
UL UL International Germany GmbH	UL 486C	E69654
UL UL International Germany GmbH	EN 60998	CCA-2617-A1
UL UL International Germany GmbH	EN 60998	D-05895-A1 (EN60998-1 EN60998-2-2)
VDE VDE Prüf- und Zertifizie- rungsinstitut	EN 60998	40022792

### Declarations of conformity and manufacturer's declarations

Approval	Standard	Certificate Name
EU-Declaration of Confor- mity WAGO GmbH & Co. KG	-	-
UK-Declaration of Conformity WAGO GmbH & Co. KG	-	-

### Approvals for marine applications









VERITAS		
Approval	Standard	Certificate Name
ABS American Bureau of Ship- ping	-	18-HG1755093-PDA
BV Bureau Veritas S.A.	EN 60998	11914/D0 BV
DNV GL Det Norske Veritas, Ger- manischer Lloyd	EN 60998	TAE000015T
LR Lloyds Register	EN 60998	LR22207029TA


https://www.wago.com/224-101




## Downloads Environmental Product Compliance Compliance Search

### Environmental Product Compliance 224-101

# Documentation Bid Text 224-101 xml 19.02.2019 3.44 KB 224-101 docx 21.02.2019 15.52 KB





Item No.: 249-130
Syringe; Contents: 20 ml Alu-Plus contact paste

### **Installation Notes**

### **Conductor termination**





Lighting Connectors (2.5 mm²), 224 Series

Strip conductor to 9  $\dots$  11 mm (0.35  $\dots$  0.43 inch).

https://www.wago.com/224-101



### **Conductor termination**





To connect: Press button fully, insert stripped conductor into square entry and



To remove: Press button and withdraw conductor.

### Conductor termination





To connect: Insert stripped solid conductor into circular entry and push until it hits the backstop.



To remove: Hold conductor to be removed and twist alternately left and right while slightly pulling the connector.

### Testing



Testing via separate test ports.



Connecting solid conductors with finestranded conductors via lighting connectors (224-101).



 $\label{thm:condition} \textbf{Subject to changes. Please also observe the further product documentation!}$