SIEMENS

Data sheet 6EP1935-6ME21



SITOP Battery module/24V/7AH

SITOP battery module 24 V/7 Ah with maintenance free sealed lead batteries for SITOP DC UPS module 6 A, 15 A and 40 A *Ex approval no longer available*

electrical data				
end-of-charge voltage at DC				
• at -10 °C recommended	29 V			
• at 0 °C recommended	28.4 V			
• at 10 °C recommended	27.8 V			
• at 20 °C recommended	27.3 V			
• at 30 °C recommended	26.8 V			
• at 40 °C recommended	26.6 V			
• at 50 °C recommended	26.3 V			
output				
battery capacity	7 A·h			
output current in buffering mode maximum	30 A			
peak current	30 A			
charging current maximum	1.75 A			
output voltage at DC rated value	24 V			
interfaces				
communication function	No			
protection and monitoring				
design of short-circuit protection	Battery fuse 20 A/32 V (solid-state circuitry blade-type fuse + support)			
design of the overload protection	Valve control			
safety				
operating resource protection class	Class III			
protection class IP	IP00			
standards, specifications, approvals				
certificate of suitability				
CE marking	Yes			
 UL approval 	Yes; cURus-Recognized (UL 1778, CSA C22.2 No. 107.1), File E219627			
EAC approval	Yes			
standards, specifications, approvals hazardous environments				
certificate of suitability				
• ATEX	No			
• cCSAus, Class 1, Division 2	No			
standards, specifications, approvals marine classification				
shipbuilding approval	Yes			
Marine classification association				
 American Bureau of Shipping Europe Ltd. (ABS) 	Yes			
 Det Norske Veritas (DNV) 	Yes			
standards, specifications, approvals Environmental Product Declaration				
Environmental Product Declaration	Yes			
Global Warming Potential [CO2 eq]				

	00.01	
• total	23.3 kg	
during manufacturing	12.9 kg	
during operation	8.2 kg	
after end of life	0.78 kg	
ambient conditions		
ambient condition	For storage, mounting and operation of lead-acid batteries, the relevant DIN/VDE regulations or country-specific regulations (e.g. VDE 0510 Part 2/EN 50272-2) must be observed. You must ensure that the battery site is sufficiently ventilated. Possible sources of ignition must be at least 50 cm away.	
ambient temperature		
 during operation 	-15 +50 °C	
 during transport 	-20 +50 °C	
during storage	-20 +50 °C	
relative temporary capacity loss at 20 °C in a month typical	3 %	
service life of energy storage		
• typical	capacity falls to 80 % of original capacity (according to EUROBAT)	
 at 20 °C typical 	4 a	
 at 30 °C typical 	2 a	
• at 40 °C typical	1 a	
• at 50 °C typical	0.5 a	
note	Along with the storage and operating temperature, other factors such as the duration of the storage period and the charge status during storage have a decisive influence on the possible useful life. Batteries should therefore be stored as briefly as possible, always fully charged, and within the temperature range 0 to +20 °C.	
connection method		
type of electrical connection	spring-loaded terminals	
• for power supply unit	1 screw terminal each for 0.08 4 mm² for + BAT and - BAT	
mechanical data		
width × height × depth of the enclosure	186 × 168 × 121 mm	
installation width × mounting height	206 × 188 mm	
fastening method	can be screwed onto flat surface (keyhole mounting for hooking in to M4 screws)	
 standard rail mounting 	No	
 S7 rail mounting 	No	
wall mounting	Yes	
net weight	6 kg	
number of cells	12	
accessories		
product component included	Accessories pack with solid-state circuitry fuse 20 A and 30 A	
further information internet links		
internet link		
• to website: Industry Mall	https://mall.industry.siemens.com	
 to web page: selection aid TIA Selection Tool 	https://siemens.com/tst	
• to website: Industrial communication	http://www.siemens.com/simatic-net	
to website: CAx-Download-Manager	http://www.siemens.com/cax	
additional information		
other information	Specifications at rated input voltage and ambient temperature +25 $^{\circ}\text{C}$ (unless otherwise specified)	
security information		
security information	Siemens provides products and solutions with industrial cybersecurity functions that support the secure operation of plants, systems, machines and networks. In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic, state-of-the-art industrial cybersecurity concept. Siemens' products and solutions constitute one element of such a concept. Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place. For additional information on industrial cybersecurity measures that may be implemented, please visit www.siemens.com/cybersecurity-industry. Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongly recommends that product updates are applied as soon as they are available and that the latest product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats. To stay informed about product updates,	

subscribe to the Siemens Industrial Cybersecurity RSS Feed under https://www.siemens.com/cert. (V4.7)

Classifications

	Version	Classification
eClass	12	27-05-04-03
eClass	9.1	27-05-04-03
eClass	9	27-05-04-03
eClass	8	27-05-04-03
eClass	7.1	27-05-04-03
eClass	6	27-05-04-90
ETIM	9	EC000356
ETIM	8	EC000356
ETIM	7	EC000356
UNSPSC	15	26-11-17-01

Approvals Certificates

General Product Approval



Manufacturer Declara-<u>tion</u>

Declaration of Conformity



Miscellaneous

For use in hazardous locations

Marine / Shipping

other

Dangerous Good









Miscellaneous

Dangerous Goods Information

Dangerous Good

Environment

Transport Information

Environmental Confirmations



last modified:

3/25/2024

