

# Product Environmental Profile

**Standard shunt trip release MX, ComPacT NSXm, 250VDC,  
220/240VAC 50Hz, 208/240VAC 60Hz, 277VAC 60Hz**




## General information

Reference product	Standard shunt trip release MX, ComPacT NSXm, 250VDC, 220/240VAC 50Hz, 208/240VAC 60Hz, 277VAC 60Hz
Description of the product	The main purpose of MX NSXm is used for emergency off or failsafe remote tripping applications on Compact NSXm and PowerPact B devices. The MX shunt trip instantaneously opens the circuit breaker when its supply voltage rises above 70% of its rated voltage.
Functional unit	To trip the circuit breaker when the control voltage rises above 70% of its rated voltage. Impulse type must be superior or equal to 20ms or maintained. This function is provided for 10 years. It complies with IEC 60947-2 standard.

## Constituent materials

Reference product mass	78 g including the product, its packaging and additional elements and accessories
------------------------	---



Plastics	18.2%
Metals	23.6%
Others	58.2%

## Substance assessment

Details of ROHS and REACH substances information are available on the Schneider-Electric Green Premium website  
<https://www.se.com/ww/en/work/support/green-premium/>

## Additional environmental information

End Of Life	Recyclability potential:	33%	Recyclability rate has been calculated based on REECYLAB tool developed by Ecosystem, for components/materials not covered by the tool, data from the "ECO'DEEE recyclability and recoverability calculation method" was taken. If no data was found a conservative assumption was used (0% recyclability).
-------------	--------------------------	-----	---

## Environmental impacts

Reference service life time	10 years		
Product category	Other equipments - Active product		
Installation elements	No special components needed during the installation phase. The disposal of the packaging material is accounted during this phase (Including transport to disposal).		
Use scenario	As per the PSR, The product is in active mode 0.000159% and in off mode 99.999841% of the time with a power use of 6W for 10 years		
Technological representativeness	The Modules of Technologies such as material production, manufacturing process and transport technology used in this PEP analysis (LCA-EIME in this case) are Similar and representative of the actual type of technologies used to make the product in production.		
Geographical representativeness	Europe		
Energy model used	[A1 - A3]	[A5]	[B6]
	Electricity Mix; Production mix; Low voltage; FR	Electricity Mix; Production mix; Low voltage; UE-27	Electricity Mix; Production mix; Low voltage; UE-27
			[C1 - C4]
			Electricity Mix; Production mix; Low voltage; UE-27

Detailed results, including all the optional indicators mentioned in PCRed4, and the split of the Use Phase (B1 to B7), are available in the LCA report and on demand in a digital format - Country Customer Care Center - <http://www.schneider-electric.com/contact>

Mandatory Indicators			Standard shunt trip release MX, ComPacT NSXm, 250VDC, 220/240VAC 50Hz, 208/240VAC 60Hz, 277VAC 60Hz - LV426844					
Impact indicators	Unit	Total	Manufacturing	Distribution	Installation	Use	End of Life	Loads and Benefits
			[A1 - A3]	[A4]	[A5]	[B1 - B7]	[C1 - C4]	[D]
Contribution to climate change	kg CO2 eq	2.19E+00	2.02E+00	1.02E-02	4.20E-02	3.43E-04	1.19E-01	-1.07E-01
Contribution to climate change-fossil	kg CO2 eq	2.17E+00	2.00E+00	1.02E-02	4.01E-02	3.42E-04	1.17E-01	-1.05E-01
Contribution to climate change-biogenic	kg CO2 eq	1.87E-02	1.46E-02	0*	1.87E-03	0*	2.19E-03	-1.45E-03
Contribution to climate change-land use and land use change	kg CO2 eq	8.89E-09	6.89E-09	0*	0*	0*	1.99E-09	0.00E+00
Contribution to ozone depletion	kg CFC-11 eq	2.55E-07	2.49E-07	0*	2.78E-09	0*	2.93E-09	-1.26E-08
Contribution to acidification	mol H+ eq	1.54E-02	1.39E-02	6.56E-05	1.67E-04	1.95E-06	1.23E-03	-6.71E-04
Contribution to eutrophication, freshwater	kg (PO4) <sup>3-</sup> eq	1.10E-05	5.73E-06	3.82E-09	3.03E-07	0*	4.98E-06	-4.63E-07
Contribution to eutrophication marine	kg N eq	2.39E-03	1.53E-03	3.08E-05	4.41E-05	0*	7.86E-04	-8.41E-05
Contribution to eutrophication, terrestrial	mol N eq	1.77E-02	1.63E-02	3.38E-04	3.33E-04	3.34E-06	7.06E-04	-8.39E-04
Contribution to photochemical ozone formation - human health	kg COVNM eq	5.99E-03	5.54E-03	8.54E-05	8.89E-05	7.13E-07	2.70E-04	-2.69E-04
Contribution to resource use, minerals and metals	kg Sb eq	9.80E-05	9.79E-05	0*	0*	0*	1.22E-07	-2.17E-05
Contribution to resource use, fossils	MJ	3.06E+01	2.59E+01	1.42E-01	4.37E-01	8.73E-03	4.07E+00	-1.88E+00
Contribution to water use	m3 eq	1.41E+01	5.38E-01	0*	1.79E-02	0*	1.35E+01	-5.47E-02

Additional indicators for the French regulation are available as well

Inventory flows Indicators			Standard shunt trip release MX, ComPacT NSXm, 250VDC, 220/240VAC 50Hz, 208/240VAC 60Hz, 277VAC 60Hz - LV426844					
Inventory flows	Unit	Total	Manufact.	Distribution	Installation	Use	End of Life	Loads and Benefits
			[A1 - A3]	[A4]	[A5]	[B1 - B7]	[C1 - C4]	[D]
Contribution to use of renewable primary energy excluding renewable primary energy used as raw material	MJ	7.39E-01	6.44E-01	1.90E-04	3.13E-02	1.68E-03	6.18E-02	1.56E-01
Contribution to use of renewable primary energy resources used as raw material	MJ	2.86E-01	2.86E-01	0*	0*	0*	0*	-2.85E-01
Contribution to total use of renewable primary energy resources	MJ	1.03E+00	9.31E-01	1.90E-04	3.13E-02	1.68E-03	6.18E-02	-1.29E-01
Contribution to use of non renewable primary energy excluding non renewable primary energy used as raw material	MJ	2.99E+01	2.53E+01	1.42E-01	4.37E-01	8.73E-03	4.07E+00	-1.88E+00
Contribution to use of non renewable primary energy resources used as raw material	MJ	6.74E-01	6.74E-01	0*	0*	0*	0*	0.00E+00
Contribution to total use of non-renewable primary energy resources	MJ	3.06E+01	2.59E+01	1.42E-01	4.37E-01	8.73E-03	4.07E+00	-1.88E+00
Contribution to use of secondary material	kg	8.12E-03	8.12E-03	0*	0*	0*	0*	0.00E+00
Contribution to use of renewable secondary fuels	MJ	0.00E+00	0*	0*	0*	0*	0*	0.00E+00
Contribution to use of non renewable secondary fuels	MJ	0.00E+00	0*	0*	0*	0*	0*	0.00E+00
Contribution to net use of freshwater	m³	3.67E-01	1.25E-02	0*	4.17E-04	0*	3.54E-01	-1.27E-03
Contribution to hazardous waste disposed	kg	2.59E+00	2.54E+00	0*	4.96E-04	0*	5.49E-02	-1.72E+00
Contribution to non hazardous waste disposed	kg	7.85E-01	6.34E-01	3.58E-04	1.37E-01	0*	1.44E-02	-4.66E-01
Contribution to radioactive waste disposed	kg	3.06E-04	2.86E-04	2.55E-07	1.83E-05	0*	8.94E-07	-4.55E-05
Contribution to components for reuse	kg	0.00E+00	0*	0*	0*	0*	0*	0.00E+00
Contribution to materials for recycling	kg	4.16E-02	5.18E-04	0*	2.31E-02	0*	1.80E-02	0.00E+00
Contribution to materials for energy recovery	kg	0.00E+00	0*	0*	0*	0*	0*	0.00E+00
Contribution to exported energy	MJ	0.00E+00	0*	0*	0*	0*	0*	0.00E+00
Contribution to biogenic carbon content of the product	kg de C	0.00E+00	0*	0*	0*	0*	0*	0.00E+00
Contribution to biogenic carbon content of the associated packaging	kg de C	0.00E+00	0*	0*	0*	0*	0*	0.00E+00

\* represents less than 0.01% of the total life cycle of the reference flow

Life cycle assessment performed with EIME version v5.9.4, database version 2022-01 in compliance with ISO14044.

Detailed results, including all the optional indicators mentioned in PCRed4, and the split of the Use Phase (B1 to B7), are available in the LCA report and on demand in a digital format - Country Customer Care Center - <http://www.schneider-electric.com/contact>

Please note that the values given above are only valid within the context specified and cannot be used directly to draw up the environmental assessment of an installation.

Registration number :	SCHN-01134-V01.01-EN	Drafting rules	PEP-PCR-ed4-2021 09 06
Verifier accreditation N°	VH08	Supplemented by	PSR-0005-ed2-2016 03 29
Date of issue	12/2023	Information and reference documents	<a href="http://www.pep-ecopassport.org">www.pep-ecopassport.org</a>
		Validity period	5 years
Independent verification of the declaration and data, in compliance with ISO 14025 : 2010			
Internal                      External      X			
The PCR review was conducted by a panel of experts chaired by Julie ORGELET (DDemain)			
PEP are compliant with XP C08-100-1 :2016 or EN 50693:2019			
The elements of the present PEP cannot be compared with elements from another program.			
Document in compliance with ISO 14025 : 2010 « Environmental labels and declarations. Type III environmental declarations »			



Schneider Electric Industries SAS  
Country Customer Care Center  
<http://www.se.com/contact>  
35, rue Joseph Monier  
CS 30323  
F- 92500 Rueil Malmaison Cedex  
RCS Nanterre 954 503 439  
Capital social 928 298 512 €