



Product Service

CERTIFICATE

No. B 044254 0034 Rev. 00

Holder of Certificate: **ABB Stotz-Kontakt GmbH**

Eppelheimer Str. 82
69123 Heidelberg
GERMANY

Certification Mark:



Product:

**Power supplies
(DIN RAIL MOUNTABLE POWER SUPPLIES)**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 6121020054201

Valid until: 2024-07-30

Date, 2020-09-24

(Owen Hsu)

CERTIFICATE

No. B 044254 0034 Rev. 00

Model(s): CP-E 24/20.0, CP-E 48/10.0

Brand Name: ABB



Parameters:

Rated inputs:	See below
Rated outputs:	See below
Protection class:	I
Max. ambient temperature:	50 °C

Remarks:

1. When installing, all requirements of below mentioned test standards must be fulfilled.
2. The equipment is evaluated for operating in altitude up to 5,000 m above the sea level.

The ratings & model description of the models are as below:

Model-#	Input Rating	Output Rating
CP-E 24/20.0	115/230 Vac, 47-63 Hz, 7/3.5 A; 115/220/230 Vac, 47-63 Hz, 7/3.5/3.5 A	24 Vdc, 20 A or 24 Vdc, 480 W or 24 Vdc, 20 A, 480 W
CP-E 48/10.0		48 Vdc, 10 A or 48 Vdc, 480 W or 48 Vdc, 10 A, 480 W

Tested according to: EN 62368-1:2014/A11:2017

Production Facility(ies): 004727, 004978