## SIEMENS

## Data sheet

## 6EP3447-7SB00-3AX0



SITOP PSU6200/3AC/48VDC/20A

SITOP PSU6200 48 V/20 A stabilized power supply input: 400 - 500 V AC output: 48 V DC/20 A with diagnostic interface

type of the power supply network3-phase AC or DCsupply voltage at AC400 V• minimum rated value500 V• initial value323 V• full-scale value576 Vinput voltage at DC450 600 Vbuffering time for rated value of the output current in the event of power failure minimum18 msoperating condition of the mains bufferingat Vin = 400 Vline frequency50/60 Hzinput voltage 400 V47 63 Hzinput voltage 500 V1.5 A• at rated input voltage 500 V1.2 Acurrent limitation of inrush current at 25 °C maximum10 A				
• minimum rated value400 V• maximum rated value500 V• initial value323 V• full-scale value576 Vinput voltage at DC450 600 Vbuffering time for rated value of the output current in the event of power failure minimum18 msoperating condition of the mains bufferingat Vin = 400 Vline frequency50/60 Hzline frequency50/60 Hzinput current • at rated input voltage 400 V1.5 A• at rated input voltage 500 V1.2 A				
<ul> <li>maximum rated value</li> <li>initial value</li> <li>full-scale value</li> <li>full-scale value</li> <li>for V</li> <li>input voltage at DC</li> <li>buffering time for rated value of the output current in the event of power failure minimum</li> <li>operating condition of the mains buffering</li> <li>at Vin = 400 V</li> <li>line frequency</li> <li>50/60 Hz</li> <li>line frequency</li> <li>at rated input voltage 400 V</li> <li>at rated input voltage 500 V</li> <li>1.5 A</li> <li>at rated input voltage 500 V</li> <li>1.2 A</li> </ul>				
• initial value323 V• full-scale value576 Vinput voltage at DC450 600 Vbuffering time for rated value of the output current in the event of power failure minimum18 msoperating condition of the mains bufferingat Vin = 400 Vline frequency50/60 Hzline frequency47 63 Hzopt current out current out at rated input voltage 400 V1.5 Aout current out rated input voltage 500 V1.2 A				
• full-scale value576 Vinput voltage at DC450 600 Vbuffering time for rated value of the output current in the event of power failure minimum18 msoperating condition of the mains bufferingat Vin = 400 Vline frequency50/60 Hzline frequency47 63 Hzinput current- at rated input voltage 400 V• at rated input voltage 500 V1.5 A• at rated input voltage 500 V1.2 A				
input voltage at DC450 600 Vbuffering time for rated value of the output current in the event of power failure minimum18 msoperating condition of the mains bufferingat Vin = 400 Vline frequency50/60 Hzline frequency47 63 Hzinput current • at rated input voltage 400 V1.5 A• at rated input voltage 500 V1.2 A				
buffering time for rated value of the output current in the event of power failure minimum       18 ms         operating condition of the mains buffering       at Vin = 400 V         line frequency       50/60 Hz         line frequency       47 63 Hz         input current       1.5 A         • at rated input voltage 400 V       1.2 A				
power failure minimum     at Vin = 400 V       operating condition of the mains buffering     at Vin = 400 V       line frequency     50/60 Hz       line frequency     47 63 Hz       input current     -       • at rated input voltage 400 V     1.5 A       • at rated input voltage 500 V     1.2 A				
line frequency     50/60 Hz       line frequency     47 63 Hz       input current     - at rated input voltage 400 V       • at rated input voltage 500 V     1.5 A       • at rated input voltage 500 V     1.2 A				
line frequency     47 63 Hz       input current     1.5 A       • at rated input voltage 400 V     1.2 A				
input current • at rated input voltage 400 V • at rated input voltage 500 V 1.2 A				
at rated input voltage 400 V     1.5 A     at rated input voltage 500 V     1.2 A				
at rated input voltage 500 V     1.2 A				
current limitation of inrush current at 25 °C maximum 10 A				
fuse protection type in the feederthree-poled coupled circuit breaker from 4 A characteristic C to 16 A characteristic C or circuit breaker 3RV2011-1EA10 (setting 4 A) or 3RV2711 1ED10 (UL 489)				
output				
voltage curve at output Controlled, isolated DC voltage				
number of outputs 1				
output voltage at DC rated value 48 V				
output voltage				
at output 1 at DC rated value     48 V				
output voltage adjustable Yes; via potentiometer				
adjustable output voltage 48 56 V; max. 960 W (1152 W up to 45°C)				
relative control precision of the output voltage				
• on slow fluctuation of input voltage 0.2 %				
• on slow fluctuation of ohm loading 0.1 %				
residual ripple				
• maximum 100 mV				
• typical 80 mV				
voltage peak				
• maximum 80 mV				
• typical 30 mV				
display version for normal operation Green LED for 48 V OK				
type of signal at output Electronic contact (NO contact, contact rating 30 V DC/0.1 A) for DC O.K. or diagnostic interface				
behavior of the output voltage when switching on Overshoot of Vout < 1 %				

roopopoo dolov movimum	0.5 a		
response delay maximum	0.5 s		
voltage increase time of the output voltage	200 mg		
• typical	200 ms		
output current	20. A		
rated value	20 A		
rated range	0 20 A; 24 A up to +45°C; +60 +70 °C: Derating 3%/K		
supplied active power typical	960 W		
short-term overload current			
<ul> <li>on short-circuiting during the start-up typical</li> </ul>	30 A		
<ul> <li>at short-circuit during operation typical</li> </ul>	30 A		
parallel switching of outputs	can be set with DIP switch		
bridging of equipment	Yes; switchable characteristic		
number of parallel-switched equipment resources for increasing	2		
the power			
efficiency			
efficiency in percent	96.6 %		
power loss [W]			
<ul> <li>at rated output voltage for rated value of the output current typical</li> </ul>	32 W		
during no-load operation maximum	4.5 W		
closed-loop control			
relative control precision of the output voltage at load step of	4 %		
resistive load 10/90/10 % typical	4 /0		
setting time			
<ul> <li>load step 10 to 90% typical</li> </ul>	4 ms		
<ul> <li>load step 90 to 10% typical</li> </ul>	10 ms		
• maximum	10 ms		
protection and monitoring			
design of the overvoltage protection	< 60 V		
property of the output short-circuit proof	Yes		
design of short-circuit protection	Shutdown and periodic restart attempts		
typical	24 A		
overcurrent overload capability			
• in normal operation	overload capability 150 % lout rated up to 5 s/min		
safety			
galvanic isolation between input and output	Yes		
galvanic isolation	Safety extra low output voltage Vout according to EN 60950-1		
	Class I		
operating resource protection class			
operating resource protection class leakage current			
operating resource protection class	Class I		
operating resource protection class leakage current • maximum protection class IP	Class I 3.5 mA		
operating resource protection class leakage current • maximum	Class I 3.5 mA		
operating resource protection class leakage current • maximum protection class IP standard	Class I 3.5 mA IP20		
operating resource protection class leakage current • maximum protection class IP standard • for emitted interference	Class I 3.5 mA IP20 EN 55022 Class B		
operating resource protection class leakage current • maximum protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity	Class I 3.5 mA IP20 EN 55022 Class B EN 61000-3-2		
operating resource protection class         leakage current         • maximum         protection class IP         standard         • for emitted interference         • for mains harmonics limitation         • for interference immunity         standards, specifications, approvals	Class I 3.5 mA IP20 EN 55022 Class B EN 61000-3-2		
operating resource protection class leakage current • maximum protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability	Class I 3.5 mA IP20 EN 55022 Class B EN 61000-3-2		
operating resource protection class leakage current • maximum protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking	Class I 3.5 mA IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes		
operating resource protection class leakage current • maximum protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability	Class I 3.5 mA IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2		
operating resource protection class leakage current • maximum protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking	Class I 3.5 mA IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 62368-1, UL 62368-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus		
operating resource protection class leakage current • maximum protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval	Class I 3.5 mA IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 62368-1, UL 62368-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 62368-1, UL 62368-1)		
operating resource protection class leakage current • maximum protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval	Class I 3.5 mA IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 62368-1, UL 62368-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 62368-1, UL 62368-1) Yes		
operating resource protection class leakage current • maximum protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity <b>standards, specifications, approvals</b> certificate of suitability • CE marking • UL approval • CSA approval • EAC approval • Regulatory Compliance Mark (RCM)	Class I 3.5 mA IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 62368-1, UL 62368-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 62368-1, UL 62368-1) Yes Yes		
operating resource protection class         leakage current         • maximum         protection class IP         standard         • for emitted interference         • for mains harmonics limitation         • for interference immunity         standards, specifications, approvals         certificate of suitability         • CE marking         • UL approval         • CSA approval         • EAC approval         • Regulatory Compliance Mark (RCM)         • NEC Class 2	Class I 3.5 mA IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 62368-1, UL 62368-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 62368-1, UL 62368-1) Yes Yes No		
operating resource protection class         leakage current         • maximum         protection class IP         standard         • for emitted interference         • for interference immunity         standards, specifications, approvals         certificate of suitability         • CE marking         • UL approval         • CSA approval         • Regulatory Compliance Mark (RCM)         • NEC Class 2         • SEMI F47	Class I 3.5 mA IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 62368-1, UL 62368-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 62368-1, UL 62368-1) Yes Yes		
operating resource protection class         leakage current         • maximum         protection class IP         standard         • for emitted interference         • for interference immunity         standards, specifications, approvals         certificate of suitability         • CE marking         • UL approval         • EAC approval         • Regulatory Compliance Mark (RCM)         • NEC Class 2         • SEMI F47         type of certification	Class I 3.5 mA IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 62368-1, UL 62368-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 62368-1, UL 62368-1) Yes Yes No Yes		
operating resource protection class leakage current • maximum protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • CSA approval • EAC approval • Regulatory Compliance Mark (RCM) • NEC Class 2 • SEMI F47 type of certification • BIS	Class I 3.5 mA IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 62368-1, UL 62368-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 62368-1, UL 62368-1) Yes Yes Yes No Yes Yes; R-41183539		
operating resource protection class         leakage current         • maximum         protection class IP         standard         • for emitted interference         • for mains harmonics limitation         • for interference immunity         standards, specifications, approvals         certificate of suitability         • CE marking         • UL approval         • EAC approval         • Regulatory Compliance Mark (RCM)         • NEC Class 2         • SEMI F47         type of certification         • BIS         • CB-certificate	Class I 3.5 mA IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 62368-1, UL 62368-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 62368-1, UL 62368-1) Yes Yes No Yes		
operating resource protection class         leakage current         • maximum         protection class IP         standard         • for emitted interference         • for mains harmonics limitation         • for interference immunity         standards, specifications, approvals         certificate of suitability         • CE marking         • UL approval         • Regulatory Compliance Mark (RCM)         • NEC Class 2         • SEMI F47         type of certification         • BIS         • CB-certificate         standards, specifications, approvals hazardous environments	Class I 3.5 mA IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 62368-1, UL 62368-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 62368-1, UL 62368-1) Yes Yes Yes No Yes Yes; R-41183539		
operating resource protection class         leakage current         • maximum         protection class IP         standard         • for emitted interference         • for mains harmonics limitation         • for interference immunity         standards, specifications, approvals         certificate of suitability         • CE marking         • UL approval         • EAC approval         • Regulatory Compliance Mark (RCM)         • NEC Class 2         • SEMI F47         type of certification         • BIS         • CB-certificate	Class I 3.5 mA IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 62368-1, UL 62368-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 62368-1, UL 62368-1) Yes Yes Yes No Yes Yes; R-41183539		


• ATEX	No		
	No		
ULhazloc approval	No		
cCSAus, Class 1, Division 2	No		
<ul> <li>FM registration</li> <li>standards, specifications, approvals marine classification</li> </ul>	No		
	Vec		
shipbuilding approval	Yes		
Marine classification association	Vez		
American Bureau of Shipping Europe Ltd. (ABS)	Yes		
French marine classification society (BV)	No		
Det Norske Veritas (DNV)	No; in preparation		
Lloyds Register of Shipping (LRS)	No		
standards, specifications, approvals Environmental Product De			
Environmental Product Declaration	Yes		
Global Warming Potential [CO2 eq]			
• total	1 042.1 kg		
during manufacturing	39.2 kg		
during operation	1 001.5 kg		
after end of life	0.97 kg		
ambient conditions			
ambient temperature			
<ul> <li>during operation</li> </ul>	-30 +70 °C; with natural convection a monotonically increasing start-up from -25 °C, safe start-up from -40 °C		
during transport	-40 +85 °C		
during transport     during storage	-40 +65 °C		
environmental category according to IEC 60721 connection method	Climate class 3K3, 5 95% no condensation		
	nuch is terminals		
type of electrical connection	push-in terminals		
at input	L1, L2, L3, PE: push-in for 0.5 10 mm <sup>2</sup>		
at output	+1, +2, -1, -2, -3: push-in for 0.75 16 mm <sup>2</sup>		
for auxiliary contacts	13, 14 (alarm signal): 1 push-in terminal each for 0.2 1.5 mm <sup>2</sup>		
mechanical data	05		
width × height × depth of the enclosure	95 × 155		
installation width × mounting height	95 mm		
required spacing			
• top	45 mm		
• bottom	45 mm		
• left	0 mm		
• right	0 mm		
fastening method	Snaps onto DIN rail EN 60715 35x7.5/15		
standard rail mounting	Yes		
• S7 rail mounting	No		
wall mounting	No		
housing can be lined up	Yes		
net weight	2.1 kg		
accessories			
electrical accessories	Buffer module, redundancy module		
mechanical accessories	Identification labels SIMATIC ET 200SP 6ES7193-6LF30-0AW0		
further information internet links			
internet link			
<ul> <li>to website: Industry Mall</li> </ul>	https://mall.industry.siemens.com		
<ul> <li>to web page: selection aid TIA Selection Tool</li> </ul>	https://siemens.com/tst		
<ul> <li>to website: Industrial communication</li> </ul>	http://www.siemens.com/simatic-net		
<ul> <li>to website: CAx-Download-Manager</li> </ul>	http://www.siemens.com/cax		
to website: Industry Online Support	https://support.industry.siemens.com		
additional information			
other information	Specifications at rated input voltage and ambient temperature +25 $^\circ\text{C}$ (unless otherwise specified)		
security information			
security information	Siemens provides products and solutions with industrial cybersecurity functions that support the secure operation of plants, systems, machines and networks. In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic,		

state-of-the-art industrial cybersecurity concept. Siemens' products and solutions constitute one element of such a concept. Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place. For additional information on industrial cybersecurity measures that may be implemented, please visit www.siemens.com/cybersecurity-industry. Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongly recommends that product updates are applied as soon as they are available and that the latest product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats. To stay informed about product updates, subscribe to the Siemens.com/cert. (V4.7)

## Classifications

	Version	Classification
eClass	14	27-04-07-01
eClass	12	27-04-07-01
eClass	9.1	27-04-07-01
eClass	9	27-04-07-01
eClass	8	27-04-90-02
eClass	7.1	27-04-90-02
eClass	6	27-04-90-02
ETIM	9	EC002540
ETIM	8	EC002540
ETIM	7	EC002540
IDEA	4	4130
UNSPSC	15	39-12-10-04

General Product Approval



last modified:

5/22/2024 🖸