SIEMENS

Data sheet 6EP1961-2BA21



Figure similar

SITOP PSE200U/4X3-10A/CSC

SITOP PSE200U 10 A selectivity module 4-channel input: 24 V DC/40 A output: 24 V DC/4x 10 A threshold adjustable 3-10 A with common signaling contact

input			
type of the power supply network	Controlled DC voltage		
supply voltage at DC rated value	24 V		
input voltage at DC	22 30 V		
overvoltage overload capability	35 V		
input current at rated input voltage 24 V rated value	40 A		
output			
voltage curve at output	controlled DC voltage		
formula for output voltage	Vin - approx. 0.2 V		
relative overall tolerance of the voltage note	In accordance with the supplying input voltage		
number of outputs	4		
output current up to 60 °C per output rated value	10 A		
Adjustable output current	3 10 A		
type of response value setting	via potentiometer		
response delay maximum	5 s		
product feature parallel switching of outputs	No		
type of outputs connection	Simultaneous connection of all outputs after power up of the supply voltage > 20 V, delay time of 25 ms, 100 ms or adjustable "load optimised" via DIP switch for sequential connection		
power loss			
efficiency in percent	99 %		
power loss [W] at rated output voltage for rated value of the output current typical	10 W		
switch-off characteristic			
switching characteristic			
 of the excess current 	lout = 1.01.5 x set value, switch-off after approx. 5 s		
 of the current limitation 	lout = 1.5 x set value, switch-off after typ. 100 ms		
 of the immediate switch-off 	lout > set value and Vin < 20 V, switch-off after approx. 0.5 ms		
residual current at switch-off typical	1 mA		
design of the reset device/resetting mechanism	via sensor per output		
remote reset function	Non-electrically isolated 24 V input (signal level "high" at > 15 V)		
protection and monitoring			
fuse protection type at input	15 A per output (not accessible)		
display version for normal operation	Three-color LED per output: green LED for "Output switched through"; yellow LED for "Output switched off manually"; red LED for "Output switched off due to overcurrent"		
design of the switching contact for signaling function	Common signal contact (changeover contact, rating 0.1 A/24 V DC)		
safety			
galvanic isolation between input and output at switch-off	No		
standard for safety	according to EN 60950-1 and EN 50178		

operating resource protection class	0		
	Class III		
protection class IP	IP20		
standard			
for emitted interference	EN 55022 Class B		
 for interference immunity 	EN 61000-6-2		
standards, specifications, approvals			
certificate of suitability			
CE marking	Yes		
UL approval	Yes; UL-Recognized (UL 2367) File E328600; cULus-Listed (UL 508, CSA		
	C22.2 No. 107.1) File E197259		
EAC approval	Yes		
type of certification			
CB-certificate	Yes		
MTBF at 40 °C	540 979 h		
standards, specifications, approvals hazardous environments			
certificate of suitability			
• IECEx	No		
• ATEX	No		
standards, specifications, approvals marine classification			
shipbuilding approval	Yes		
Marine classification association			
American Bureau of Shipping Europe Ltd. (ABS)	Yes		
Det Norske Veritas (DNV)	Yes		
bet Norske Veritas (DNV) standards, specifications, approvals Environmental Product Dec			
Environmental Product Declaration	Yes		
Global Warming Potential [CO2 eq]			
• total	322 kg		
during manufacturing	20.9 kg		
during operation	250.4 kg		
after end of life	0.33 kg		
ambient conditions			
ambient temperature			
 during operation 	-25 +60 °C; with natural convection		
during transport	-40 +85 °C		
during storage	-40 +85 °C		
environmental category according to IEC 60721	Climate class 3K3, 5 95% no condensation		
connection method			
type of electrical connection	screw terminal		
• at input	+24 V: 2 screw terminals for 0.5 16 mm²; 0 V: 2 screw terminals for 0.5 4 mm²		
• at output	Output 1 4: 1 screw terminal each for 0.5 4 mm²		
at outputfor auxiliary contacts	Output 1 4: 1 screw terminal each for 0.5 4 mm ² Remote reset: 1 screw terminal for 0.5 4 mm ²		
•			
• for auxiliary contacts	Remote reset: 1 screw terminal for 0.5 4 mm ²		
for auxiliary contacts for signaling contact	Remote reset: 1 screw terminal for 0.5 4 mm ²		
for auxiliary contacts for signaling contact mechanical data	Remote reset: 1 screw terminal for 0.5 4 mm ² 3 screw terminals for 0.5 4 mm ²		
for auxiliary contacts for signaling contact mechanical data width × height × depth of the enclosure installation width × mounting height	Remote reset: 1 screw terminal for 0.5 4 mm ² 3 screw terminals for 0.5 4 mm ² $72 \times 80 \times 72 \text{ mm}$		
for auxiliary contacts for signaling contact mechanical data width × height × depth of the enclosure installation width × mounting height required spacing	Remote reset: 1 screw terminal for 0.5 4 mm ² 3 screw terminals for 0.5 4 mm ² $72 \times 80 \times 72 \text{ mm}$		
for auxiliary contacts for signaling contact mechanical data width × height × depth of the enclosure installation width × mounting height required spacing top	Remote reset: 1 screw terminal for 0.5 4 mm ² 3 screw terminals for 0.5 4 mm ² 72 × 80 × 72 mm 72 × 180 mm 50 mm		
for auxiliary contacts for signaling contact mechanical data width × height × depth of the enclosure installation width × mounting height required spacing top bottom	Remote reset: 1 screw terminal for 0.5 4 mm ² 3 screw terminals for 0.5 4 mm ² 72 × 80 × 72 mm 72 × 180 mm 50 mm		
for auxiliary contacts for signaling contact mechanical data width × height × depth of the enclosure installation width × mounting height required spacing top bottom left	Remote reset: 1 screw terminal for 0.5 4 mm² 3 screw terminals for 0.5 4 mm² 72 × 80 × 72 mm 72 × 180 mm 50 mm 50 mm 0 mm		
for auxiliary contacts for signaling contact mechanical data width × height × depth of the enclosure installation width × mounting height required spacing top bottom left right	Remote reset: 1 screw terminal for 0.5 4 mm² 3 screw terminals for 0.5 4 mm² 72 × 80 × 72 mm 72 × 180 mm 50 mm 0 mm 0 mm		
for auxiliary contacts for signaling contact mechanical data width × height × depth of the enclosure installation width × mounting height required spacing top bottom left right fastening method	Remote reset: 1 screw terminal for 0.5 4 mm² 3 screw terminals for 0.5 4 mm² 72 × 80 × 72 mm 72 × 180 mm 50 mm 0 mm 0 mm Snaps onto DIN rail EN 60715 35x7.5/15		
for auxiliary contacts for signaling contact mechanical data width × height × depth of the enclosure installation width × mounting height required spacing top bottom left right fastening method standard rail mounting	Remote reset: 1 screw terminal for 0.5 4 mm² 3 screw terminals for 0.5 4 mm² 72 × 80 × 72 mm 72 × 180 mm 50 mm 0 mm 0 mm Snaps onto DIN rail EN 60715 35x7.5/15 Yes		
for auxiliary contacts for signaling contact mechanical data width × height × depth of the enclosure installation width × mounting height required spacing top bottom left right fastening method standard rail mounting S7 rail mounting	Remote reset: 1 screw terminal for 0.5 4 mm² 3 screw terminals for 0.5 4 mm² 72 × 80 × 72 mm 72 × 180 mm 50 mm 50 mm 0 mm 0 mm Snaps onto DIN rail EN 60715 35x7.5/15 Yes No		
for auxiliary contacts for signaling contact mechanical data width × height × depth of the enclosure installation width × mounting height required spacing top bottom left right fastening method standard rail mounting S7 rail mounting wall mounting	Remote reset: 1 screw terminal for 0.5 4 mm² 3 screw terminals for 0.5 4 mm² 72 × 80 × 72 mm 72 × 180 mm 50 mm 50 mm 0 mm Snaps onto DIN rail EN 60715 35x7.5/15 Yes No No		
for auxiliary contacts for signaling contact mechanical data width × height × depth of the enclosure installation width × mounting height required spacing top bottom left right fastening method standard rail mounting S7 rail mounting wall mounting housing can be lined up	Remote reset: 1 screw terminal for 0.5 4 mm² 3 screw terminals for 0.5 4 mm² 72 × 80 × 72 mm 72 × 180 mm 50 mm 0 mm 0 mm Snaps onto DIN rail EN 60715 35x7.5/15 Yes No No		
for auxiliary contacts for signaling contact mechanical data width × height × depth of the enclosure installation width × mounting height required spacing top bottom left right fastening method standard rail mounting S7 rail mounting wall mounting housing can be lined up net weight	Remote reset: 1 screw terminal for 0.5 4 mm² 3 screw terminals for 0.5 4 mm² 72 × 80 × 72 mm 72 × 180 mm 50 mm 50 mm 0 mm Snaps onto DIN rail EN 60715 35x7.5/15 Yes No No		
for auxiliary contacts for signaling contact mechanical data width × height × depth of the enclosure installation width × mounting height required spacing top bottom left right fastening method standard rail mounting S7 rail mounting wall mounting housing can be lined up net weight accessories	Remote reset: 1 screw terminal for 0.5 4 mm² 3 screw terminals for 0.5 4 mm² 72 × 80 × 72 mm 72 × 180 mm 50 mm 0 mm 0 mm Snaps onto DIN rail EN 60715 35x7.5/15 Yes No No Yes 0.2 kg		
for auxiliary contacts for signaling contact mechanical data width × height × depth of the enclosure installation width × mounting height required spacing top bottom left right fastening method standard rail mounting S7 rail mounting wall mounting housing can be lined up net weight accessories mechanical accessories	Remote reset: 1 screw terminal for 0.5 4 mm² 3 screw terminals for 0.5 4 mm² 72 × 80 × 72 mm 72 × 180 mm 50 mm 0 mm 0 mm Snaps onto DIN rail EN 60715 35x7.5/15 Yes No No		
for auxiliary contacts for signaling contact mechanical data width × height × depth of the enclosure installation width × mounting height required spacing top bottom left right fastening method standard rail mounting S7 rail mounting wall mounting housing can be lined up net weight accessories	Remote reset: 1 screw terminal for 0.5 4 mm² 3 screw terminals for 0.5 4 mm² 72 × 80 × 72 mm 72 × 180 mm 50 mm 0 mm 0 mm Snaps onto DIN rail EN 60715 35x7.5/15 Yes No No Yes 0.2 kg		

• to website: Industry Mall

• to web page: selection aid TIA Selection Tool

• to website: Industrial communication

• to website: CAx-Download-Manager

• to website: Industry Online Support

https://mall.industry.siemens.com

https://siemens.com/tst

http://www.siemens.com/simatic-net

http://www.siemens.com/cax

https://support.industry.siemens.com

additional information

other information

Specifications at rated input voltage and ambient temperature +25 $^{\circ}\text{C}$ (unless otherwise specified)

security information

security information

Siemens provides products and solutions with industrial cybersecurity functions that support the secure operation of plants, systems, machines and networks. In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic, state-of-the-art industrial cybersecurity concept. Siemens' products and solutions constitute one element of such a concept. Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place. For additional information on industrial cybersecurity measures that may be implemented, please visit www.siemens.com/cybersecurity-industry. Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongly recommends that product updates are applied as soon as they are available and that the latest product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats. To stay informed about product updates, subscribe to the Siemens Industrial Cybersecurity RSS Feed under https://www.siemens.com/cert. (V4.7)

Classifications

	Version	Classification
eClass	14	27-37-18-02
eClass	12	27-37-18-02
eClass	9.1	27-37-18-02
eClass	9	27-37-18-02
eClass	8	27-37-18-02
eClass	7.1	27-37-18-02
eClass	6	27-37-18-02
ETIM	9	EC001440
ETIM	8	EC001440
ETIM	7	EC001440
IDEA	4	4727
UNSPSC	15	39-12-15-21

Approvals Certificates

General Product Approval





Manufacturer Declaration Declaration of Conformity





General Product Approval

For use in hazardous locations

Marine / Shipping





Miscellaneous







Environment



last modified: 5/22/2024 🖸