Name:	Vent-Axia	Vent-Axia	Vent-Axia	Vent-Axia
Model ID (Stock Ref.) :	ATQ10012D	ATQ12512D	ATQ15012D	ATQ16012D
SEC Class	C	С	C	С
SEC Value ('Average')	-24.03	-24.38	-24.44	-24.44
SEC Value ('Warm')	-8.97	-9.33	-9.38	-9.38
SEC Value ('Cold')	-51.09	-51.45	-51.50	-51.50
Label Required? (Yes/No=Out of scope)	Yes	Yes	Yes	Yes
Declared as: RVU or NRVU/UVU or BVU	RVU/UVU	RVU/UVU	RVU/UVU	RVU/UVU
Speed Drive	Multi-Speed	Multi-Speed	Multi-Speed	Multi-Speed
Type HRS (Recuperative, Regenerative, None)	None	None	None	None
Thermal Eff: [ (%), NA(if none)]	N/A	N/A	N/A	N/A
Max. Flow Rate (m3/h)	315.72	334.80	345.60	345.60
Max. Power Input (W): (@Max.Flow Rate)	52.00	52.00	52.00	52.00
LWA: Sound Power Level (dB)	N/A - (Ducted)	N/A - (Ducted)	N/A - (Ducted)	N/A - (Ducted)
Ref. Flow Rate (m3/s)	0.06	0.07	0.07	0.07
Ref. Pressure Diff. (Pa)	233	234	234	234
SPI [W/(m3/h)]	0.23	0.21	0.21	0.21
Control Factor & Control Typology: (CTRL/ Typology)				
Control Factor; CTRL	0.65	0.65	0.65	0.65
,.	Local Demand Control	Local Demand	Local Demand	Local Demand
Control Typology		Control	Control	Control
Declared: -Max Internal & External Leakage Rates(%) for BVUs or carry				
over (for regenerative heat exchangers only),	<5% Internal,	<5% Internal,	<5% Internal,	<5% Internal,
-&Ext. Leakage Rates (%) for Ducted UVUs;	<5%External	<5%External	<5%External	<5%External
- ALAI. LEBRUGE NATES (70) TOT DUCTED GVOS,				
Mixing Rate of Non-Ducted BVUs not intended to be equipped with				
	N/A	N/A	N/A	N/A
one duct connection on either supply or extract air side;				
Position and description of visual filter warning for RVUs intended for	No	No	No	No
use with filters, including text pointing out the importance of regular	***	***		
filter changes for performance and energy efficiency of the unit				
	In F&W	In F&W	In F&W	In F&W
For UVUs (Instructions Install Regulated Supply/Extract Grilles Façade)	III FOXVV	III FOLVV	III FOLVV	III FOLVV
	www.vent-axia.com	www.vent-axia.com	www.vent-axia.com	www.vent-axia.com
Internet Address (for Disassembly Instructions)	www.veiit-axia.com	www.vent-axia.com	www.veiit-axia.com	www.veiit-axia.com
Sensitivity p. Variation@+20/-20 Pa: (for Non-Ducted Vus)	N/A	N/A	N/A	N/A
Air Tightness-ID/OD-(m3/h) (for Non-Ducted Vus)	N/A	N/A	N/A	N/A
Annual Electricity Consumption: AEC (kWh/a)	1.98	1.84	1.81	1.81
Annual Heating Saved: AHS (kWh/a)				
AHS: Average	28.30	28.30	28.30	28.30
AHS: Warm	12.80	12.80	12.80	12.80
AHS: Cold	55.36	55.36	55.36	55.36