Name:	Vent-Axia
Model ID (Stock Ref.) :	Integra Plus - 437666
SEC Class	В
SEC Value ('Average')	-32.99
SEC Value ('Warm')	-11.83
SEC Value ('Cold')	-70.72
Label Required? (Yes/No=Out of scope)	Yes
Declared as: RVU or NRVU/UVU or BVU	RVU/BVU
Speed Drive	Multi-Speed
Type HRS (Recuperative, Regenerative, None)	Recuperative
Thermal Eff: [(%), NA(if none)]	70.00
Max. Flow Rate (m3/h)	406.80
Max. Power Input (W): (@Max.Flow Rate)	167.00
LWA: Sound Power Level (dB)	53.03
Ref. Flow Rate (m3/s)	0.07910
Ref. Pressure Diff. (Pa)	50.00
SPI [W/(m3/h)]	0.19
Control Factor & Control Typology: (CTRL/ Typology)	
Control Factor; CTRL	1.00
Control Typology	Manual Control
Declared: -Max Internal & External Leakage Rates(%) for BVUs or carry	.50/ 1-11 .50/
over (for regenerative heat exchangers only),	<5% Internal, <5%
-&Ext. Leakage Rates (%) for Ducted UVUs;	External
Mixing Rate of Non-Ducted BVUs not intended to be equipped with	N/A
one duct connection on either supply or extract air side;	
Position and description of visual filter warning for RVUs intended for	
use with filters, including text pointing out the importance of regular	N/A
filter changes for performance and energy efficiency of the unit	
For UVUs (Instructions Install Regulated Supply/Extract Grilles Façade)	N/A
Internet Address (for Disassembly Instructions)	www.vent-axia.com
Sensitivity p. Variation@+20/-20 Pa: (for Non-Ducted VUs)	N./A
Air Tightness-ID/OD-(m3/h) (for Non-Ducted VUs)	N./A
Annual Electricity Consumption: AEC (kWh/a)	2.85
Annual Heating Saved: AHS (kWh/a)	
AHS: Average	39.45
AHS: Warm	17.84
AHS: Cold	77.17