Long Case Axial Fan

Installation and Wiring Instructions



220-240V/1/50Hz & 380-415V/3/50Hz



READ INSTRUCTIONS IN CONJUNCTION WITH ILLUSTRATIONS PLEASE SAVE THESE INSTRUCTIONS

Vent-Axia. Installation and Wiring Instructions for the Case Axial Fan.

Ka € €

IMPORTANT: READ THESE INSTRUCTIONS BEFORE COMMENCING THE INSTALLATION

DO NOT install this product in areas where the following may be present or occur:

- Excessive oil or a grease laden atmosphere.
- Corrosive or flammable gases, liquids or vapors.
- Ambient temperatures less than -5°C or higher than 54°C.
- Relative humidity above 95%
- · Possible obstructions which would hinder the access or removal of the fan.
- Sudden ductwork bends or transformations close to the fan.

SAFETY AND GUIDANCE NOTES

Air moving equipment may present mechanical, electrical or noise hazards. To minimise the risks associated with these potential hazards, it is essential that installation, operation and maintenance instructions are followed and carried out by a suitably qualified person.

- **A.** All wiring to be in accordance with the current I.E.E. Regulations, or the appropriate standards of your country.
- **B.** The Fan should be provided with a local 2/3 pole isolator switch having a contact separation of at least 3mm.
- C. Ensure that the mains supply (Voltage, Frequency, and Phase) complies with the rating label.
- **D.** The Fan should only be used in conjunction with the appropriate Vent-Axia products.
- E. It is recommended that the connection to the terminal box is made with flexible cable/conduit.
- **F.** The fan should not be sited within 600mm horizontally of/or 2250mm vertically of a bath/shower tray, in accordance with the I.E.E. Regulations for bathrooms.
- **G.** When the Fan is used to remove air from a room containing a fuel-burning appliance, ensure that the air replacement is adequate for both the fan and the fuel-burning appliance.
- **H.** If the fan is used to supply air into a room, the installer must ensure that the fan intake is located a minimum of 600mm from any flue outlet.
- I. This fan is designed as an inline ducted fan to be positioned between lengths of ducting. Short duct runs terminating within 1.5m must incorporate suitable guards.
- J. Certain applications may require the installation of sound attenuation material, together with either an Auto Transformer or Inverter Speed Controller to achieve the sound levels required.

DESCRIPTION.

The Long Case Axial range of fans incorporates factory adjustable pitch impellers, which provide a comprehensive range of duties offering high performance and pressure characteristics. Available in twelve sizes ranging from 315mm to 1250mm \emptyset and performances from 0.24m³/s to 38m³/s with a pressure development up to 1250Pa. The casing is constructed from rolled steel plate and protected with a galvanised finish.

A. INSTALLATION.

- 1. Ensure the impeller rotates and is free from obstruction, prior to installation.
- 2. The fan is suitable for mounting at any angle.
- 3. Ensure that there is adequate clearance for accessing the fan.
- 4. Securely mount the fan using the holes in the end flanges and use the appropriate drop rods, bolts, antivibration mountings etc.
- 5. Ensure the Airflow Arrow is aligned with the direction of the airflow required.
- **6.** The use of flexible connections and anti-vibration mountings is recommended to minimise noise and vibration.
- 7. Ensure that the flexible connections are taut and the fan and ductwork are aligned.
- 8. Flexible connections **MUST** be used in conjunction with anti-vibration mountings.

9. Anti-vibration mountings must be installed in compression.

Fig.1. TYPICAL INSTALLATION (Horizontal).



WIRING



WARNING: THE FAN AND ANCILLARY CONTROL EQUIPMENT <u>MUST</u> BE ISOLATED FROM THE POWER SUPPLY DURING THE INSTALLATION / OR MAINTENANCE. THE EQUIPMENT MUST BE EARTHED

- 1. Select and follow the appropriate wiring diagram (Figs. 2-11).
- 2. Check all connections have been made correctly and ensure that all terminal connections and cable clamps are securely fastened.
- 3. The cable entry must be made using a suitable grommet or cable gland.
- 4. Switch the mains power supply on and check the fan is operating correctly.

Fig. 2. Single Phase Fan Connected to a 240V D.O.L. Starter.

Fig. 3. Single Phase Fan Connected to a 240V D.O.L. Starter an Auto Transformer Speed Controller.





240 Volt D.O.L. Starter A suitable sized overload relay must be fitted to provide motor protection.

N.B. Links between terminals 1 to A1, 3 to 6, 5 to 95 and 24 to 96 must be fitted.

Fig. 4. Three Phase Fan Connected to a 415V D.O.L. Starter.

Fig. 5. Three Phase Fan Connected to a Star / Delta Starter.



Fig. 6. Three Phase Fan

Connected to a 415V D.O.L. Starter and an Auto Transformer Speed Controller.







Fig. 7. Three Phase Fan Single Phase in – Three Phase (240V) Out LC Fan connected to an Inverter Speed Controller Kit (103 20 101).

Fig. 8. Three Phase Fan Single Phase in – Three Phase (240V) Out LC Fan connected to an Inverter Speed Controller Kit (103 20 102 or 103 20 103).



Fig. 9. Three Phase Fan.

Three Phase In – Three Phase Out. LC Fan connected to an Inverter Speed Controller Kit (103 20 301, 103 20 302, 103 20 303 or 103 20 305).



Vent-Axia.

Fig. 10. Three Phase Fan. Three Phase In – Three Phase Out. LC Fan connected to an Inverter Speed Controller Kit (103 20 350 or 103 20 310).



Fig. 11. Three Phase Fan. Three Phase In – Three Phase Out. LC Fan connected to an Inverter Speed Controller Kit (103 20 315).



ROUTINE INSPECTION AND MAINTENANCE

ISOLATE FROM THE POWER SUPPLY AND ENSURE THAT TH

1. At intervals appropriate to the installation, the fan build up of dirt or other deposits on the impeller o recommended that a filter is installed.

ACCIDENTALLY SWITCHED BACK ON.

- ted and cleaned to ensure there is no is handling dust laden air, it is
- 2. All Case Axial fans have sealed for life bearings and do not require lubrication.
- 3. Check the condition and security of all fixing bolts, rods, anti-vibration mountings, and flexible connections.



Vent-Axia

Head Office: Fleming Way, Crawley, West Sussex, RH10 9YX. Tel: 01293 526062 Fax: 01293 551188 EU Authorised Representative: Vent-Axia Bedrijvenweg 17 7442 CX Nijverdal Nederland authorisedrep@vent-axia.nl

UK NATIONAL CALL CENTRE, Newton Road, Crawley, West Sussex, RH10 9JA

SALES ENQUIRIES: TECHNICAL SUPPORT: Web:-www.vent-axia.com Tel: 0844 8560590 Fax: 01293 565169 Tel: 0844 8560594 Fax: 01293 539209 Email:- <u>info@vent-axia.com</u>

As part of the policy of continuous product improvement Vent-Axia reserves the right to alter specifications without notice.

443395B