# Data Sheet | Item Number: 249-130

Syringe; Contents: Aluminum Contact Paste, 20 ml

https://www.wago.com/249-130



## Material data

| | |
|---|---|
| Weight | 35.3 g |

## Commercial data

| | |
|---|---|
| Product Group | 2 (Terminal Block Accessories) |
| PU (SPU) | 5 (5) pcs |
| Packaging type | Box |
| Country of origin | DE |
| GTIN | 4066966600957 |
| Customs tariff number | 34039900000 |

## Product Classification

| | |
|---|---|
| UNSPSC | 31201602 |
| eCl@ss 10.0 | 27-14-11-92 |
| eCl@ss 9.0 | 27-14-11-92 |
| ETIM 9.0 | EC002848 |
| ETIM 10.0 | EC002848 |
| ECCN | NO US CLASSIFICATION |

## Environmental Product Compliance

| | |
|---|---|
| RoHS Compliance Status | Compliant,No Exemption |

## Downloads

### Environmental Product Compliance

**Compliance Search**

Environmental Product Compliance 249-130

### Documentation

**Safety Data Sheet**

| | | |
|---|---|---|
| Connection of aluminum conductors | pdf 236.24 KB | |

**Bid Text**

| | | |
|---|---|---|
| 249-130 | 17.05.2017 | doc 23.50 KB |
| 249-130 | 19.02.2019 | xml 2.49 KB |


### CAD/CAE-Data

**CAE data**

EPLAN Data Portal 249-130

## Installation Notes

### Application




WAGO Rail-Mount Terminal Blocks (up to 4 mm²/12 AWG)
For each conductor entry: Insert nozzle of the syringe in every open conductor entry hole (one after the other).




Press plunger down **until aluminum contact paste has filled all conductor entry holes.**

### Application



**WAGO Lighting Connectors**
Push nozzle of the syringe first into the circular entry and then into the square conductor entry hole of the WAGO Lighting Connector.




Press the plunger down **until aluminum contact paste has filled both entry holes.**


**Note:** Not suitable for higher temperature applications!


Continued on next page

## Application



1. Push nozzle of the syringe into every open conductor entry hole (one after the other).



2. Press plunger down until aluminum contact paste has filled all conductor entry holes.